



12 December 2016

CANTIMBER BIOTECH INC.

Operations and Emissions Evaluation

Submitted to:

Port Alberni Port Authority
2750 Harbour Road
Port Alberni, BC
V9Y 7X2

Attention: David. A. McCormick, MBA
Director Public Relations & Business Development

REPORT



Reference Number: 1661112-004-R-Rev0-1

Distribution:

1 Electronic Copy - Port Alberni Port Authority
1 Hard Copy - Port Alberni Port Authority
1 Hard Copy - Golder Associates Ltd.





Table of Contents

1.0 INTRODUCTION.....1

2.0 FINDINGS AND RECOMMENDATIONS2

 2.1 Process Observations.....2

 2.1.1 Combustion Chambers (Carbonization Process)2

 2.1.2 Scrubber System (Carbonization and Activation Process).....3

 2.1.3 Fugitive Emissions - Carbonization Process4

 2.1.4 Fugitive Emissions – Activation Process.....4

 2.1.5 Activation Controls (Feed Rate and Temperature).....4

 2.1.6 Water Discharges5

 2.1.7 Process Operation Recommendations.....5

 2.2 Stack Test Results.....6

 2.2.1 Daily Emission Rates6

 2.2.2 Annual Emissions8

 2.2.3 Stack Test Recommendations9

 2.3 Ambient Monitoring.....10

 2.3.1 Wind monitoring10

 2.3.2 Continuous Particulate Monitoring12

 2.3.3 Partisol Monitoring by Cantimber15

 2.3.4 Ambient Monitoring Recommendations16

 2.4 Other Regulatory Considerations.....16

 2.4.1 Regulatory Consideration Recommendations.....16

3.0 SUMMARY OF RECOMMENDATIONS18

4.0 LIMITATIONS20

5.0 CLOSURE.....21

REFERENCE22



TABLES

Table 1: Comparison of Stack Test Results and License Levels.....	7
Table 2: Annual Emissions.....	8
Table 3: DustTrak Monitor Data Completeness	12
Table 4: Summary of Recommendations	18

FIGURES

Figure 1: Carbonization Stack Run 2 Comparison of Combustion Chamber Temperature and VOC Concentration	3
Figure 2: Cantimber and Port Alberni Elementary School Wind Rose Comparison 11:00, 1 November to 11:00, 15 November.....	11
Figure 3: Cantimber Wind Rose Plot during Operation for Stack Test (17:00 November 7th to 17:00 November 9th) .	11
Figure 4: Daily Ambient Monitoring Data – DustTrak Located at South Street/1 Avenue.....	13
Figure 5: Ambient Monitoring Data - DustTrak Located at Stirling Street/1 Avenue.....	14
Figure 6: Hourly Concentration Distribution – DustTrak Located at South Street and 1 Avenue.....	14
Figure 7: Hourly Concentration Distribution – DustTrak Located at Stirling Street and 1 Avenue	15
Figure 8: Daily Particulate Concentrations 2 to 12 November.....	15

PHOTOGRAPHS

Photograph 1: Activation Process Cooling Tower and Water Discharge.....	5
---	---

APPENDICES

APPENDIX A

Stack Test Report



1.0 INTRODUCTION

The Port Alberni Port Authority (PAPA) commissioned Golder to assist with the evaluation of operations and emissions for the Cantimber Biotech Inc. (Cantimber) facility at Port Alberni, BC. The evaluation comprised a site visit to the facility, design of a stack testing program, stack testing to characterize emissions from the facility, observations and monitoring during the facility operation and provision of key findings and associated recommendations.

The Cantimber facility ceased operations at the request of PAPA in June 2016, and therefore was not operational prior to the November stack test period. The facility was shut down after the stack test, and cannot commence operations until 10 January (as stipulated in the license agreement between PAPA and Cantimber).

A staged approach to the stack testing was taken, with testing of the carbonization stack and the activation stack occurring on 8 and 9 November respectively. The stack testing was undertaken between by A. Lanfranco and associates, and Golder representatives were present during the stack testing to observe the operation of the facility, and to undertake monitoring for fugitive emissions within and around the facility, and ambient monitoring within the nearby residential area.

This report provides key findings and recommendations around the following:

- observations made during the operation of facility
- stack test results
- meteorological and ambient air quality monitoring undertaken during the stack test period
- other regulatory considerations



2.0 FINDINGS AND RECOMMENDATIONS

2.1 Process Observations

The process is a batch operation with two distinct process stages – carbonization and activation. During the carbonization process the wood chips contained within the carbonization vessels undergo pre-heating at a temperature of 100-120 °C for 3-5 hours. Carbonization heating then occurs at a temperature of 100-500 °C for 2.5 to 3 hours. When the vessel reaches 500 °C, the vessel is removed from the heating stage and cooling begins. The vessel slowly cools to room temperature. Each carbonization vessel is heated by an individual furnace beneath each vessel. Syngas produced within the carbonization vessels is used as a fuel source in the carbonization furnaces in addition to cordwood. The exhaust gas from the carbonization furnace then goes into the east or west combustion chamber for secondary combustion.

At some points in the carbonization process, not all the syngas produced is needed in the carbonization furnaces, so syngas can also travel directly to the east or west combustion chamber (and hence this is the primary mechanism to combust this syngas). All gases produced in the pre-heating vessels are combusted solely in the east and west combustion chambers. As a result of the means by which the syngas can be generated and combusted, it appears that the rate of syngas fuel for the east and west combustion chambers varies over time. Therefore, in addition to the syngas, the two combustion chambers (east and west) are fuelled by bottled propane and manual charcoal addition. Flue gas from the east and west combustion chambers is directed through a cyclone and wet scrubber prior to discharge through the carbonization stack.

Following the carbonization process the charcoal is crushed and ground in preparation for the activation stage.

During the activation process the charcoal is automatically fed at a constant rate through an activation furnace with a fluidized bed combustion process and steam injection. Flue gas is fed through a heat exchanger, which supplies heat for use in steam production. Flue gas is directed through a cyclone, baghouse and wet scrubber prior to discharge through the activation stack.

2.1.1 Combustion Chambers (Carbonization Process)

The carbonization process is not a steady state process due to the batch nature of bringing different vessels in/out of the process, and syngas line. The 8 individual carbonization vessels are generally at different stages in the carbonization process, can be at different temperatures, and therefore be producing different amounts of syngas. This is expected to result in a variation in the composition of the syngas feeding into the east and west combustion chambers.

To keep the combustion chambers temperature above 875 °C charcoal was added manually, approximately twice an hour. The timing of the charcoal addition was entirely dependent on the chamber temperature, and was therefore not added on a regular time basis (e.g., every 30 minutes). The temperature in the chamber relied on the operator visually monitoring the temperature read out, and acting to add more charcoal when the temperature decreased close to 875 °C.



The temperature within the combustion chambers typically varied by around 100 °C over an hour, with the temperature quickly rising after the charcoal was added. Figure 1 shows the minute by minute correlation of the combustion temperatures and the total Volatile Organic Content (VOC) stack concentrations (reported as Total Hydrocarbons – THC) for one of the three stack tests. The other two stack runs showed similar data trends. The VOC concentrations did not vary significantly over the test run (24-29 ppm), and did not appear to directly correlate to the combustion chamber temperatures. The combustion chamber temperatures were maintained above 850°C, which is probably why the VOC concentrations remained fairly consistent (i.e., the control efficiency of the device was maintained above a reasonable level).




Figure 1: Carbonization Stack Run 2 Comparison of Combustion Chamber Temperature and VOC Concentration

2.1.2 Scrubber System (Carbonization and Activation Process)

Currently, when the solids content in the scrubber sump becomes too great, the sump water is released to the containment and is evaporated to the atmosphere. The containment may not be adequate, particularly during periods of significant rainfall. During the evaporation, any water soluble organic compounds collected by the scrubbers have the potential to be re-emitted to the atmosphere. During the site visit, an upgrade to the scrubber water system was discussed which includes capturing scrubber sump discharges within plastic containers, and subsequent removal off site for disposal. It is Golder's understanding that these upgrades are currently in process and will be in place prior to the re-start of operations.

Scrubbers operate on the principle of removing air emissions and collecting them in the scrubber solution, in this case water. As the water collects material it becomes more concentrated. A wet scrubber by nature will have water losses due to droplet carry-out and evaporation. Droplets that are emitted will dry and release any particulate that they carry. Therefore it is necessary to remove some scrubber water from the sump (blowdown) as the concentration of collected emissions goes up. There should be a mechanism/procedure in place to replace the scrubber water on a regular basis so the concentration of particulate in the scrubber water does not become too great. Currently the scrubbers have no means of regular blowdown to maintain a low particulate concentration.



2.1.3 Fugitive Emissions - Carbonization Process

The combustion chamber door, seals around the vessel lids, liquid seal around the vessel nose, furnace doors and syngas pipe connections to the furnaces were monitored for potential fugitive emissions as total VOCs using a ppbRAE. In addition, fugitive VOC levels were monitored at building openings and directly outside the facility buildings to the north, east and west (the facility is bounded to the south by an adjacent building so no measurements were possible directly to the south).

VOC concentrations around the vessel lids and seals typically ranged from 100 ppb to 10 ppm, with peak (instantaneous) readings up to 57 ppm. Concentrations around the combustion chamber (east and west) doors ranged from 150 ppb to 460 ppb.

During the monitoring a leak was detected near the fire door of eastern furnace #4, which was traced to the nearby syngas valve. Concentrations at the leak location were detected up to 40 ppm. A temporary seal was made to the leak at the time it was detected. Concentrations at the other syngas valves ranged from 200 ppb to 15 ppm.

VOC concentrations at building openings (large doors) and the area immediately surrounding the buildings were found to be 0 ppb, with the exception of the western side of the building, directly under the building vent, where concentrations ranged from 40 to 250 ppb. The concentration dropped down to 10 ppb a few meters away from the building vent indicating off site concentrations are not expected to be significant.

The measurements of fugitive emissions were limited to measuring total VOC concentrations, the volume (or flow rate) of the emissions was not measured given the practical difficulties in doing this. However, it is expected that the volume of fugitive emissions are relatively small. Currently there is no formal process, procedure or instrumentation available at the facility to check for equipment leaks and monitor the relative magnitude of fugitive emissions from various sources at the facility.

2.1.4 Fugitive Emissions – Activation Process

The furnace door, temperature probe locations on the top of the activation chamber, and welded sections of the top of the activation chamber were monitored for potential fugitive emissions using a ppbRAE to measure total VOC. During operation of the activation process, periodic monitoring for fugitive VOC levels was undertaken at building openings and directly outside the facility buildings to the north, east and west.

Monitored concentrations of total VOCs were consistently 0.0 ppb, therefore no sources of fugitive emissions were identified from the activation process. Similarly, concentrations of total VOC at process building openings, and directly outside facility buildings were found to be 0.0 ppb.

2.1.5 Activation Controls (Feed Rate and Temperature)

The activation system is generally more automated than the carbonization process. The two main operation variables identified that had the potential to affect emissions were the temperature and the feed rate.

Temperature is monitored at three points within the activation chamber. During the stack testing, the temperatures were observed to be fairly constant, typically only varying within a 15 °C range over an hour period.



The activation feed rate (displayed in cycles per second or hertz (Hz)) can be changed by the operator. This value in Hz relates to the rotational speed of the feeder that introduced the charcoal dust into the activation chamber, the higher the value the greater the feed rate. The feed rate was initially set at 4.6 and 4.2 Hz for the stack testing, however in discussions with Cantimber it was set at 5.0 Hz – the maximum that Cantimber would operate the process at, for the 3rd test run.

2.1.6 Water Discharges

Cooling water discharges were identified during the facility operation. The cooling water is non-contact water that is not in direct contact with the process gases.

- Cooling water from the carbonization process was periodically discharging from the cooling tank located directly outside the northern wall of the main process building. The temperature of the water discharge was estimated to be 50-70 °C. The water was discharged to a surface water drain.
- Cooling water from the activation process continually discharged from the cooling tower located adjacent to the northwest corner of the main process building. The temperature of the water discharge was estimated to be 30-40 °C. The water was discharged to a surface water drain (Photograph 1).



Photograph 1: Activation Process Cooling Tower and Water Discharge

2.1.7 Process Operation Recommendations

The following recommendations are provided on the process operations:

- The fuel source for the high temperature combustion chamber is changed to natural gas and is automated to avoid the current manual system of operation. It is unusual for a facility to rely on manual operation of an air emission control system.



- A low temperature audible alarm is installed on both high temperature combustion chambers, this is considered to be industry best practice.
- A datalogger is installed to record temperatures within both high temperature combustion chambers. This is considered to be an industry best practice and provides an automated record of combustion temperatures that can be inspected by the regulator. Readings should be taken and recorded no less frequent than once per minute. Records of the feed rate and temperature logs should be retained for inspection for no less than 2 years.
- The scrubber water disposal system should be upgraded to a contained system prior to the facilities resumed operation. Regular blowdown of scrubber water and replacement with fresh makeup water should be implemented.
- Regular fugitive emission surveys are undertaken on the carbonization process. Any leaks identified should be addressed immediately.
- Although fugitive emissions are not considered to specifically be an ambient air quality concern outside of the facility boundaries, an industrial hygiene assessment of worker exposure should be undertaken to ensure workers exposures are below exposure limits. This assessment should conform to WorkSafe BC requirements.
- Cooling water should be adequately cooled prior to discharge to surface water drains.

2.2 Stack Test Results

2.2.1 Daily Emission Rates

Table 1 provides a summary of the stack test results. A comparison is provided against the emission rates used as the basis of the dispersion modelling assessment undertaken by Levelton (Levelton 2015). These modelled values are hereafter referred to as the license levels, since they are included in the license between PAPA and Cantimber Biotech Inc. dated 1 May 2015. It should be noted that the basis of the modelling was both activation trains operational, whereas during the stack testing only one activation train was operational. In order to compare against license levels, emissions from the activation stack were multiplied by 2.

For the activation process, the feed rate was slightly different at 4.6, 4.2 and 5.0 Hz for stack runs 1, 2, and 3 respectively. For the activation stack results are presented for run 3, which had the highest activation process feed rate. The full stack test report is included in Appendix A.



OPERATIONS AND EMISSIONS EVALUATION

Table 1: Comparison of Stack Test Results and License Levels

Parameter	Units	Carbonization Stack		Activation Stack		
		License Levels/Basis of Modelling	Stack Test (Average)	License Levels/Basis of Modelling (2 Activation Trains)	Stack Test (Run 3) (1 Activation Train)	Stack Test (Run 3, Emissions Multiplied by 2 to Represent 2 Activation Trains)
Emissions						
Total Particulate	Kg/day	-	0.72	-	0.048	0.096
PM ₁₀ ^(a)	Kg/day	-	0.38	-	0.048	0.096
PM _{2.5} ^(b)	Kg/day	2.08	0.12	3.47	0.030	0.060
Nitrogen Dioxide (NO ₂)	Kg/day	4.15	2.88	2.77	2.4	4.8
Carbon Monoxide (CO)	Kg/day	2.08	4.56	4.15	547.2	1094.4
VOC (THC as CH ₄)	Kg/day	-	0.96	-	3.12	6.24
Sulphur Dioxide (SO ₂)	Kg/day	-	0.12	-	0.024	0.05
Phenol	Kg/day	-	0.009	-	0.004	0.01
Formaldehyde	Kg/day	-	0.59	-	0.02	0.04
Methanol	Kg/day	-	0.11	-	0.09	0.18
Stack Parameters						
Stack Temperature	°C	150	59	100	58	-
Flow Rate	Sm ³ /hour	2500	1836	5000	1644	-
Velocity	m/s	11.4	5.6	30.4	7.3	-

Values in bold indicate mass emission rates higher than license levels.

- a) Suspended particles with a nominal aerodynamic diameter of 10 µm or less.
- b) Suspended particles with a nominal aerodynamic diameter of 2.5 µm or less.

- = Indicates no license emission level for comparison. During the stack test, the carbon monoxide concentrations within the activation stack exceeded the maximum range of the analyzer, and therefore concentrations were determined from a canister sample for each run.



2.2.2 Annual Emissions

Table 2 provides a summary of the emissions on an annual basis, based on the stack test data in Table 1 above, and assuming continuous 24 hour operation for 305 days per year, with 60 days shut down per year between November 10th and January 10th (as per the restriction within the license). To derive the total facility emissions in Table 2 below, the activation test data has been multiplied by 2 to account for both activation trains being operational.

For context, annual emissions have been compared to emissions from facilities within Port Alberni that reported air emissions for the 2015 calendar year to the National Pollutant Release Inventory (NPRI).

Table 2: Annual Emissions

Emission	Units	Carbonization Stack	Activation Stack (Run 3) (1 Activation Train)	Total Facility (2 Activation Trains)	Catalyst Paper Corporation – Port Alberni	Western Forest Products – Alberni Pacific Sawmill
Total Particulate	Tonnes/year	0.22	0.01	0.25	5	108
PM ₁₀	Tonnes/year	0.12	0.01	0.15	4.1	4.8
PM _{2.5}	Tonnes/year	0.04	0.01	0.06	2.8	1.3
NO ₂	Tonnes/year	0.88	0.73	2.34	359	-
CO	Tonnes/year	1.39	166.90	335.18	626	-
VOC	Tonnes/year	0.29	0.95	2.20	121	18
SO ₂	Tonnes/year	0.04	0.01	0.05	179	-
Phenol	Tonnes/year	0.00	0.00	0.01	-	-
Formaldehyde	Tonnes/year	0.18	0.01	0.19	-	-
Methanol	Tonnes/year	0.03	0.03	0.09	18	-

- = Indicates no emissions reported to NPRI in 2015. This could mean either no emissions of this substance, or the NPRI emission reporting level for this substance was not met by the facility.

The stack test data, and comparison against license emission level, shows that:

- The mass emission rates of PM_{2.5} from both stacks were low, and were below the license emission levels.
- Emissions of NO₂ from the carbonization stack were low, and were approximately 70% of the license emission levels. Emissions of NO₂ from the activation stack were approximately double the license emission levels at 4.8 Kg/day compared to the license emission level of 2.77 Kg/day.
- The measured emission rates of SO₂ from both stacks were low.
- Emissions of CO from the carbonization stack were approximately double the license emission levels. Emissions of CO from the activation stack were high, and were approximately 250 times higher than the license emission levels.



- Annual emissions of CO based on measured values are 335 tonnes/year (t/yr). This annual emission rate is approximately half of the annual CO emissions from the Catalyst Port Alberni facility of 626 t/yr.
- Total VOC emissions from both stacks were low. On an annual basis VOC emissions are 0.3 and 1.9 tonnes from the carbonization and activation trains respectively, which are significantly below the annual total VOC emissions of 121 and 18 tonnes reported by the other large facilities within Port Alberni.
- The concentrations of individual VOC species within both stacks are provided in Appendix A. The majority of VOC emissions were found to be below laboratory detection limits. Individual compounds that were present above laboratory detection limits were screened against the ambient air quality standards from Alberta and Ontario (in the absence of BC standards), where they existed. Comparing in-stack concentrations to ambient standards is generally not a direct comparison because in-stack concentrations are much higher than ambient concentrations, since, upon exiting the stack, emissions are dispersed. This approach was used to identify individual VOC emissions that require further assessment. This screening identified that Acrolein, Acrylonitrile, Benzene and Naphthalene should be further assessed using modelling to confirm acceptable off site impacts.
- Naphthalene, a polyaromatic hydrocarbon (PAH) was detected within both the carbonization and activation stacks. This was the only PAH compound currently included in the stack test. Based on the presence of naphthalene, stack testing of speciated PAH's is recommended in the future.
- Measured stack temperatures are significantly lower than those used as the basis of the dispersion modelling (Levelton 2015). The lower temperatures will result in less thermal buoyancy, and therefore poorer dispersion of stack emissions.
- Measured volumetric flow rates, and consequently stack gas velocities are lower than those used as the basis for the dispersion modelling (Levelton 2015).

2.2.3 Stack Test Recommendations

The following recommendations are provided on the process operations:

- Given the significant differences between measured stack emissions, temperature and flow rates, the results and conclusions of the dispersion modelling assessment (Levelton 2015) are not considered to be representative of the facility. It is recommended that the modelling assessment is updated for PM_{2.5}, NO₂, and CO, and additionally the modelling is used to assess the off-site concentrations of individual VOCs detected, including Acrolein, Acrylonitrile, Benzene and Naphthalene. Future modelling should use measured data from activation run 3, since this represents emissions from the highest process feed rate. Given the magnitude of the CO emissions, the modelling assessment should be undertaken to confirm that the level of emissions result in acceptable ambient concentrations of CO prior to the facility re-commencing operations.
- Given the presence of naphthalene, it is recommended that speciated stack testing for PAH compounds is undertaken in future to characterize the type and quantity of any other PAH's present in both stacks.



- Given the high concentrations of CO measured within the stack, monitoring for CO at the facility and associated procedures should be developed to reduce the risk of worker exposure to CO. This may include both worker related monitoring and monitoring of ambient gas levels with audible alarms at the facility. This monitoring and procedures should conform to WorkSafe BC requirements.
- Future stack sampling should consider the measured levels from this sampling effort, particularly the CO concentrations which were high, and plan appropriate health and safety procedures and controls.

2.3 Ambient Monitoring

Ambient monitoring was undertaken during the stack test as follows:

- wind monitoring in the vicinity of the Cantimber facility
- ambient continuous particulate monitoring at two locations within the adjacent residential area
- ambient daily Partisol particulate monitoring within the community on 2nd Avenue
- periodic observations within the neighbourhood during the stack testing to assess conditions and possible odours

Available data from the air quality and meteorological station located at Port Alberni elementary school was also considered in the interpretation of ambient monitoring data.

2.3.1 Wind monitoring

A meteorological station (Novalynx 110-WS-16) was located in the vicinity of the Cantimber facility, approximately 70 m NNE at UTM Easting 368,046 m, Northing 5,454,316 m. Wind speed and wind direction were recorded at a height of 2.4 m between 31 October and 15 November 2016.

Figure 2 shows a comparison of the wind rose at the Cantimber station compared to available data reported by the BC Ministry of Environment from the meteorological station located at Port Alberni elementary school. The wind rose depicts the relative frequency of wind direction on a 16-point compass, with north, east, south, and west directions going clockwise, whose value is listed adjacent to each of the compass points. Each ring on the wind rose represents a frequency of 2% of the total. The length of the shaded bars on each wind rose petal represents the frequency of wind recorded from a given direction within a certain speed range.

The comparison figure shows that the wind pattern is significantly different at the Cantimber facility located that at the elementary school, this is expected given the different locations and surrounding topographic features of each station. For the Cantimber station the dominant wind direction was from the southerly directions, with the highest wind speeds also recorded from these southerly directions. Data from the elementary school shows the dominant wind direction was from the east-northeast, with much lower wind speeds recorded than at the Cantimber station.




Figure 2: Cantimber and Port Alberni Elementary School Wind Rose Comparison 11:00, 1 November to 11:00, 15 November

Figure 3 shows the wind rose plot for the stack test period. During this period, the vast majority of the time the wind was from the south, or the south-south east, therefore the nearby community was not located downwind of the Cantimber facility during the stack test period.




Figure 3: Cantimber Wind Rose Plot during Operation for Stack Test (17:00 November 7th to 17:00 November 9th)



2.3.2 Continuous Particulate Monitoring

Continuous particulate monitors were set up in the nearby residential area between 2 November, 17:00 and 14 November, midnight. Prior to this, both monitors were co-located with the continuous air quality monitor at Port Alberni elementary school for a day (1 November, midday – 2 November, 13:00). Monitoring was undertaken using DustTrak DRX monitors with the auto zero module activated every 12 hours. Data was recorded every 5 minutes.

When the DustTrak monitors were located at the elementary school, data were directly compared to the PM_{2.5} data from the continuous monitor. The DustTrak monitors generally recorded higher hourly concentrations, ranging from -3 to 20 µg/m³ difference over the 25 hour measurement period, with an average difference of 6.5 µg/m³ for the DustTrak that was subsequently located at South Street/1 Avenue (DustTrak 1) and average difference of 6.3 µg/m³ for the DustTrak that was subsequently located at Stirling Street/1 Avenue (DustTrak 2). The two different monitors are not expected to correlate exactly, in addition the monitor located at the elementary school is considered to be permanent ‘reference’ monitoring method, and therefore more accurate data that is generally acceptable in a regulatory context.

Data completeness for the DustTrak Monitors is summarized in Table 3. Data completeness during the stack test period (7 November through 9 November) was greater than 98% for both monitors.

Table 3: DustTrak Monitor Data Completeness

Date (November, 2016)	Overview of Cantimber Process Operations	Data Completeness (%)	
		DustTrak - South Street/1 Avenue	DustTrak - Stirling Street/1 Avenue
2 (17:00 – 24:00)	No operations	100	100
3	Start warm up of combustion chamber (8pm), charcoal and propane fuel sources	61	99
4	Combustion chamber warm up on charcoal and propane fuel sources	7	99
5		37	99
6		99	99
7	Start carbonization process for stack test (5pm)	98	99
8	Carbonization process operating – stack test	99	99
9	Activation process operating – stack test. Initiated shut down in the evening.	98	99
10	No operations	99	99
11		98	99
12		44	99
13		58	99
14		42	99



Figures 4 and 5 show the trends of the daily concentrations over the 2 to 15 November period from the DustTraks and the Port Alberni Elementary School monitor. All available data collected during the monitoring period is included in the figures, even though data completeness was not close to 100% for the daily period. Summary monitoring data is presented in a series of box-and-whisker plots. A simplified box-and-whisker plots are a type of bar chart that displays a variety of statistical data which allows for trend identification. The box on the figures represents the bounds of the middle (50th percentile) of the data points, with the top of the box representing the 75th percentile concentration and the bottom of the box representing the 25th percentile concentration. The blue diamond represents the average concentration. On the figures, the 'whiskers' extend up to the maximum, and down to the minimum daily concentration.

The DustTrak monitors generally recorded higher concentrations than the monitor at Port Alberni Elementary School, however on a daily basis they appear to track the same trends, with the exception of November 4th at the South Street/1 Avenue location. Data completeness for this monitor on 4 November was poor, with only around an hour of monitoring data, which means this data is not a reliable indication of the daily average on this day.




Figure 4: Daily Ambient Monitoring Data – DustTrak Located at South Street/1 Avenue




Figure 5: Ambient Monitoring Data - DustTrak Located at Stirling Street/1 Avenue

The hourly distribution of all the data from both monitors is shown in Figures 6 and 7. The figures show the PM_{2.5} concentrations are greatest between 6pm and midnight, which is expected to correlate to the time of greatest use of wood stoves in the residential area. The hours of 21:00-23:00 at the South Street/1 Avenue monitor is the only period when ambient concentrations exceeded the BC 24-hour ambient air quality objective.




Figure 6: Hourly Concentration Distribution – DustTrak Located at South Street and 1 Avenue




Figure 7: Hourly Concentration Distribution – DustTrak Located at Stirling Street and 1 Avenue

2.3.3 Partisol Monitoring by Cantimber

Daily particulate monitoring was undertaken throughout the stack test period by Cantimber using a Partisol sampler, and subsequent laboratory analysis. Based on the limited dataset, the daily data from the Partisol monitor correlated closely to the daily averages from the continuous monitor at the elementary school. Figure 8 provides a comparison of the daily averages between the Partisol, elementary school monitor and all available DustTrak data.



Figure 8: Daily Particulate Concentrations 2 to 12 November



Figure 8 shows that during the stack test period on 7, 8, and 9 November ambient concentrations of PM_{2.5} were below BC ambient air quality objectives. With the exception of 4 November (which has been discussed in the previous section), the available daily data from the DustTrak monitors followed the same general daily trend as the Partisol and elementary school monitors. The DustTrak monitors consistently recorded higher concentrations than the Partisol and elementary school monitors.

2.3.4 Ambient Monitoring Recommendations

Recommendations relating to ambient monitoring are as follows:

- Given the significant difference in wind pattern between the Cantimber and elementary school station locations, the meteorological data from the elementary school location is not considered to be representative of the wind pattern at the Cantimber facility. Therefore it is recommended that a meteorological station is installed in the vicinity of the facility. This will provide information to use in the investigation of complaints and interpretation of ambient monitoring data. The specification and location of the meteorological station should be approved by a suitably qualified person.
- The current license conditions relating to continuous ambient monitoring should be updated based on the results of the recommended updated dispersion model assessment. Pending the results of the modeling, this would potentially include consideration of monitoring of other compounds in addition to PM_{2.5}.

2.4 Other Regulatory Considerations

Current regulatory conditions relating to air quality, including air emission levels and monitoring requirements relating to the facility, are outlined in the license between PAPA and Cantimber Biotech Inc. dated 1 May 2015. In summary, current air quality conditions include the following:

- Quarterly stack testing for PM_{2.5} is required during the first year of operation on both stacks
- Stack sampling for NO_x and CO is not required
- Continuous ambient PM_{2.5} monitoring is required in the nearby adjacent residential area
- Process operations must cease between 10 November and 10 January

2.4.1 Regulatory Consideration Recommendations

Based on the findings of this study, the following additional recommendations are provided on regulatory considerations:

- The license is modified to incorporate the main aspects of a typical air emissions permit. This would generally include facility specific information on the processes undertaken at a facility, associated air pollution control systems, air emission limits, testing, monitoring, recordkeeping and reporting requirements, and complaint investigation requirements. This document would provide a clear basis for regulating air emissions from the facility.



OPERATIONS AND EMISSIONS EVALUATION

- As well as requirements to collect and report data within a permit, conditions could be included in the permit that state the data/reports be interpreted by a suitably qualified person.
- The permit should include restrictions around the source of wood chips to ensure they are not in contact with saltwater, as this could potentially result in air emissions of dioxins and furans.
- The use of the current complaint log system, which the public can use to lodge complaints with the regulator (PAPA) is continued. Data captured in the complaint log would assist in the investigation and verification of any future complaints. This should be retained and available for inspection.
- The system of investigation and response to complaints by Cantimber should be continued, and this process should be formalized in the air emissions permit.
- Regular audits and inspections of the facility by a suitably qualified person should be undertaken, to verify compliance with 'permit' conditions and requirements. The inspection frequency may initially be high, but could be reduced in the future based on inspection results.
- The current license requirements for quarterly stack sampling should be updated based on the results of the recommended updated dispersion model assessment. Based on current data, quarterly stack testing for PM_{2.5}, NO₂ and CO is recommend during the first year of operation.



3.0 SUMMARY OF RECOMMENDATIONS

Table 4 provides a summary of recommendations. The recommendations shaded in grey should be completed prior to the facilities resumed operation.

Table 4: Summary of Recommendations

Tracking #	Recommendation
Process Operations	
1	The fuel source for the combustion chambers is changed to natural gas, and is automated.
2	A low temperature audible alarm is installed on both combustion chambers.
3	A datalogger is installed to record temperatures within both high temperature combustion chambers.
4	Regular fugitive emission surveys are undertaken on the carbonization process with an analyzer. Any leaks identified should be addressed immediately.
5	An industrial hygiene assessment of worker exposure should be undertaken to ensure workers exposures are below exposure limits. This assessment should conform to WorkSafe BC requirements.
6	The scrubber water disposal system should be upgraded to a contained system prior to the facilities resumed operation.
7	There should be a mechanism/procedure in place to replace the scrubber water as required to maintain efficiency of the particulate removal from exhaust gases.
8	Cooling water should be adequately cooled prior to discharge to surface drains.
Ambient Monitoring	
9	A meteorological station with a datalogger and web portal access to the data is installed in the proximity of the facility. The specification and location of the meteorological station should be approved by a suitably qualified person.
10	The current license requirements for continuous ambient monitoring should be updated based on the results of the recommended updated dispersion model assessment (recommendation #11). This would potentially include consideration of monitoring of additional compounds in addition to PM _{2.5} .
Stack Emissions	
11	The dispersion modelling is updated using the measured stack emissions, temperature and flow rates. The updated modelling should consider emissions of PM _{2.5} , NO ₂ , CO and individual VOCs including Acrolein, Acrylonitrile, Benzene and Naphthalene. Given the magnitude of the CO emissions, the modelling assessment should be undertaken to confirm that the level of emissions result in acceptable ambient concentrations of CO prior to the facility re-commencing operations.
12	Speciated PAH testing is undertaken on both stacks in the near future.
13	Monitoring for CO at the facility and associated procedures should be developed to reduce the risk of worker exposure to CO. This may include both worker related monitoring and monitoring of ambient gas levels with audible alarms at the facility. This monitoring and procedures should conform to WorkSafe BC requirements.
14	Future stack sampling should consider the measured levels from this sampling effort, particularly the CO concentrations which were high, and plan appropriate health and safety procedures and controls.



OPERATIONS AND EMISSIONS EVALUATION

Regulatory Considerations

15	The license of operation is modified to incorporate the main aspects of a typical air emissions permit. This would generally include facility specific information on the processes undertaken, air pollution control systems conditions, air emission limits, monitoring and reporting requirements, complaint investigation requirements.
16	Data collected and reported under the permit should be interpreted by a suitable qualified person.
17	Use of the complaint log system is continued so that the public has a mechanism to file air quality complaints to the regulatory body (PAPA).
18	The system of investigation and follow up process to complaints received by Cantimber is continued, and this requirement is included in the air emissions permit.
19	Regular audits and inspection of the facility by a suitably qualified person, to verify compliance with 'permit' conditions and requirements. The inspection frequency may initially be high, but could be reduced in future based on compliance results.
20	Inclusion of a condition in the permit to avoid saltwater contact with the wood chip feedstock.
21	The current license requirements for quarterly stack sampling should be updated based on the results of the recommended updated dispersion model assessment. As a minimum, quarterly stack testing for PM _{2.5} , NO ₂ and CO is recommend during the first year of operation.



4.0 LIMITATIONS

Golder Associates Ltd. (Golder) has prepared this document in a manner consistent with that level of care and skill ordinarily exercised by members of the engineering and science professions currently practising under similar conditions in the jurisdiction in which the services are provided, subject to the time limits and physical constraints applicable to this document. No warranty, express or implied, is made.

This document, including all text, data, tables, plans, figures, drawings and other documents contained herein, has been prepared by Golder for the sole benefit of Port Alberni Port Authority. It represents Golder's professional judgement based on the knowledge and information available at the time of completion. Golder is not responsible for any unauthorized use or modification of this document. All third parties relying on this document do so at their own risk.

The factual data, interpretations, suggestions, recommendations and opinions expressed in this document pertain to the specific project, site conditions, design objective, development and purpose described to Golder by Port Alberni Port Authority, and are not applicable to any other project or site location. In order to properly understand the factual data, interpretations, suggestions, recommendations and opinions expressed in this document, reference must be made to the entire document.



This document, including all text, data, tables, plans, figures, drawings and other documents contained herein, as well as all electronic media prepared by Golder are considered its professional work product and shall remain the copyright property of Golder. Port Alberni Port Authority may make copies of the document in such quantities as are reasonably necessary for those parties conducting business specifically related to the subject of this document or in support of or in response to regulatory inquiries and proceedings. Electronic media is susceptible to unauthorized modification, deterioration and incompatibility and therefore no party can rely solely on the electronic media versions of this document.



5.0 CLOSURE

We trust that this provides sufficient information at this time, should you have any questions, please contact the undersigned.

GOLDER ASSOCIATES LTD.

  *Dec 12, 2016*

Rachel Wyles, MEng, PEng
Associate, Air Quality Engineer



Sean Capstick, PEng
Principal

RW/SC/it/rs

Golder, Golder Associates and the GA globe design are trademarks of Golder Associates Corporation.

o:\final\2016\3 proj\1661112 port authority_review_port albernai\1661112-004-r-rev0-1\1661112-004-r-rev0-1-operations and emissions evaluation 12dec_16.docx



REFERENCE

Levelton. 2015. Air Quality Assessment for the Cantimber Charcoal Manufacturing Facility. 21 January 2015.



APPENDIX A

Stack Test Report

EMISSIONS MONITORING SURVEY

**Cantimber Biotech Inc.
Pt. Alberni, B.C.**

**Carbonization and Activation Stacks
November 2016 Survey**

Prepared for:

Golder Associates Ltd.

Prepared by:

A. LANFRANCO & ASSOCIATES INC.

Surrey, B.C.

December 2016

CERTIFICATION

The field monitoring conducted for this survey was conducted by certified stack test technicians as required by the B.C. MOE stack testing code. The field crew consisted of:

Mr. C. Lanfranco (certified), Mr. D. Sampson (certified), and Mr. J. Burch (certified).


The report was prepared by Mr. M. Lanfranco and Mr. L. Agassiz using reporting principles and guidelines generally acceptable to B.C. MOE.

The field crew and A. Lanfranco and Associates Inc. certify that the test methods used were MOE/MV approved reference methods for the parameters investigated.



L. Agassiz, Certified Stack Test Technician

Report reviewed by:



M. Lanfranco
Managing Director

TABLE OF CONTENTS

SUMMARY	1
1.0 INTRODUCTION	2
2.0 PROCESS DESCRIPTIONS	2
3.0 METHODOLOGY	3
3.1 Sampling Techniques	3
3.2 Analytical Techniques	9
3.3 Quality Assurance and Control	10
4.0 RESULTS	10
5.0 DISCUSSION OF RESULTS	16

APPENDICES

**Appendix 1 - Computer Outputs of Measured
and Calculated Data**

Appendix 2 - Analytical Data

Appendix 3 - Field Data Sheets

Appendix 4 - Calibration Data and Process Data

SUMMARY

The following tables present the average emission results for the listed parameters from Cantimber Biotech Inc.'s Carbonization Stack and Activation Stack from November 8-9, 2016. The individual test results can be seen in Tables 1 to 5 and in the appendix.

Parameter	Carbonization Stack (East)	Activation Stack (West)
Total Particulate (mg/Sm ³)	16.2	1.8
Total Particulate (mg/Sm ³ @ 8% O ₂)	23.3	3.0
Particulate Emissions Rate (kg/hr)	0.03	0.003
Condensable Organics (mg/Sm ³)	0.6	0.0
PM ₁₀ (mass % of partic. <10 micron)	53.1%	100%
PM _{2.5} (mass % of partic. <2.5 micron)	17.2%	62.7%
Phenol (mg/Sm ³)	0.2	0.1
Formaldehyde (mg/Sm ³)	13.5	0.8
Methanol (mg/Sm ³)	2.5	2.1
THC (mg/Sm ³)	20.5	51.5
NO _x (mg/Sm ³)	63.0	58.8
SO _x (mg/Sm ³)	2.6	0.4
CO (mg/Sm ³)	103	> 3180
CO (mg/Sm ³) from canisters	N/A	10200
THC (mg/Sm ³ @ 8% O ₂)	29.5	84.7
NO _x (mg/Sm ³ @ 8% O ₂)	90.5	96.5
SO _x (mg/Sm ³ @ 8% O ₂)	3.8	0.65
CO (mg/Sm ³ @ 8% O ₂)	149	> 5230
CO (mg/Sm ³ @ 8% O ₂) from canisters	N/A	16800
Flowrate (Sm ³ /min)	30.6	27.5

standard conditions of 20 deg C and 101.3 kPa

Note: Results for individual Volatile Organic Compounds can be found in Appendix 2 in the analytical report from ALS Environmental

1.0 INTRODUCTION

In November 2016, Golder Associates Ltd retained A. Lanfranco and Associates Inc. of Surrey, B.C. to conduct an emission survey at the Cantimber Biotech Inc facility located in Port Alberni, B.C. The purpose of the emission survey was to measure and report emission parameters and pollutants from the Carbonization and Activation Stacks. The parameters measured for both stacks include particulate matter with condensable particulate, PM 2.5, PM 10, Phenol, Formaldehyde, Methanol, Total Hydrocarbons (Organic Carbon), Nitrogen Oxides, Sulphur Oxides, Carbon Monoxide, Oxygen, Carbon Dioxide, flowrate, and moisture.

Normal operating parameters were maintained on the test days. Process information has been retained by Cantimber and Golder Associates.

This report documents the methods used and the results determined for the tests completed from November 8 to 9, 2016.

2.0 PROCESS DESCRIPTIONS

Cantimber Biotech Inc. project utilizes the abundant logging residue in the province of British Columbia as raw material. The main tree species are Douglas-fir, hemlock, red cedar and others. The project utilizes retort pyrolysis technology to produce clean and high quality charcoal. The project uses a fluidized based steam activation chamber to produce granular and powder pure physical method wood activated carbon, that can be further refined into pharmaceutical grade, food plant grade and chemical engineering grade raw material.

3.0 METHODOLOGY

All sampling and analytical methods used throughout this survey comply with procedures published in the B.C. "Field Sampling Manual, Source Testing Section" 2003 Edition, and the B.C. Air Analytical Manual, or with government approved sampling and analytical methods.

3.1 Sampling Techniques

The table below outlines the methods followed for the sampling regime at Cantimber Biotech Inc.

<u>Parameter</u>	<u>Reference Method</u>
Sample and velocity traverse points	EPA Method 1
Velocity and flowrate	EPA Method 2
Gas molecular weight (O ₂ /CO ₂)	EPA Method 3 & 3a
Fluegas Moisture	EPA Method 4
Particulate Matter	EPA Method 5
Condensable Particulate Matter	EPA Method 202
Nitrogen Oxides (NO _x)	EPA Method 7e
Sulphur Oxides (SO _x)	EPA Method 6c
Carbon Monoxide (CO)	EPA Method 10
Total Organic Carbon as CH ₄	EPA Method 25a
Volatile Organic Compounds (VOC)	EPA TO-15
Formaldehyde	NCASI 98.01
Methanol	NCASI 98.01
Phenol	NCASI 98.01
Particle Sizing	*CCSEM

*Computer controlled scanning electron microscopy for PM 10 and 2.5

Sampling for particulate and condensable particulate (EPA Method 202) from both stacks was conducted using Apex/CAE sampling trains equipped with heated filter assemblies and a heated four-foot probe (Fig. 1). The impinger sections of the sampling trains were charged with D.I. water for moisture and condensable particulate collection. The EPA 202 optional back filter was not used for this test program.




Figure 1: Method 202 Particulate Sampling Train (w/ 3 100 ml H₂O)

Cyclones were not used as part of the sampling apparatus.

Velocity measurements were made with S-type pitot tubes and oil manometers or Magnehelic gauges. Stack temperatures were monitored at each point by K-type thermocouples attached to the sampling probes. Oxygen and carbon dioxide measurements were made with Fyrite analysers (wet and electrochemical) and a sophisticated CEM system.

Orifice pressures recorded on the data sheets represent the orifice pressure for the beginning and end of each sample point.

Stack gas moisture content was determined by using the impinger condensed water vapour technique.

The sampling port location for both stacks did not meet ideal duct diameter criteria, thus the maximum 24-point (Fig. 2, 3/3a) sampling regime was used for these sources.

The sample ports were approximately 2.3 diameters downstream of the fans or nearest disturbance and more than two diameters upstream of the stack exits.

Samples for particulate/condensable organics were collected for 60 minute durations resulting in sample volumes of about 1.5 cubic meters (as sampled).

Isokinetic sampling rates were determined with programmable calculators using the Ko orifice constant procedure. The stacks were checked for cyclonic flow using methods outlined in the source test code. No cyclonic flow condition existed.

Phenol/Formaldehyde/Methanol

Phenol and formaldehyde were sampled using NCASI CI/WP 98.01 test methodology, using a independent small impinger train charged with distilled water. Samples were collected for 60 minutes at a sample rate of about 0.4-0.5 lpm. Sampling was conducted in triplicate.


Figure 2: Location of Traverse Points in Circular Stacks

(inches from inside wall to traverse point)

Client Stack I.D.: Cantimber Carbonization Stack

Diameter (inches)	72	
Total Points	24	Diameters Upstream: > 0.5
# of Ports Used	2	
Points / Traverse	12	Diameters Downstream: > 2

Point	Distance from Wall
1	1.5
2	4.8
3	8.5
4	12.7
5	18.0
6	25.6
7	46.4
8	54.0
9	59.3
10	63.5
11	67.2
12	70.5



* distance A : duct diameters upstream from flow disturbance
 * distance B : duct diameters downstream from flow disturbance
 < < < : flow direction


Figure 3: Location of Traverse Points in Circular Stacks

(inches from inside wall to traverse point)

Client Stack I.D.: Cantimber Activation Stack

Diameter (inches)	15	
Total Points	24	Diameters Upstream: > 0.5
# of Ports Used	2	
Points / Traverse	12	Diameters Downstream: > 2

Point	Distance from Wall
1	0.3
2	1.0
3	1.8
4	2.7
5	3.8
6	5.3
7	9.7
8	11.3
9	12.3
10	13.2
11	14.0
12	14.7



* distance A : duct diameters upstream from flow disturbance
 * distance B : duct diameters downstream from flow disturbance
 < < < : flow direction

Figure 3a: Location of Traverse Points in Circular Stacks

(percent of diameter from inside wall to traverse point)

Traverse Point Number on a Diameter	<u>Number of Traverse Points on a Diameter</u>					
	2	4	6	8	10	12
1	14.6%	6.7%	4.4%	3.2%	2.6%	2.1%
2	85.4%	25.0%	14.6%	10.5%	8.2%	6.7%
3		75.0%	29.6%	19.4%	14.6%	11.8%
4		93.3%	70.4%	32.3%	22.6%	17.7%
5			85.4%	67.7%	34.2%	25.0%
6			95.6%	80.6%	65.8%	35.6%
7				89.5%	77.4%	64.4%
8				96.8%	85.4%	75.0%
9					91.8%	82.3%
10					97.4%	88.2%
11						93.3%
12						97.9%

CEM System for THC, NO_x, SO_x, CO, CO₂ and O₂

Continuous emission monitoring (CEM) was conducted for NO_x, SO₂, CO, THC, O₂ and CO₂ using A. Lanfranco and Associates Inc. CEM monitoring mobile laboratory. The analyzers were calibrated with EPA Protocol gas standards.

NO _x	API Chemiluminescence Monitor, Model 252 for NO/NO ₂ /NO _x with ranges from 0 to 2000 ppm. Range 0 to 100 ppm was used for all tests.
CO/CO ₂ /O ₂	California Analytical Model 300 Infrared Analyzer with ranges 0 to 2000 ppm CO, and 0 to 40% CO ₂ , and 0 to 25% O ₂
THC	JUM Model, Hot FID Analyzer with ranges 0 to 100000 ppm
SO ₂	Ametek Model 721-M Photometric Analyzer with ranges 0-2000 ppm

A diagram of the sampling, conditioning and analyzer system is provided in Figure 4. With this system, the stack gas sample is withdrawn from the source through a coarse filter and stainless steel probe. For all CEM analysis except THC, the stack sample is transported in a heated Teflon sample line to a gas conditioner (KWW Mak II) where condensed water is removed. The dried stack gas is

delivered to a stainless-steel manifold, which distributes (by external pumps) the dried stack gas to the individual analyzers. THC is measured on a hot /wet basis.

Samples for NO_x, SO_x and THC as well as combustion gases (CO, O₂, CO₂) were collected and analyzed for three, one-hour test periods on each of the stacks.




Figure 4 – CEM Measurement System Schematic

3.2 Analytical Techniques

Glass fibre filters used for this survey were Whatman GF/A 0.3 u glass microfibre filters. The filters were initially conditioned by one hour oven drying and desiccating to constant weight. Following sampling, the filters were removed from their holders (in a clean environment) with stainless steel tweezers, oven dried at 105°C for one hour and desiccated to constant weight. Any filter material adhering to the gasket was scraped with a stainless steel razor blade and deposited on the filter. The particulate collected on the filter was determined by the difference of initial and final weights, adjusted for blank values.

Moisture determinations were made by before and after test impinger weights or saturation values. Impinger contents from each test were saved for condensable (hexane extractable) analysis by Exova Laboratories in Surrey, B.C. The impingers used were rinsed using Hexane and de-ionized water to recover any oily residues from the impinger walls.

Probe washings were evaporated in tared pyrex beakers using oven drying at 105 °C for about eight hours and desiccation to constant weight. Probe and washings particulate was determined by difference of initial and final dish weights, adjusted for blank values.

Methanol, Phenol and formaldehyde were analysed according to the analytical methods stipulated in NCASI 98.01. Phenol was analysed by direct aqueous injection and GC analysis, while formaldehyde was analysed with the acetylacetone colorimetric procedure. Analysis was performed by Exova Laboratories in Surrey, B.C.

CEM results were calculated from the analyzer responses to stack gases, in comparison to the analyzer responses to known certified calibration gases.

3.3 Quality Assurance and Control

QA/QC of this survey was accomplished by the following mechanisms.

1. Pre and post-test leak checks to RM specs
2. Calibration of emission test equipment to RM specs
3. Cyclonic flow checks
4. CEM system zero and calibration drift and Bias determinations
5. Calibration error assessments
6. CEM calibrations using EPA Protocol and 1% calibration gases
7. 3 point initial calibration and calibration error checks
8. Analysis of all blank solutions and materials
9. Sample labelling, record-keeping, and chain-of-custody documentation

Reference materials, blanks were analysed to validate all laboratory analyses.

4.0 RESULTS

Emission results were calculated with a computer program utilizing formulae approved by BC MOE. The computer outputs were checked by hand calculation. Tables 1 through 5 present the individual and average test data for triplicate particulate/condensables tests from the two stacks.

In the following tables, particulate and flowrate are shown in actual, standard or corrected standard terms. The "std" particulate results are mg/m^3 at standard conditions of 20 °C and 101.3 KPa (dry).

The "actual" flowrate results are volumetric flowrate at stack conditions while the standard flowrates are flowrates corrected to 20 °C and 101.3 KPa (dry).

Point by point isokinetic rates are presented in Appendix 1.

CEM and manual gas sampling results for three, one hour periods are presented in the tables. Minutely averages and trend graphs for THC, CO₂, O₂, SO_x, NO_x, and CO are presented in Appendix 1.

Table 1: Cantimber Carbonization Stack

Parameter		Test 1	Test 2	Test 3	Average
Test Date		Nov.8, 2016	Nov.8, 2016	Nov.8, 2016	
Test Time		11:50-12:58	13:20-14:26	14:40-15:42	
Duration	(minutes)	60	60	60	60
Particulate including					
Condensable Organics	(mg/Sm ³)	18.9	11.6	18.2	16.2
Particulate including					
Condensable Organics	(mg/Sm ³ @ 8% O ₂)	27.8	16.7	25.5	23.3
Particulate Front Half	(mg/Sm ³)	18.1	11.6	17.3	15.6
Particulate Back Half	(mg/Sm ³)	0.87	0.00	0.93	0.60
Particulate	(Kg/hr)	0.04	0.02	0.03	0.03
PM ₁₀	(mass % of partic. <10 micron)				53.1%
PM _{2.5}	(mass % of partic. <2.5 micron)				17.2%
Phenol	(mg/Sm ³)	0.2	0.1	0.2	0.2
Formaldehyde	(mg/Sm ³)	13.4	13.5	13.6	13.5
Methanol	(mg/Sm ³)	1.4	2.4	3.7	2.5
Flowrate	(Sm ³ /min)	31.1	30.3	30.4	30.6
Flowrate	(Am ³ /min)	42.1	42.1	41.7	42.0
Temperature	(°C)	58.4	60.4	59.3	59.4
O ₂	(vol % dry)	12.1	11.9	11.7	11.9
CO ₂	(vol % dry)	8.81	8.96	9.07	8.94
H ₂ O	(vol %)	16.4	18.3	17.4	17.4
Isokinetic Variation	(%)	99.9	100	96.0	98.7

standard conditions of 20 deg C and 101.3kPa

Table 2: Carbonization Stack Gaseous Emissions

Parameter		Test 1	Test 2	Test 3	Average
Test Date		8-Nov-16	8-Nov-16	8-Nov-16	
Test Time		12:15 - 13:15	13:40 - 14:40	15:00 - 16:00	
Test Duration	(min)	60	60	60	60
Nitrogen Oxides as NO ₂	(mg/Sm ³)	61.4	62.6	65.0	63.0
Nitrogen Oxides as NO ₂	(mg/Sm ³ @ 8% O ₂)	90.1	90.2	91.2	90.5
Nitrogen Oxides as NO ₂	(kg/hr)	0.11	0.11	0.12	0.12
Total HC as CH ₄	(mg/Sm ³)	22.5	21.5	17.5	20.5
Total HC as CH ₄	(mg/Sm ³ @ 8% O ₂)	33.0	30.9	24.6	29.5
Total HC as CH ₄	(kg/hr)	0.04	0.04	0.03	0.04
Sulphur Dioxide	(mg/Sm ³)	2.7	4.0	1.2	2.6
Sulphur Dioxide	(mg/Sm ³ @ 8% O ₂)	4.0	5.7	1.7	3.8
Sulphur Dioxide	(kg/hr)	0.005	0.007	0.002	0.005
Carbon Monoxide	(mg/Sm ³)	172	90.4	44.8	103
Carbon Monoxide	(mg/Sm ³ @ 8% O ₂)	253	130	63.0	149
Carbon Monoxide	(kg/hr)	0.32	0.16	0.08	0.19

standard conditions of 20 deg C and 101.3kPa

Table 3: Cantimber Activation Stack

Parameter		Test 1	Test 2	Test 3	Average
Test Date		Nov.9, 2016	Nov.9, 2016	Nov.9, 2016	
Test Time		09:50-10:51	11:25-12:28	13:10-14:16	
Duration	(minutes)	60	60	60	60
Particulate including					
Condensable Organics	(mg/Sm ³)	1.09	2.95	1.36	1.80
Particulate including					
Condensable Organics	(mg/Sm ³ @ 8% O ₂)	1.79	4.83	2.24	2.95
Particulate Front Half	(mg/Sm ³)	1.09	2.95	1.36	1.80
Particulate Back Half	(mg/Sm ³)	0.0	0.0	0.0	0.0
Particulate	(Kg/hr)	0.002	0.005	0.002	0.003
PM ₁₀	(mass % of partic. <10 micron)				100%
PM _{2.5}	(mass % of partic. <2.5 micron)				62.7%
Phenol	(mg/Sm ³)	0.1	0.1	0.1	0.1
Formaldehyde	(mg/Sm ³)	1.0	0.8	0.5	0.8
Methanol	(mg/Sm ³)	1.7	2.1	2.3	2.1
Flowrate	(Sm ³ /min)	28.2	27.0	27.4	27.5
Flowrate	(Am ³ /min)	37.7	36.0	36.5	36.7
Temperature	(°C)	59.0	58.3	57.7	58.3
O ₂	(vol % dry)	13.0	13.0	13.1	13.0
CO ₂	(vol % dry)	7.37	7.30	7.09	7.25
H ₂ O	(vol %)	15.9	15.9	15.8	15.9
Isokinetic Variation	(%)	97.7	99.3	100	99.0

standard conditions of 20 deg C and 101.3kPa

Table 4: Activation Stack Gaseous Emissions

Parameter		Test 1	Test 2	Test 3	Average
Test Date		9-Nov-16	9-Nov-16	9-Nov-16	
Test Time		10:15 - 11:15	11:35 - 12:35	13:10 - 14:10	
Test Duration	(min)	60	60	60	60
Nitrogen Oxides as NO ₂	(mg/Sm ³)	54.7	59.4	62.2	58.8
Nitrogen Oxides as NO ₂	(mg/Sm ³ @ 8% O ₂)	89.3	97.3	103	96.5
Nitrogen Oxides as NO ₂	(kg/hr)	0.09	0.10	0.10	0.10
Total HC as CH ₄	(mg/Sm ³)	30.1	46.7	77.7	51.5
Total HC as CH ₄	(mg/Sm ³ @ 8% O ₂)	49.1	76.5	128	84.7
Total HC as CH ₄	(kg/hr)	0.05	0.08	0.13	0.08
Sulphur Dioxide	(mg/Sm ³)	0.50	0.38	0.31	0.40
Sulphur Dioxide	(mg/Sm ³ @ 8% O ₂)	0.82	0.63	0.51	0.65
Sulphur Dioxide	(kg/hr)	0.001	0.001	0.001	0.001
Carbon Monoxide	(mg/Sm ³)	> 3170	> 3190	> 3190	> 3180
Carbon Monoxide	(mg/Sm ³ @ 8% O ₂)	> 5180	> 5220	> 5280	> 5230
Carbon Monoxide	(kg/hr)	> 5.37	> 5.16	> 5.24	> 5.26
Carbon Monoxide from canisters	(mg/Sm ³)	6820	9940	13900	10200
Carbon Monoxide from canisters	(mg/Sm ³ @ 8% O ₂)	11100	16300	23000	16800
Carbon Monoxide from canisters	(kg/hr)	11.5	16.1	22.8	16.8

standard conditions of 20 deg C and 101.3kPa

TABLE 5: GRAVIMETRIC RESULTS

	Filter Particulate (mg)	Probe and Washings Particulate (mg)	Condensable Particulate (mg)	Total Particulate (mg)
Carbonization Stack				
Test 1	17.8	2.9	1.0	21.7
Test 2	10.8	2.2	0.0	13.0
Test 3	18.3	0.3	1.0	19.6
Activation Stack				
Test 1	0.3	1.0	0.0	1.3
Test 2	0.4	3.0	0.0	3.4
Test 3	0.5	1.1	0.0	1.6

5.0 DISCUSSION OF RESULTS

Triplicate emission tests from the Carbonization and Activation stacks were conducted with Ministry of Environment or EPA approved techniques for particulate matter including condensable particulate, methane, THC, and volumetric flowrate, as well as phenol and formaldehyde.

During the testing period, Cantimber was operating the processes in a normal manner at normal production rates.

CEM data showed consistent results from both sources, with some variation that can be expected within normal operating conditions. The levels of CO on the Activation stack were higher than the largest scale of the CO analyzer can handle. Thus, the CO results from the canister analysis are taken as the accurate results.

There were no problems with sample collection or analysis and all samples were collected isokinetically (100 +/- 10%), where required. The results are in the anticipated ranges based on process loads and operating conditions and the tests were conducted by certified technicians using calibrated source test equipment. The results, therefore, are presented with confidence and are an accurate representation of emission characteristics for the process conditions maintained on the test dates.

APPENDIX 1

**COMPUTER OUTPUTS OF MEASURED
AND CALCULATED DATA
AND CEM DATA**

Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Carbonization Stack

Date: Nov.8, 2016
Run: 1 Part/Cond
Run Time: 11:50-12:58

Particulate Concentration: **18.9 mg/dscm** 0.0083 gr/dscf
 14.0 mg/Acm 0.0061 gr/Acf
 Front Half: 18.1 mg/dscm
 Back Half: 0.9 mg/dscm
 27.8 mg/dscm (@ 8% O2) 0.0121 gr/dscf (@ 8% O2)

Emission Rate: 0.04 Kg/hr 0.078 lb/hr

Sample Gas Volume: 1.1460 dscm 40.472 dscf
Total Sample Time: 60.0 minutes

Average Isokineticity: 99.9 %

Flue Gas Characteristics

Moisture: 16.43
Temperature 58.4 oC 137.2 oF
Flow 31.1 dscm/min 1098 dscf/min
 0.52 dscm/sec 18.3 dscf/sec
 42.1 Acm/min 1486 Acf/min
Velocity 6.152 m/sec 20.18 f/sec
Gas Analysis 12.10 % O2 8.81 % CO2
 29.893 Mol. Wt (g/gmole) Dry 27.939 Mol. Wt (g/gmole) Wet

* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa
 Imperial: 68 deg F, 29.92 in.Hg

Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Carbonization Stack

Date: Nov.8, 2016
Run: 1 Part/Cond
Run Time: 11:50-12:58

Control Unit (Y) 1.0194
Nozzle Diameter (in.) 0.3720
Pitot Factor 0.8450
Baro. Press. (in. Hg) 29.92
Static Press. (in. H2O) 0.05
Stack Height (ft) 40
Stack Diameter (in.) 15.0
Stack Area (sq.ft.) 1.227
Minutes Per Reading 2.5
Minutes Per Point 2.5
Port Length (inches) 3.0

Gas Analysis (Vol. %):

	CO2	O2
CEM AVG:	8.81	12.10
Average =	8.81	12.10

Condensate Collection:

Impinger 1 (grams)	116.0
Impinger 2 (grams)	40.0
Impinger 3 (grams)	4.0
Impinger 4 (grams)	9.0

Total Gain (grams) 169.0

Collection:

Filter (grams)	0.0178
Washings (grams)	0.0029
Impinger (grams)	0.0010
Total (grams)	0.0217

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
		0.0	438.568							
1	1	2.5	440.230	0.100	1.53	68	68	121	1.0	103.9
	2	5.0	441.900	0.100	1.52	68	68	123	1.0	104.6
	3	7.5	443.500	0.100	1.46	68	68	127	1.8	100.5
	4	10.0	445.090	0.100	1.42	68	68	130	2.6	100.1
	5	12.5	446.680	0.100	1.42	68	68	132	3.7	100.3
	6	15.0	448.270	0.100	1.42	68	68	134	5.3	100.5
	7	17.5	449.860	0.100	1.41	68	68	136	9.7	100.6
	8	20.0	451.440	0.100	1.41	68	68	138	11.2	100.2
	9	22.5	453.030	0.100	1.41	69	69	138	12.3	100.6
	10	25.0	454.620	0.100	1.41	70	70	139	13.2	100.5
	11	27.5	456.210	0.100	1.41	70	70	139	14.0	100.5
	12	30.0	457.790	0.100	1.41	70	70	140	14.0	99.9
		0.0	457.790							
2	1	2.5	459.460	0.110	1.55	71	71	140	1.0	100.6
	2	5.0	461.130	0.110	1.55	71	71	140	1.0	100.6
	3	7.5	462.760	0.110	1.49	71	71	140	1.8	98.1
	4	10.0	464.390	0.110	1.49	71	71	140	2.6	98.1
	5	12.5	466.100	0.120	1.62	72	72	141	3.7	98.5
	6	15.0	467.810	0.120	1.62	73	73	142	5.3	98.4
	7	17.5	469.520	0.120	1.62	74	74	142	9.7	98.2
	8	20.0	471.230	0.120	1.63	74	74	142	11.2	98.2
	9	22.5	473.020	0.130	1.76	74	74	142	12.3	98.8
	10	25.0	474.810	0.130	1.76	75	75	142	13.2	98.6
	11	27.5	476.600	0.130	1.76	75	75	142	14.0	98.6
	12	30.0	478.330	0.120	1.63	75	75	142	14.0	99.2
Average:				0.110	1.530	70.8	70.8	137.2		99.9

Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Carbonization Stack

Date: Nov.8, 2016
Run: 2 - Part/Cond
Run Time: 13:20-14:26

Particulate Concentration: **11.6 mg/dscm** 0.0051 gr/dscf
 8.3 mg/Acm 0.0036 gr/Acf

Front Half: 11.6 mg/dscm
 Back Half: 0.0 mg/dscm

16.7 mg/dscm (@ 8% O2) 0.0073 gr/dscf (@ 8% O2)

Emission Rate: 0.02 Kg/hr 0.046 lb/hr

Sample Gas Volume: 1.1200 dscm 39.553 dscf
Total Sample Time: 60.0 minutes

Average Isokineticity: 100.3 %

Flue Gas Characteristics

Moisture: 18.27

Temperature 60.4 oC 140.7 oF

Flow 30.3 dscm/min 1069 dscf/min
 0.50 dscm/sec 17.8 dscf/sec
 42.1 Acm/min 1488 Acf/min

Velocity 6.159 m/sec 20.21 f/sec

Gas Analysis 11.94 % O2 8.96 % CO2

29.911 Mol. Wt (g/gmole) Dry 27.736 Mol. Wt (g/gmole) Wet

* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa
 Imperial: 68 deg F, 29.92 in.Hg

Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Carbonization Stack

Date: Nov.8, 2016
Run: 2 - Part/Cond
Run Time: 13:20-14:26

Control Unit (Y) 1.0194
Nozzle Diameter (in.) 0.3720
Pitot Factor 0.8450
Baro. Press. (in. Hg) 29.92
Static Press. (in. H2O) 0.05
Stack Height (ft) 40
Stack Diameter (in.) 15.0
Stack Area (sq.ft.) 1.227
Minutes Per Reading 2.5
Minutes Per Point 2.5
Port Length (inches) 3.0

Gas Analysis (Vol. %):

	CO2	O2
CEM AVG:	8.96	11.94
<hr/>		
Average =	8.96	11.94

Condensate Collection:

Impinger 1 (grams)	150.0
Impinger 2 (grams)	26.0
Impinger 3 (grams)	2.0
Impinger 4 (grams)	9.8

Total Gain (grams) 187.8

Collection:

Filter (grams)	0.0108
Washings (grams)	0.0022
Impinger (grams)	0.0000
Total (grams)	<u>0.0130</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
1		0.0	478.606							
	1	2.5	480.180	0.100	1.36	76	76	141	1.0	100.4
	2	5.0	481.750	0.100	1.36	76	76	141	1.0	100.1
	3	7.5	483.320	0.100	1.36	76	76	140	1.8	100.0
	4	10.0	484.890	0.100	1.36	76	76	140	2.6	100.0
	5	12.5	486.460	0.100	1.36	76	76	140	3.7	100.0
	6	15.0	488.040	0.100	1.36	76	76	140	5.3	100.7
	7	17.5	489.620	0.100	1.36	76	76	140	9.7	100.7
	8	20.0	491.190	0.100	1.36	76	76	140	11.2	100.0
	9	22.5	492.760	0.100	1.36	76	76	140	12.3	100.0
	10	25.0	494.330	0.100	1.36	76	76	140	13.2	100.0
	11	27.5	495.900	0.100	1.36	76	76	140	14.0	100.0
12	30.0	497.470	0.100	1.36	76	76	142	14.0	100.2	
2		0.0	497.470							
	1	2.5	499.190	0.120	1.63	77	77	142	1.0	100.1
	2	5.0	500.920	0.120	1.63	78	78	143	1.0	100.6
	3	7.5	502.650	0.120	1.64	78	78	142	1.8	100.5
	4	10.0	504.380	0.120	1.64	78	78	141	2.6	100.4
	5	12.5	506.110	0.120	1.64	78	78	141	3.7	100.4
	6	15.0	507.840	0.120	1.64	78	78	141	5.3	100.4
	7	17.5	509.570	0.120	1.64	78	78	141	9.7	100.4
	8	20.0	511.300	0.120	1.65	79	79	141	11.2	100.2
	9	22.5	512.960	0.110	1.51	80	80	140	12.3	100.1
	10	25.0	514.630	0.110	1.51	81	81	140	13.2	100.6
	11	27.5	516.290	0.110	1.51	80	80	140	14.0	100.1
12	30.0	517.953	0.110	1.51	80	80	140	14.0	100.3	
			Average:	0.108	1.478	77.4	77.4	140.7		100.3

Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Carbonization Stack

Date: Nov.8, 2016
Run: 3 - Part/Cond
Run Time: 14:40-15:42

Particulate Concentration:	18.2 mg/dscm	0.0079 gr/dscf
	13.3 mg/Acm	0.0058 gr/Acf
Front Half:	17.3 mg/dscm	
Back Half:	0.9 mg/dscm	
	25.5 mg/dscm (@ 8% O2)	0.0112 gr/dscf (@ 8% O2)
Emission Rate:	0.03 Kg/hr	0.073 lb/hr
Sample Gas Volume:	1.0778 dscm	38.064 dscf
Total Sample Time:	60.0 minutes	
Average Isokineticity:	96.0 %	
Flue Gas Characteristics		
Moisture:	17.36	
Temperature	59.3 oC	138.8 oF
Flow	30.4 dscm/min	1074 dscf/min
	0.51 dscm/sec	17.9 dscf/sec
	41.7 Acm/min	1474 Acf/min
Velocity	6.102 m/sec	20.02 f/sec
Gas Analysis	11.72 % O2	9.07 % CO2
	29.919 Mol. Wt (g/gmole) Dry	27.850 Mol. Wt (g/gmole) Wet

* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa
 Imperial: 68 deg F, 29.92 in.Hg

Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Carbonization Stack

Date: Nov.8, 2016
Run: 3 - Part/Cond
Run Time: 14:40-15:42

Control Unit (Y) 1.0194
Nozzle Diameter (in.) 0.3720
Pitot Factor 0.8450
Baro. Press. (in. Hg) 29.92
Static Press. (in. H2O) 0.05
Stack Height (ft) 40
Stack Diameter (in.) 15.0
Stack Area (sq.ft.) 1.227
Minutes Per Reading 2.5
Minutes Per Point 2.5
Port Length (inches) 3.0

Gas Analysis (Vol. %):

	CO2	O2
CEM AVG:	9.07	11.72
<hr/>		
Average =	9.07	11.72

Condensate Collection:

Impinger 1 (grams)	146.0
Impinger 2 (grams)	14.0
Impinger 3 (grams)	0.0
Impinger 4 (grams)	9.9

Total Gain (grams) 169.9

Collection:

Filter (grams)	0.0183
Washings (grams)	0.0003
Impinger (grams)	0.0010
Total (grams)	0.0196

Traverse	Point	Time (min)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
		0.0	518.235							
1	1	2.5	519.810	0.100	1.37	78	78	139	1.0	99.0
	2	5.0	521.390	0.100	1.37	78	78	139	1.0	99.3
	3	7.5	522.970	0.100	1.37	78	78	139	1.8	99.3
	4	10.0	524.490	0.100	1.26	78	78	139	2.6	95.5
	5	12.5	526.010	0.100	1.26	78	78	138	3.7	95.4
	6	15.0	527.530	0.100	1.26	78	78	138	5.3	95.4
	7	17.5	529.050	0.100	1.26	77	77	139	9.7	95.7
	8	20.0	530.570	0.100	1.26	77	77	139	11.2	95.7
	9	22.5	532.090	0.100	1.26	78	78	138	12.3	95.4
	10	25.0	533.610	0.100	1.26	78	78	138	13.2	95.4
	11	27.5	535.130	0.100	1.26	77	77	139	14.0	95.7
	12	30.0	536.650	0.100	1.26	77	77	139	14.0	95.7
		0.0	536.650							
2	1	2.5	538.240	0.110	1.39	78	78	139	1.0	95.3
	2	5.0	539.830	0.110	1.39	78	78	139	1.0	95.3
	3	7.5	541.430	0.110	1.39	78	78	139	1.8	95.9
	4	10.0	543.090	0.120	1.52	78	78	139	2.6	95.3
	5	12.5	544.760	0.120	1.52	78	78	138	3.7	95.8
	6	15.0	546.430	0.120	1.52	78	78	139	5.3	95.9
	7	17.5	548.090	0.120	1.52	78	78	139	9.7	95.3
	8	20.0	549.760	0.120	1.52	78	78	139	11.2	95.9
	9	22.5	551.360	0.110	1.39	78	78	139	12.3	95.9
	10	25.0	552.960	0.110	1.39	79	79	139	13.2	95.7
	11	27.5	554.550	0.110	1.39	79	79	139	14.0	95.1
	12	30.0	556.152	0.110	1.39	79	79	139	14.0	95.8
Average:				0.107	1.366	78.0	78.0	138.8		96.0

A. Lanfranco and Associates Inc.
METLab CEM Report

Client: Cantimber
Source: Carbonization Stack
Run: 1
O2 Correction: 8
Year: 2016
Moisture % = 16.43

Date	Time	O2 (Vol. %)	CO2 (Vol. %)	CO (ppm)	THC (ppm as CH4)	SOx (ppm)	NOx (ppm)
08-Nov	1216	11.03	9.86	86.3	23.7	1.5	35.4
08-Nov	1217	11.24	9.69	88.8	23.6	1.4	35.6
08-Nov	1218	11.60	9.27	91.6	23.3	1.6	35.5
08-Nov	1219	11.71	9.20	92.7	23.2	1.6	35.4
08-Nov	1220	11.64	9.17	104.3	24.3	1.6	35.3
08-Nov	1221	11.52	9.24	150.4	28.7	1.5	35.2
08-Nov	1222	11.20	9.71	189.3	31.9	1.5	35.5
08-Nov	1223	11.01	9.72	209.4	33.2	1.4	36.4
08-Nov	1224	11.00	9.95	203.1	31.8	1.4	37.2
08-Nov	1225	11.10	9.78	191.9	30.8	1.3	37.9
08-Nov	1226	11.20	9.69	186.4	30.8	1.2	38.0
08-Nov	1227	11.30	9.54	183.0	30.8	1.1	37.5
08-Nov	1228	11.54	9.39	180.8	30.9	1.1	36.7
08-Nov	1229	11.63	9.25	174.2	30.2	1.0	35.8
08-Nov	1230	11.66	9.22	171.5	30.2	1.0	35.0
08-Nov	1231	11.69	9.17	172.0	30.0	1.0	34.2
08-Nov	1232	11.81	9.07	171.8	29.8	0.9	33.6
08-Nov	1233	12.00	8.96	169.0	30.8	0.9	33.1
08-Nov	1234	11.99	8.95	170.1	29.7	0.9	32.5
08-Nov	1235	11.81	9.17	171.8	29.7	0.8	32.2
08-Nov	1236	11.93	8.96	173.7	29.8	0.8	32.1
08-Nov	1237	11.85	9.08	172.2	29.8	0.7	31.9
08-Nov	1238	11.85	9.06	170.8	31.0	1.0	31.8
08-Nov	1239	11.87	9.11	170.0	30.7	1.6	31.6
08-Nov	1240	11.90	9.08	168.3	29.9	1.5	31.5
08-Nov	1241	11.41	9.48	166.2	30.0	1.5	33.6
08-Nov	1242	11.64	9.30	164.7	29.6	1.5	35.2
08-Nov	1243	11.70	9.24	162.9	29.1	1.5	34.7
08-Nov	1244	11.79	9.17	163.1	28.7	1.5	34.3
08-Nov	1245	11.83	9.10	161.2	29.0	1.5	33.7
08-Nov	1246	11.69	9.26	160.8	28.7	1.4	33.0
08-Nov	1247	11.71	9.25	158.4	28.6	1.4	32.7
08-Nov	1248	11.96	8.94	154.7	28.4	1.4	32.4
08-Nov	1249	11.97	8.99	154.8	28.6	1.3	32.2
08-Nov	1250	12.04	8.89	151.4	28.3	1.3	31.9
08-Nov	1251	12.10	8.86	149.0	28.1	1.2	31.3
08-Nov	1252	12.18	8.76	145.6	27.8	1.1	30.9
08-Nov	1253	12.27	8.66	144.1	27.9	1.0	30.6
08-Nov	1254	12.36	8.57	140.8	27.4	1.0	30.3
08-Nov	1255	12.41	8.51	139.4	27.0	0.9	29.8
08-Nov	1256	12.61	8.29	136.1	26.8	0.9	29.7
08-Nov	1257	12.53	8.37	137.2	27.1	0.9	29.1
08-Nov	1258	12.53	8.37	138.4	26.9	0.9	29.1
08-Nov	1259	12.56	8.35	136.8	26.9	0.9	28.7
08-Nov	1300	12.62	8.31	135.6	26.8	0.9	28.6
08-Nov	1301	12.71	8.19	133.5	27.3	0.9	28.6
08-Nov	1302	12.91	8.00	133.5	28.0	0.9	28.5
08-Nov	1303	12.92	8.00	132.0	27.8	0.8	28.3
08-Nov	1304	12.97	7.92	129.7	27.5	0.8	28.0
08-Nov	1305	12.74	8.21	129.9	27.0	0.7	28.1
08-Nov	1306	12.64	8.26	126.6	26.7	0.6	28.5
08-Nov	1307	12.65	8.24	124.0	26.5	0.6	28.9
08-Nov	1308	12.82	8.03	121.4	26.6	0.5	29.5
08-Nov	1309	12.91	7.95	120.6	27.1	0.4	29.5
08-Nov	1310	13.08	7.81	119.6	27.0	0.3	29.5
08-Nov	1311	13.16	7.74	118.4	26.7	0.3	29.1
08-Nov	1312	13.30	7.63	118.6	26.3	0.3	28.6
08-Nov	1313	13.37	7.56	117.1	26.2	0.3	28.0
08-Nov	1314	13.48	7.45	117.8	26.0	0.3	27.6
08-Nov	1315	13.54	7.38	118.4	25.4	0.3	27.2

Average	12.1	8.81	147.9	28.2	1.0	32.1
Minimum	11.0	7.38	86.3	23.2	0.3	27.2
Maximum	13.5	9.95	209.4	33.2	1.6	38.0

Mass Concentration (mg/m3 dry)	n/a	n/a	172.4	22.5	2.7	61.4
mg/m3 dry @ 8% O2			252.7	33.0	4.0	90.1

Range	25.0	20.00	500.0	1000.0	200.0	300.0
--------------	------	-------	-------	--------	-------	-------

Calibration Summary

Gas (Cert. Value)	O2	CO2	CO	THC	SOx	NOx
Analyzer Initial Span	11.03	9.98	252.2	510.43	9.5	44.9
Analyzer Initial Zero	0.13	0.02	0.0	1.68	-0.4	0.2
Initial Gas Response	10.87	9.90	246.4	510.4	9.8	45.3
Final Gas Response	11.08	9.58	242.1	489.2	9.6	43.5
Initial Zero Response	0.13	0.05	1.5	1.7	0.1	1.2
Final Zero Response	0.04	0.06	2.4	2.8	-4.4	0.4

Error Summary

Analyzer Cal. Error	(+/- 2% or 5% THC)	0.3%	0.0%	0.8%	1.7%	-0.3%	-0.3%
Initial Span System Bias	(+/- 5%)	-0.6%	-0.4%	-1.2%	0.0%	0.1%	0.1%
Final Span System Bias	(+/- 5%)	0.2%	-2.0%	-2.0%	-2.1%	0.0%	-0.5%
Initial Zero System Bias	(+/- 5%)	0.0%	0.2%	0.3%	0.0%	0.3%	0.3%
Final Zero System Bias	(+/- 5%)	-0.4%	0.2%	0.5%	0.1%	-2.0%	0.1%
Test Span Drift	(+/- 3%)	0.8%	-1.6%	-0.9%	-2.1%	-0.1%	-0.6%
Test Zero Drift	(+/- 3%)	-0.4%	0.1%	0.2%	0.1%	-2.3%	-0.3%

A. Lanfranco and Associates Inc.
METLab CEM Report

Client: Cantimber
Source: Carbonization Stack
Run: 2

O2 Correction: 8
Year: 2016

Moisture % =
 18.27

Date	Time	O2 (Vol. %)	CO2 (Vol. %)	CO (ppm)	THC (ppm as CH4)	SOx (ppm)	NOx (ppm)
08-Nov	1341	12.33	8.50	127.3	28.9	2.7	27.5
08-Nov	1342	11.16	9.73	132.7	28.2	2.6	32.9
08-Nov	1343	10.50	10.47	115.7	26.6	2.5	43.3
08-Nov	1344	10.52	10.37	101.9	25.9	2.4	45.7
08-Nov	1345	10.82	10.07	96.6	26.3	2.3	45.0
08-Nov	1346	10.44	10.47	108.2	27.6	2.3	43.8
08-Nov	1347	10.25	10.68	104.3	26.9	2.2	42.7
08-Nov	1348	10.17	10.75	88.6	26.1	2.1	41.5
08-Nov	1349	10.37	10.52	77.3	28.6	2.0	41.0
08-Nov	1350	10.55	10.35	69.5	27.8	2.0	40.2
08-Nov	1351	10.81	10.10	65.1	27.2	1.9	39.3
08-Nov	1352	11.06	9.87	61.5	26.9	1.9	38.2
08-Nov	1353	11.08	9.78	60.7	27.1	1.9	37.1
08-Nov	1354	11.32	9.59	61.1	27.1	1.8	36.2
08-Nov	1355	11.53	9.41	62.3	27.0	1.8	35.0
08-Nov	1356	11.55	9.35	66.4	27.9	1.8	34.0
08-Nov	1357	11.93	9.14	69.9	28.4	1.7	33.0
08-Nov	1358	11.88	8.96	73.2	28.0	1.7	32.3
08-Nov	1359	11.44	9.43	68.8	26.9	1.6	31.7
08-Nov	1400	11.55	9.41	65.5	26.1	1.6	31.8
08-Nov	1401	11.55	9.39	68.6	26.6	1.6	32.1
08-Nov	1402	11.62	9.25	68.6	26.5	1.6	32.5
08-Nov	1403	11.65	9.21	67.8	26.3	1.6	32.5
08-Nov	1404	11.75	9.14	69.9	26.4	1.6	32.3
08-Nov	1405	11.95	8.96	71.0	26.7	1.6	31.9
08-Nov	1406	12.17	8.74	75.4	27.1	1.6	31.6
08-Nov	1407	12.24	8.69	76.4	26.8	1.6	31.1
08-Nov	1408	12.33	8.54	76.8	26.6	1.6	30.3
08-Nov	1409	12.34	8.57	80.5	26.3	1.5	29.9
08-Nov	1410	12.24	8.68	83.2	26.3	1.5	29.7
08-Nov	1411	12.39	8.51	84.4	26.6	1.5	29.8
08-Nov	1412	12.23	8.73	96.0	26.6	1.5	30.1
08-Nov	1413	12.32	8.61	99.2	26.4	1.5	30.6
08-Nov	1414	12.51	8.42	95.8	26.2	1.4	30.2
08-Nov	1415	12.20	8.71	74.9	25.3	1.4	29.6
08-Nov	1416	12.11	8.81	65.5	25.0	1.4	29.1
08-Nov	1417	11.78	9.06	64.4	25.1	1.3	29.4
08-Nov	1418	12.11	8.83	65.4	24.9	1.3	30.3
08-Nov	1419	12.25	8.70	67.3	25.5	1.2	31.0
08-Nov	1420	12.33	8.57	68.8	25.3	1.2	31.1
08-Nov	1421	12.33	8.49	70.2	25.1	1.2	30.4
08-Nov	1422	12.48	8.54	70.3	25.4	1.1	29.9
08-Nov	1423	12.21	8.69	70.5	26.5	1.1	30.0
08-Nov	1424	12.35	8.52	73.0	27.0	1.1	30.3
08-Nov	1425	12.48	8.39	74.8	26.8	1.1	30.3
08-Nov	1426	12.41	8.46	76.5	26.6	1.0	30.3
08-Nov	1427	12.13	8.80	76.9	25.9	1.0	30.4
08-Nov	1428	12.31	8.58	76.1	26.2	1.0	31.2
08-Nov	1429	12.51	8.37	75.6	25.7	1.1	31.7
08-Nov	1430	12.50	8.37	75.7	25.1	1.0	32.1
08-Nov	1431	12.46	8.34	77.3	25.5	1.0	31.6
08-Nov	1432	12.63	8.24	77.0	25.3	0.9	30.6
08-Nov	1433	12.74	8.15	76.4	25.2	0.9	30.2
08-Nov	1434	12.91	7.96	75.2	25.3	0.8	29.3
08-Nov	1435	12.61	8.23	71.9	24.8	0.8	29.0
08-Nov	1436	12.76	8.12	70.2	25.0	0.8	28.8
08-Nov	1437	12.89	8.01	69.9	25.0	0.7	28.4
08-Nov	1438	13.26	7.64	67.1	24.8	0.8	28.3
08-Nov	1439	13.42	7.45	67.9	24.3	0.7	27.7
08-Nov	1440	13.55	7.33	68.1	23.9	0.7	26.8

Average	11.9	8.96	77.6	26.3	1.5	32.7
Minimum	10.2	7.33	60.7	23.9	0.7	26.8
Maximum	13.5	10.75	132.7	28.9	2.7	45.7

Mass Concentration (mg/m3 dry)	n/a	n/a	90.4	21.5	4.0	62.6
mg/m3 dry @ 8% O2			130.2	30.9	5.7	90.2

Range	O2	CO2	CO	THC	SOx	NOx
Calibration Summary						
Gas (Cert. Value)	10.95	9.98	248.0	502.0	10.0	45.7
Analyzer Initial Span	11.03	9.98	252.2	510.43	9.5	44.9
Analyzer Initial Zero	0.13	0.02	0.0	1.68	-0.4	0.2
Initial Gas Response	11.08	9.58	242.1	489.2	9.6	43.5
Final Gas Response	10.98	9.75	233.2	505.6	9.3	43.0
Initial Zero Response	0.04	0.06	2.4	2.8	-4.4	0.4
Final Zero Response	0.34	0.07	0.3	-7.7	-2.8	0.3

Error Summary		O2	CO2	CO	THC	SOx	NOx
Analyzer Cal. Error	(+/- 2% or 5% THC)	0.3%	0.0%	0.8%	1.7%	-0.5%	-0.3%
Initial Span System Bias	(+/- 5%)	0.2%	-2.0%	-2.0%	-2.1%	0.1%	-0.5%
Final Span System Bias	(+/- 5%)	-0.2%	-1.2%	-3.8%	-0.5%	-0.3%	-0.6%
Initial Zero System Bias	(+/- 5%)	-0.4%	0.2%	0.5%	0.1%	-4.0%	0.1%
Final Zero System Bias	(+/- 5%)	0.8%	0.3%	0.1%	-0.9%	-2.4%	0.0%
Test Span Drift	(+/- 3%)	-0.4%	0.9%	-1.8%	1.6%	-0.4%	-0.2%
Test Zero Drift	(+/- 3%)	1.2%	0.1%	-0.4%	-1.0%	1.6%	0.0%

A. Lanfranco and Associates Inc.
METLab CEM Report

Client: Cantimber
 Source: Carbonization Stack
 Run: 3
 O2 Correction: 8
 Year: 2016
 Moisture % = 17.36

Date	Time	O2 (Vol. %)	CO2 (Vol. %)	CO (ppm)	THC (ppm as CH4)	SOx (ppm)	NOx (ppm)
08-Nov	1501	11.01	8.84	38.9	18.6	1.6	36.9
08-Nov	1502	10.61	9.19	43.3	19.0	1.4	36.9
08-Nov	1503	10.28	9.50	67.4	19.6	1.2	37.3
08-Nov	1504	10.24	9.57	72.2	19.2	1.0	37.4
08-Nov	1505	10.11	10.00	52.9	19.5	0.9	37.4
08-Nov	1506	10.19	10.36	45.3	19.5	1.0	37.3
08-Nov	1507	10.45	10.43	39.0	19.5	0.9	36.7
08-Nov	1508	10.62	10.20	34.8	19.6	0.8	36.5
08-Nov	1509	10.72	10.08	32.8	19.5	0.7	35.9
08-Nov	1510	11.00	9.87	32.5	19.9	0.7	35.6
08-Nov	1511	11.17	9.72	31.8	19.8	0.7	35.1
08-Nov	1512	11.30	9.58	32.8	20.2	0.7	34.5
08-Nov	1513	11.32	9.54	34.1	20.0	0.7	34.2
08-Nov	1514	11.52	9.36	35.7	19.6	0.6	33.7
08-Nov	1515	11.59	9.30	37.7	22.1	0.5	33.3
08-Nov	1516	11.64	9.19	40.3	19.2	0.5	32.9
08-Nov	1517	11.78	9.09	43.7	20.2	0.5	32.5
08-Nov	1518	11.94	8.94	46.6	20.3	0.5	32.1
08-Nov	1519	12.14	8.66	46.4	19.9	0.5	31.7
08-Nov	1520	11.69	9.21	47.0	19.5	0.4	31.5
08-Nov	1521	10.95	9.82	47.2	19.2	0.4	33.4
08-Nov	1522	10.93	9.81	47.7	18.9	0.4	40.0
08-Nov	1523	11.16	9.62	47.3	18.5	0.4	39.6
08-Nov	1524	11.42	9.42	48.9	18.7	0.4	38.7
08-Nov	1525	11.68	9.20	49.2	21.4	0.4	37.1
08-Nov	1526	12.00	8.94	49.6	20.6	0.3	35.4
08-Nov	1527	12.20	8.68	51.0	22.0	0.3	33.6
08-Nov	1528	12.35	8.56	51.2	21.5	0.3	32.4
08-Nov	1529	12.44	8.46	52.8	22.2	0.3	31.3
08-Nov	1530	12.45	8.41	52.6	22.8	0.2	30.7
08-Nov	1531	12.25	8.66	43.3	22.1	0.2	30.0
08-Nov	1532	12.41	8.49	38.3	21.2	0.2	30.4
08-Nov	1533	12.49	8.40	38.4	20.7	0.3	30.4
08-Nov	1534	12.52	8.38	35.7	21.0	0.3	30.3
08-Nov	1535	12.57	8.38	32.8	21.1	0.3	30.5
08-Nov	1536	12.41	8.46	32.4	22.6	0.2	30.3
08-Nov	1537	12.50	8.44	31.9	22.6	0.2	30.4
08-Nov	1538	12.26	8.60	32.1	23.0	0.2	30.4
08-Nov	1539	12.23	8.63	32.1	22.9	0.3	30.7
08-Nov	1540	12.55	8.39	32.8	23.3	0.3	31.1
08-Nov	1541	12.63	8.29	34.0	23.5	0.3	31.1
08-Nov	1542	12.45	8.39	33.2	23.4	0.3	30.8
08-Nov	1543	11.81	9.15	32.0	23.2	0.2	31.3
08-Nov	1544	11.24	9.59	31.2	23.0	0.2	38.3
08-Nov	1545	11.41	9.42	28.3	23.2	0.2	39.1
08-Nov	1546	11.65	9.22	27.0	23.6	0.3	38.5
08-Nov	1547	11.72	9.09	26.2	23.1	0.3	37.2
08-Nov	1548	11.93	8.98	26.2	23.2	0.2	35.6
08-Nov	1549	12.07	8.83	26.8	23.3	0.3	33.7
08-Nov	1550	12.18	8.74	27.3	23.3	0.3	32.6
08-Nov	1551	12.25	8.68	28.0	23.3	0.3	31.8
08-Nov	1552	12.37	8.59	29.9	24.6	0.2	31.1
08-Nov	1553	12.44	8.49	31.1	24.6	0.2	30.7
08-Nov	1554	12.44	8.44	31.2	24.6	0.2	30.3
08-Nov	1555	12.36	8.50	32.4	24.9	0.3	30.0
08-Nov	1556	12.11	8.72	33.5	25.4	0.3	30.3
08-Nov	1557	11.78	9.07	33.3	25.6	0.3	35.2
08-Nov	1558	11.46	9.30	32.2	25.5	0.3	37.6
08-Nov	1559	11.63	9.16	31.7	25.4	0.2	38.0
08-Nov	1600	11.91	8.87	31.6	25.5	0.2	37.8

Average	11.7	9.07	38.5	21.7	0.4	33.9
Minimum	10.1	8.29	26.2	18.5	0.2	30.0
Maximum	12.6	10.43	72.2	25.6	1.6	40.0

Mass Concentration (mg/m3 dry)	n/a	n/a	44.8	17.5	1.2	65.0
mg/m3 dry @ 8% O2			63.0	24.6	1.7	91.2


Range	25.0	20.00	500.0	1000.0	200.0	300.0
Calibration Summary	O2	CO2	CO	THC	SOx	NOx
Gas (Cert. Value)	10.95	9.98	248.0	502.0	10.0	45.7
Analyzer Initial Span	11.03	9.98	252.2	510.43	9.5	44.9
Analyzer Initial Zero	0.13	0.02	0.0	1.68	-0.4	0.2
Initial Gas Response	10.98	9.75	233.2	505.6	9.3	43.0
Final Gas Response	10.92	10.08	243.6	528.7	8.6	45.0
Initial Zero Response	0.34	0.07	0.3	-7.7	-2.8	0.3
Final Zero Response	-0.06	0.13	0.4	-1.9	-5.1	0.9

Error Summary							
Analyzer Cal. Error	(+/- 2% or 5% THC)	0.3%	0.0%	0.8%	1.7%	-0.3%	-0.3%
Initial Span System Bias	(+/- 5%)	-0.2%	-1.2%	-3.8%	-0.5%	-0.1%	-0.6%
Final Span System Bias	(+/- 5%)	-0.4%	0.5%	-1.7%	1.8%	-0.5%	0.0%
Initial Zero System Bias	(+/- 5%)	0.8%	0.3%	0.1%	-0.9%	-1.2%	0.0%
Final Zero System Bias	(+/- 5%)	-0.8%	0.6%	0.1%	-0.4%	-2.4%	0.2%
Test Span Drift	(+/- 3%)	-0.2%	1.7%	2.1%	2.3%	-0.3%	0.7%
Test Zero Drift	(+/- 3%)	-1.6%	0.3%	0.0%	0.6%	-1.1%	0.2%

Carbonization Stack - Run 1 (November 8, 2016)

CanTimber
METLab CEM Results


Note: CO is referenced to the right hand axis (0-250), all others on the left (0-40)



Carbonization Stack - Run 2 (November 8, 2016) Cantimber

METLab CEM Results


Note: CO is referenced to the right hand axis (0-140), all others on the left (0-40)



Carbonization Stack - Run 3 (Nov 8, 2016) Cantimber

METLab CEM Results

Note: CO is referenced to the right hand axis (0-80), all others on the left (0-40)



Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Activation Stack

Date: Nov.9, 2016
Run: 1 Part/Cond
Run Time: 09:50-10:51

Particulate Concentration:	1.1 mg/dscm	0.0005 gr/dscf
	0.8 mg/Acm	0.0004 gr/Acf
Front Half:	1.1 mg/dscm	
Back Half:	0.0 mg/dscm	
	1.8 mg/dscm (@ 8% O2)	0.0008 gr/dscf (@ 8% O2)
Emission Rate:	0.00 Kg/hr	0.004 lb/hr
Sample Gas Volume:	1.1880 dscm	41.955 dscf
Total Sample Time:	60.0 minutes	
Average Isokineticity:	97.7 %	
Flue Gas Characteristics		
Moisture:	15.86	
Temperature	59.0 oC	138.3 oF
Flow	28.2 dscm/min	996 dscf/min
	0.47 dscm/sec	16.6 dscf/sec
	37.7 Acm/min	1333 Acf/min
Velocity	5.518 m/sec	18.10 f/sec
Gas Analysis	13.00 % O2	7.37 % CO2
	29.699 Mol. Wt (g/gmole) Dry	27.844 Mol. Wt (g/gmole) Wet

* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa
 Imperial: 68 deg F, 29.92 in.Hg

Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Activation Stack

Date: Nov.9, 2016
Run: 1 Part/Cond
Run Time: 09:50-10:51

Control Unit (Y) 1.0194
 Nozzle Diameter (in.) 0.4020
 Pitot Factor 0.8450
 Baro. Press. (in. Hg) 30.11
 Static Press. (in. H2O) 0.03
 Stack Height (ft) 40
 Stack Diameter (in.) 15.0
 Stack Area (sq.ft.) 1.227
 Minutes Per Reading 2.5
 Minutes Per Point 2.5
 Port Length (inches) 3.0

Gas Analysis (Vol. %):

	CO2	O2
CEM AVG:	7.37	13.00
Average =	7.37	13.00

Condensate Collection:

Impinger 1 (grams)	122.0
Impinger 2 (grams)	34.0
Impinger 3 (grams)	2.0
Impinger 4 (grams)	10.0

Total Gain (grams) 168.0

Collection:

Filter (grams)	0.0003
Washings (grams)	0.0010
Impinger (grams)	0.0000
Total (grams)	0.0013

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
		0.0	557.570							
1	1	2.5	559.160	0.080	1.45	59	59	138	1.0	97.7
	2	5.0	560.750	0.080	1.45	59	59	138	1.0	97.7
	3	7.5	562.340	0.080	1.45	59	59	138	1.8	97.7
	4	10.0	563.930	0.080	1.45	59	59	137	2.6	97.6
	5	12.5	565.520	0.080	1.45	59	59	137	3.7	97.6
	6	15.0	567.300	0.100	1.81	59	59	137	5.3	97.8
	7	17.5	569.080	0.100	1.81	59	59	137	9.7	97.8
	8	20.0	570.860	0.100	1.81	60	60	138	11.2	97.7
	9	22.5	572.640	0.100	1.81	60	60	138	12.3	97.7
	10	25.0	574.430	0.100	1.81	61	61	138	13.2	98.0
	11	27.5	576.220	0.100	1.81	61	61	138	14.0	98.0
	12	30.0	578.010	0.100	1.81	62	62	138	14.0	97.9
		0.0	578.010							
2	1	2.5	579.610	0.080	1.46	63	63	139	1.0	97.6
	2	5.0	581.210	0.080	1.46	63	63	139	1.0	97.6
	3	7.5	582.310	0.080	1.46	63	63	139	1.8	67.1
	4	10.0	584.420	0.080	1.46	64	64	138	2.6	128.4
	5	12.5	586.030	0.080	1.46	64	64	138	3.7	97.9
	6	15.0	587.640	0.080	1.46	65	65	139	5.3	97.8
	7	17.5	589.250	0.080	1.46	66	66	139	9.7	97.7
	8	20.0	591.050	0.100	1.83	66	66	139	11.2	97.7
	9	22.5	592.850	0.100	1.83	66	66	139	12.3	97.7
	10	25.0	594.650	0.100	1.83	67	67	139	13.2	97.6
	11	27.5	596.260	0.080	1.47	68	68	139	14.0	97.3
	12	30.0	597.886	0.080	1.47	69	69	139	14.0	98.1
		Average:		0.088	1.607	62.5	62.5	138.3		97.7

Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Activation Stack

Date: Nov.9, 2016
Run: 2 - Part/Cond
Run Time: 11:25-12:28

Particulate Concentration: **2.9 mg/dscm** 0.0013 gr/dscf
 2.2 mg/Acm 0.0010 gr/Acf

Front Half: 2.9 mg/dscm
 Back Half: 0.0 mg/dscm

4.8 mg/dscm (@ 8% O2) 0.0021 gr/dscf (@ 8% O2)

Emission Rate: 0.00 Kg/hr 0.011 lb/hr

Sample Gas Volume: 1.1533 dscm 40.729 dscf
Total Sample Time: 60.0 minutes

Average Isokineticity: 99.3 %

Flue Gas Characteristics

Moisture: 15.92

Temperature 58.3 oC 136.9 oF

Flow 27.0 dscm/min 952 dscf/min
 0.45 dscm/sec 15.9 dscf/sec
 36.0 Acm/min 1272 Acf/min

Velocity 5.264 m/sec 17.27 f/sec

Gas Analysis 13.02 % O2 7.30 % CO2

29.688 Mol. Wt (g/gmole) Dry 27.828 Mol. Wt (g/gmole) Wet

* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa
 Imperial: 68 deg F, 29.92 in.Hg

Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Activation Stack

Date: Nov.9, 2016
Run: 2 - Part/Cond
Run Time: 11:25-12:28

Control Unit (Y) 1.0194
 Nozzle Diameter (in.) 0.4020
 Pitot Factor 0.8450
 Baro. Press. (in. Hg) 30.11
 Static Press. (in. H2O) 0.03
 Stack Height (ft) 40
 Stack Diameter (in.) 15.0
 Stack Area (sq.ft.) 1.227
 Minutes Per Reading 2.5
 Minutes Per Point 2.5
 Port Length (inches) 3.0

Gas Analysis (Vol. %):

	CO2	O2
CEM AVG:	7.30	13.02
<hr/>		
Average =	<u>7.30</u>	<u>13.02</u>

Condensate Collection:

Impinger 1 (grams)	130.0
Impinger 2 (grams)	20.0
Impinger 3 (grams)	4.0
Impinger 4 (grams)	9.8

Total Gain (grams) 163.8

Collection:

Filter (grams)	0.0004
Washings (grams)	0.0030
Impinger (grams)	0.0000
<hr/>	
Total (grams)	<u>0.0034</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
		0.0	598.035							
1	1	2.5	599.550	0.070	1.30	71	71	138	1.0	97.2
	2	5.0	601.070	0.070	1.30	71	71	138	1.0	97.6
	3	7.5	602.590	0.070	1.30	71	71	138	1.8	97.6
	4	10.0	604.220	0.080	1.48	71	71	137	2.6	97.8
	5	12.5	605.850	0.080	1.48	71	71	137	3.7	97.8
	6	15.0	607.480	0.080	1.48	71	71	137	5.3	97.8
	7	17.5	609.110	0.080	1.48	71	71	137	9.7	97.8
	8	20.0	610.740	0.080	1.48	71	71	137	11.2	97.8
	9	22.5	612.370	0.080	1.48	71	71	137	12.3	97.8
	10	25.0	614.040	0.080	1.54	71	71	137	13.2	100.2
	11	27.5	615.710	0.080	1.54	71	71	137	14.0	100.2
	12	30.0	617.380	0.080	1.54	71	71	137	14.0	100.2
		0.0	617.380							
2	1	2.5	619.050	0.080	1.54	72	72	137	1.0	100.0
	2	5.0	620.720	0.080	1.54	72	72	137	1.0	100.0
	3	7.5	622.390	0.080	1.54	72	72	137	1.8	100.0
	4	10.0	624.260	0.100	1.94	73	73	136	2.6	100.0
	5	12.5	626.140	0.100	1.94	73	73	136	3.7	100.6
	6	15.0	627.820	0.080	1.55	73	73	136	5.3	100.4
	7	17.5	629.500	0.080	1.55	73	73	137	9.7	100.5
	8	20.0	631.180	0.080	1.55	74	74	137	11.2	100.3
	9	22.5	632.860	0.080	1.56	74	74	136	12.3	100.2
	10	25.0	634.540	0.080	1.56	75	75	136	13.2	100.0
	11	27.5	636.220	0.080	1.56	75	75	137	14.0	100.1
	12	30.0	637.904	0.080	1.56	75	75	137	14.0	100.3
Average:			0.080	1.533	72.2	72.2	136.9	99.3		

Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Activation Stack

Date: Nov.9, 2016
Run: 3 - Part/Cond
Run Time: 13:10-14:16

Particulate Concentration:	1.4 mg/dscm	0.0006 gr/dscf
	1.0 mg/Acm	0.0004 gr/Acf
Front Half:	1.4 mg/dscm	
Back Half:	0.0 mg/dscm	
	2.2 mg/dscm (@ 8% O2)	0.0010 gr/dscf (@ 8% O2)
Emission Rate:	0.00 Kg/hr	0.005 lb/hr
Sample Gas Volume:	1.1802 dscm	41.677 dscf
Total Sample Time:	60.0 minutes	
Average Isokineticity:	100.1 %	
Flue Gas Characteristics		
Moisture:	15.83	
Temperature	57.7 oC	135.8 oF
Flow	27.4 dscm/min	966 dscf/min
	0.46 dscm/sec	16.1 dscf/sec
	36.5 Acm/min	1287 Acf/min
Velocity	5.329 m/sec	17.48 f/sec
Gas Analysis	13.10 % O2	7.09 % CO2
	29.659 Mol. Wt (g/gmole) Dry	27.813 Mol. Wt (g/gmole) Wet

* **Standard Conditions:** Metric: 20 deg C, 101.325 kPa
 Imperial: 68 deg F, 29.92 in.Hg

Client: Cantimber
Jobsite: Pt. Alberni, BC
Source: Activation Stack

Date: Nov.9, 2016
Run: 3 - Part/Cond
Run Time: 13:10-14:16

Control Unit (Y) 1.0194
 Nozzle Diameter (in.) 0.4020
 Pitot Factor 0.8450
 Baro. Press. (in. Hg) 30.11
 Static Press. (in. H2O) 0.03
 Stack Height (ft) 40
 Stack Diameter (in.) 15.0
 Stack Area (sq.ft.) 1.227
 Minutes Per Reading 2.5
 Minutes Per Point 2.5
 Port Length (inches) 3.0

Gas Analysis (Vol. %):

	CO2	O2
CEM AVG:	7.09	13.10
<hr/>		
Average =	<u>7.09</u>	<u>13.10</u>

Condensate Collection:

Impinger 1 (grams)	142.0
Impinger 2 (grams)	12.0
Impinger 3 (grams)	2.0
Impinger 4 (grams)	10.5

Total Gain (grams) 166.5

Collection:

Filter (grams)	0.0005
Washings (grams)	0.0011
Impinger (grams)	0.0000
Total (grams)	<u>0.0016</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
		0.0	638.100							
1	1	2.5	639.790	0.080	1.56	77	77	136	1.0	100.1
	2	5.0	641.480	0.080	1.56	77	77	136	1.0	100.1
	3	7.5	643.170	0.080	1.56	77	77	136	1.8	100.1
	4	10.0	644.860	0.080	1.56	77	77	136	2.6	100.1
	5	12.5	646.550	0.080	1.56	77	77	136	3.7	100.1
	6	15.0	648.240	0.080	1.56	77	77	136	5.3	100.1
	7	17.5	649.930	0.080	1.56	77	77	136	9.7	100.1
	8	20.0	651.620	0.080	1.56	77	77	136	11.2	100.1
	9	22.5	653.310	0.080	1.56	77	77	136	12.3	100.1
	10	25.0	655.000	0.080	1.56	78	78	136	13.2	99.9
	11	27.5	656.690	0.080	1.56	78	78	136	14.0	99.9
	12	30.0	658.380	0.080	1.56	78	78	136	14.0	99.9
		0.0	658.380							
2	1	2.5	660.080	0.080	1.57	79	79	136	1.0	100.3
	2	5.0	661.780	0.080	1.57	79	79	136	1.0	100.3
	3	7.5	663.480	0.080	1.57	79	79	136	1.8	100.3
	4	10.0	665.180	0.080	1.57	79	79	136	2.6	100.3
	5	12.5	666.870	0.080	1.57	79	79	136	3.7	99.7
	6	15.0	668.560	0.080	1.57	79	79	136	5.3	99.7
	7	17.5	670.260	0.100	1.96	79	79	136	9.7	100.4
	8	20.0	672.350	0.100	1.96	79	79	136	11.2	99.8
	9	22.5	674.250	0.100	1.96	80	80	135	12.3	100.1
	10	25.0	675.950	0.080	1.57	80	80	135	13.2	100.0
	11	27.5	677.650	0.080	1.57	80	80	135	14.0	100.0
	12	30.0	679.356	0.080	1.57	80	80	135	14.0	100.4
Average:			0.083		1.614	78.3	78.3	135.8		100.1

A. Lanfranco and Associates Inc.
METLab CEM Report

Client: Cantimber
Source: Activation Stack
Run: 1
O2 Correction: 8
Year: 2016
Moisture % = 15.86

Date	Time	O2 (Vol. %)	CO2 (Vol. %)	CO (ppm)	THC (ppm as CH4)	SOx (ppm)	NOx (ppm)
09-Nov	1016	12.97	7.34	2722.1	33.3	0.1	30.0
09-Nov	1017	12.95	7.36	2722.1	33.6	0.2	29.7
09-Nov	1018	12.98	7.31	2721.1	34.4	0.1	29.6
09-Nov	1019	13.01	7.31	2722.1	33.7	0.2	29.6
09-Nov	1020	13.00	7.34	2722.1	30.5	0.3	29.7
09-Nov	1021	12.97	7.38	2721.1	30.3	0.2	29.6
09-Nov	1022	13.00	7.35	2721.1	31.8	0.2	29.4
09-Nov	1023	13.01	7.35	2721.1	32.2	0.1	29.1
09-Nov	1024	12.99	7.37	2721.1	31.8	0.2	29.1
09-Nov	1025	12.98	7.38	2722.1	32.7	0.1	29.3
09-Nov	1026	13.00	7.38	2721.1	32.1	0.2	29.4
09-Nov	1027	12.99	7.39	2721.1	32.0	0.3	29.1
09-Nov	1028	13.00	7.37	2721.1	32.1	0.2	29.1
09-Nov	1029	12.99	7.38	2721.1	32.0	0.2	29.2
09-Nov	1030	12.98	7.40	2721.1	32.4	0.2	29.1
09-Nov	1031	12.98	7.40	2721.1	35.2	0.2	29.0
09-Nov	1032	13.03	7.34	2721.1	34.4	0.1	29.0
09-Nov	1033	13.01	7.35	2721.1	35.3	0.2	29.1
09-Nov	1034	12.96	7.40	2721.1	35.6	0.1	29.2
09-Nov	1035	12.97	7.38	2721.1	35.7	0.2	29.3
09-Nov	1036	12.99	7.37	2721.1	36.8	0.3	29.3
09-Nov	1037	13.02	7.36	2721.1	35.9	0.2	29.4
09-Nov	1038	12.99	7.38	2721.1	35.3	0.2	29.4
09-Nov	1039	12.97	7.41	2721.1	36.9	0.1	29.3
09-Nov	1040	13.01	7.36	2721.1	38.5	0.2	29.3
09-Nov	1041	13.02	7.35	2721.1	36.8	0.3	29.3
09-Nov	1042	12.99	7.37	2721.1	35.7	0.2	29.3
09-Nov	1043	13.01	7.36	2721.1	37.7	0.1	29.3
09-Nov	1044	13.02	7.37	2721.1	35.2	0.2	29.3
09-Nov	1045	12.98	7.42	2721.1	36.7	0.3	29.2
09-Nov	1046	13.01	7.38	2721.1	37.6	0.2	29.1
09-Nov	1047	13.04	7.34	2721.1	38.0	0.2	29.0
09-Nov	1048	12.99	7.38	2721.1	35.8	0.2	29.0
09-Nov	1049	12.96	7.42	2721.1	35.9	0.2	28.9
09-Nov	1050	13.00	7.39	2721.1	34.9	0.1	28.9
09-Nov	1051	13.08	7.32	2721.1	36.8	0.2	28.8
09-Nov	1052	13.05	7.37	2721.1	39.5	0.1	28.6
09-Nov	1053	13.04	7.39	2721.1	36.1	0.2	28.4
09-Nov	1054	13.08	7.36	2721.1	37.6	0.3	28.2
09-Nov	1055	13.19	7.24	2721.1	46.2	0.2	27.9
09-Nov	1056	13.15	7.27	2721.1	46.2	0.1	27.7
09-Nov	1057	13.13	7.28	2721.1	46.0	0.2	27.6
09-Nov	1058	13.11	7.30	2721.1	45.8	0.3	27.5
09-Nov	1059	13.09	7.32	2721.1	42.8	0.2	27.5
09-Nov	1100	13.07	7.36	2721.1	43.3	0.2	27.4
09-Nov	1101	13.08	7.35	2721.1	43.4	0.2	27.3
09-Nov	1102	13.08	7.33	2721.1	41.6	0.2	27.3
09-Nov	1103	13.03	7.36	2721.1	40.6	0.3	27.1
09-Nov	1104	13.02	7.38	2721.1	41.9	0.2	27.2
09-Nov	1105	13.02	7.38	2721.1	42.5	0.3	27.4
09-Nov	1106	12.99	7.41	2721.1	41.3	0.2	27.5
09-Nov	1107	12.96	7.43	2721.1	40.8	0.2	27.5
09-Nov	1108	12.94	7.45	2721.1	42.3	0.2	27.5
09-Nov	1109	12.94	7.45	2721.1	43.9	0.2	27.5
09-Nov	1110	12.92	7.47	2721.1	43.0	0.1	27.4
09-Nov	1111	12.96	7.42	2721.1	44.4	0.2	27.4
09-Nov	1112	12.97	7.42	2721.1	45.5	0.1	27.4
09-Nov	1113	12.95	7.43	2721.1	45.0	0.2	27.5
09-Nov	1114	12.88	7.49	2721.1	45.6	0.3	27.3
09-Nov	1115	12.53	7.53	2721.1	45.4	0.2	27.5

Average	13.0	7.37	2721.2	37.9	0.2	28.6
Minimum	12.8	7.24	2721.1	30.3	0.1	27.1
Maximum	13.2	7.53	2722.1	46.2	0.3	30.0

Mass Concentration (mg/m3 drv)
mg/m3 drv @ 8% O2

n/a	n/a	3170.6	30.1	0.5	54.7
		5178.5	49.1	0.8	89.3

Range

25.0	20.00	2500.0	100.0	200.0	300.0
------	-------	--------	-------	-------	-------

Calibration Summary

Gas (Cert. Value)	O2	CO2	CO	THC	SOx	NOx
Analyzer Initial Span	11.00	10.04	248.0	43.2	10.0	45.2
Analyzer Initial Zero	0.00	0.03	2.7	0.72	-0.3	0.6
Initial Gas Response	10.99	9.92	244.6	43.2	10.2	44.9
Final Gas Response	11.08	9.93	243.6	44.1	6.4	43.0
Initial Zero Response	0.11	0.07	1.4	0.7	0.1	0.7
Final Zero Response	0.18	0.11	4.5	0.1	-3.0	0.6

Error Summary

Analyzer Cal. Error	(+/- 2% or 5% THC)	0.2%	0.3%	0.0%	-2.0%	0.0%	-0.2%
Initial Span System Bias	(+/- 5%)	0.0%	-0.6%	-0.1%	0.0%	0.1%	-0.1%
Final Span System Bias	(+/- 5%)	0.3%	-0.5%	-0.2%	0.8%	-1.8%	-0.7%
Initial Zero System Bias	(+/- 5%)	0.4%	0.2%	-0.1%	0.0%	0.2%	0.0%
Final Zero System Bias	(+/- 5%)	0.7%	0.4%	0.1%	-0.6%	-1.3%	0.0%
Test Span Drift	(+/- 3%)	0.4%	0.0%	0.0%	0.8%	-1.9%	-0.6%
Test Zero Drift	(+/- 3%)	0.3%	0.2%	0.1%	-0.6%	-1.5%	0.0%

A. Lanfranco and Associates Inc.
METLab CEM Report

Client: Cantimber
Source: Activation Stack
Run: 2

O2 Correction: 8
Year: 2016

Moisture % =
 15.92

Date	Time	O2 (Vol. %)	CO2 (Vol. %)	CO (ppm)	THC (ppm as CH4)	SOx (ppm)	NOx (ppm)
09-Nov	1136	13.03	7.25	2738.1	60.8	0.3	29.4
09-Nov	1137	13.06	7.23	2738.1	58.9	0.2	29.5
09-Nov	1138	13.02	7.27	2738.1	54.8	0.2	29.5
09-Nov	1139	13.00	7.32	2738.1	56.9	0.2	29.5
09-Nov	1140	13.07	7.23	2738.1	59.0	0.2	29.5
09-Nov	1141	13.08	7.22	2738.1	59.2	0.2	29.5
09-Nov	1142	12.95	7.35	2738.1	59.2	0.2	29.6
09-Nov	1143	12.97	7.32	2738.1	58.5	0.2	29.7
09-Nov	1144	12.98	7.32	2738.1	59.8	0.1	29.8
09-Nov	1145	12.97	7.33	2738.1	54.5	0.1	29.9
09-Nov	1146	13.00	7.31	2738.1	53.8	0.1	30.1
09-Nov	1147	13.01	7.31	2738.1	55.5	0.2	30.2
09-Nov	1148	13.02	7.30	2738.1	54.4	0.2	30.3
09-Nov	1149	12.99	7.33	2738.1	54.1	0.2	30.3
09-Nov	1150	12.98	7.32	2738.1	56.8	0.2	30.2
09-Nov	1151	12.97	7.35	2738.1	57.7	0.2	30.3
09-Nov	1152	12.99	7.34	2738.1	57.2	0.1	30.2
09-Nov	1153	13.00	7.32	2738.1	58.9	0.1	30.2
09-Nov	1154	13.02	7.32	2738.1	59.4	0.1	30.3
09-Nov	1155	13.01	7.34	2738.1	57.2	0.1	30.1
09-Nov	1156	13.02	7.31	2738.1	55.2	0.1	30.1
09-Nov	1157	13.03	7.32	2738.1	51.5	0.1	30.0
09-Nov	1158	13.03	7.33	2738.1	51.9	0.1	29.8
09-Nov	1159	13.04	7.31	2738.1	51.2	0.1	29.7
09-Nov	1200	13.01	7.34	2738.1	51.0	0.1	29.5
09-Nov	1201	13.02	7.32	2738.1	51.0	0.0	29.4
09-Nov	1202	13.02	7.33	2738.1	51.7	0.2	29.5
09-Nov	1203	13.04	7.31	2738.1	54.9	0.2	29.7
09-Nov	1204	13.02	7.32	2738.1	51.9	0.2	30.2
09-Nov	1205	13.00	7.34	2738.1	55.0	0.2	30.7
09-Nov	1206	13.02	7.33	2738.1	54.1	0.1	31.1
09-Nov	1207	13.02	7.34	2738.1	56.0	0.1	31.3
09-Nov	1208	12.98	7.35	2738.1	52.6	0.1	31.3
09-Nov	1209	12.99	7.33	2738.1	52.5	0.2	31.3
09-Nov	1210	13.01	7.34	2738.1	54.1	0.2	31.1
09-Nov	1211	13.03	7.33	2738.1	56.1	0.2	30.9
09-Nov	1212	13.06	7.29	2738.1	55.8	0.2	30.9
09-Nov	1213	13.04	7.28	2738.1	54.4	0.1	31.1
09-Nov	1214	13.03	7.30	2738.1	57.2	0.1	31.3
09-Nov	1215	13.02	7.31	2738.1	56.9	0.1	31.4
09-Nov	1216	13.03	7.31	2738.1	58.3	0.1	31.5
09-Nov	1217	13.02	7.29	2738.1	59.5	0.2	31.6
09-Nov	1218	13.00	7.32	2738.1	59.1	0.2	32.0
09-Nov	1219	13.02	7.30	2738.1	62.0	0.2	32.2
09-Nov	1220	13.04	7.28	2738.1	64.1	0.2	32.4
09-Nov	1221	13.07	7.25	2738.1	64.5	0.1	32.5
09-Nov	1222	13.03	7.28	2738.1	60.8	0.1	32.5
09-Nov	1223	13.04	7.28	2738.1	64.2	0.1	32.5
09-Nov	1224	13.02	7.26	2738.1	73.6	0.1	32.5
09-Nov	1225	13.05	7.21	2738.1	71.9	0.1	32.7
09-Nov	1226	13.07	7.19	2738.1	69.5	0.1	33.1
09-Nov	1227	13.01	7.23	2738.1	70.7	0.1	33.5
09-Nov	1228	13.01	7.22	2738.1	72.0	0.1	33.7
09-Nov	1229	13.02	7.21	2738.1	70.5	0.1	33.7
09-Nov	1230	13.04	7.26	2738.1	65.0	0.0	33.5
09-Nov	1231	13.05	7.25	2738.1	65.0	0.2	33.3
09-Nov	1232	13.03	7.25	2738.1	63.3	0.2	33.0
09-Nov	1233	13.03	7.26	2738.1	63.0	0.2	32.8
09-Nov	1234	13.06	7.25	2738.1	65.4	0.2	32.6
09-Nov	1235	13.09	7.22	2738.1	68.0	0.1	32.5

Average	13.0	7.30	2738.1	58.9	0.1	31.0
Minimum	12.9	7.19	2738.1	51.0	0.0	29.4
Maximum	13.1	7.35	2738.1	73.6	0.3	33.7

Mass Concentration (mg/m3 dry)	n/a	n/a	3190.3	46.7	0.4	59.4
mg/m3 dry @ 8% O2			5223.1	76.5	0.6	97.3

Range	25.0	20.00	2500.0	100.0	200.0	300.0
--------------	------	-------	--------	-------	-------	-------

Calibration Summary

Gas (Cert. Value)	O2	CO2	CO	THC	SOx	NOx
Analyzer Initial Span	11.00	10.04	248.0	43.2	10.0	45.2
Analyzer Initial Zero	0.00	0.03	2.7	0.72	-0.3	0.6
Initial Gas Response	11.08	9.93	243.6	44.1	6.4	43.0
Final Gas Response	11.13	9.87	243.1	42.1	6.1	41.6
Initial Zero Response	0.28	0.11	4.5	0.1	-3.0	0.6
Final Zero Response	0.18	0.09	2.9	-0.1	-3.3	0.3

Error Summary

Analyzer Cal. Error	(+/- 2% or 5% THC)	0.2%	0.3%	0.0%	-2.0%	0.0%	-0.2%
Initial Span System Bias	(+/- 5%)	0.3%	-0.5%	-0.2%	0.8%	-1.8%	-0.7%
Final Span System Bias	(+/- 5%)	0.5%	-0.9%	-0.2%	-1.1%	-1.9%	-1.2%
Initial Zero System Bias	(+/- 5%)	1.1%	0.4%	0.1%	-0.6%	-1.3%	0.0%
Final Zero System Bias	(+/- 5%)	0.7%	0.3%	0.0%	-0.8%	-1.5%	-0.1%
Test Span Drift	(+/- 3%)	0.2%	-0.3%	0.0%	-2.0%	-0.1%	-0.5%
Test Zero Drift	(+/- 3%)	-0.4%	-0.1%	-0.1%	-0.2%	-0.2%	-0.1%

A. Lanfranco and Associates Inc.
METLab CEM Report

Client: Cantimber
 Source: Activation Slack
 Run: 3
 O2 Correction: 8
 Year: 2016
 Moisture % = 15.83

Date	Time	O2 (Vol. %)	CO2 (Vol. %)	CO (ppm)	THC (ppm as CH4)	SOx (ppm)	NOx (ppm)
09-Nov	1311	13.07	7.15	2739.7	86.6	0.1	32.6
09-Nov	1312	13.10	7.13	2739.7	85.2	0.1	32.9
09-Nov	1313	13.10	7.13	2739.7	86.7	0.1	33.0
09-Nov	1314	13.11	7.13	2739.7	87.9	0.1	33.2
09-Nov	1315	13.12	7.13	2739.7	89.0	0.1	33.4
09-Nov	1316	13.10	7.14	2739.7	86.4	0.1	33.6
09-Nov	1317	13.10	7.15	2739.7	84.6	0.1	33.8
09-Nov	1318	13.11	7.15	2739.7	87.9	0.1	33.8
09-Nov	1319	13.12	7.13	2739.7	89.6	0.1	33.8
09-Nov	1320	13.09	7.15	2739.7	86.6	0.0	34.0
09-Nov	1321	13.07	7.16	2739.7	87.9	0.1	34.1
09-Nov	1322	13.10	7.12	2739.7	91.6	0.1	34.1
09-Nov	1323	13.12	7.10	2739.7	91.9	0.1	34.2
09-Nov	1324	13.15	7.09	2739.7	94.3	0.2	34.2
09-Nov	1325	13.13	7.10	2739.7	91.0	0.1	34.4
09-Nov	1326	13.10	7.13	2739.7	90.9	0.2	34.4
09-Nov	1327	13.11	7.11	2739.7	94.2	0.1	34.3
09-Nov	1328	13.13	7.10	2739.7	94.4	0.2	34.2
09-Nov	1329	13.15	7.09	2739.7	94.9	0.2	34.0
09-Nov	1330	13.11	7.12	2739.7	93.7	0.1	34.0
09-Nov	1331	13.10	7.12	2739.7	93.8	0.1	33.9
09-Nov	1332	13.12	7.10	2739.7	96.1	0.1	33.7
09-Nov	1333	13.13	7.10	2739.7	93.3	0.1	33.5
09-Nov	1334	13.11	7.11	2739.7	90.0	0.1	33.4
09-Nov	1335	13.10	7.12	2739.7	95.7	0.0	33.3
09-Nov	1336	13.11	7.10	2739.7	95.7	0.1	33.2
09-Nov	1337	13.13	7.08	2739.7	98.3	0.1	33.2
09-Nov	1338	13.11	7.09	2739.7	97.9	0.1	33.1
09-Nov	1339	13.07	7.11	2739.7	96.2	0.2	33.2
09-Nov	1340	13.08	7.10	2739.7	96.6	0.2	33.2
09-Nov	1341	13.12	7.07	2739.7	99.2	0.1	33.0
09-Nov	1342	13.13	7.06	2739.7	104.2	0.1	32.9
09-Nov	1343	13.09	7.08	2739.7	102.0	0.1	32.8
09-Nov	1344	13.08	7.08	2739.7	100.2	0.1	32.7
09-Nov	1345	13.10	7.07	2739.7	107.0	0.1	32.7
09-Nov	1345	15.08	7.07	2739.7	103.8	0.2	32.8
09-Nov	1346	13.11	7.05	2739.7	102.6	0.2	32.8
09-Nov	1347	13.11	7.06	2739.7	105.9	0.1	32.9
09-Nov	1348	13.09	7.07	2739.7	111.3	0.1	32.8
09-Nov	1349	13.06	7.11	2739.7	102.6	0.2	32.7
09-Nov	1350	13.08	7.11	2739.7	105.9	0.2	32.4
09-Nov	1351	13.09	7.07	2739.7	111.3	0.2	32.2
09-Nov	1352	13.10	7.05	2739.7	104.8	0.2	32.2
09-Nov	1353	13.07	7.09	2739.7	102.9	0.1	32.1
09-Nov	1354	13.08	7.09	2739.7	103.0	0.0	31.9
09-Nov	1355	13.08	7.09	2739.7	105.4	0.1	31.6
09-Nov	1356	13.11	7.07	2739.7	105.2	0.1	31.2
09-Nov	1357	13.08	7.09	2739.7	102.6	0.2	30.9
09-Nov	1358	13.07	7.09	2739.7	101.0	0.2	30.7
09-Nov	1359	13.08	7.09	2739.7	100.0	0.2	30.4
09-Nov	1400	13.10	7.07	2739.7	102.2	0.2	30.2
09-Nov	1401	13.12	7.05	2739.7	105.2	0.1	30.0
09-Nov	1402	13.14	7.04	2739.7	105.0	0.1	29.8
09-Nov	1403	13.11	7.04	2739.7	101.9	0.0	29.7
09-Nov	1404	13.09	7.04	2739.7	101.9	0.1	29.7
09-Nov	1405	13.11	7.04	2739.7	103.9	0.1	29.7
09-Nov	1406	13.10	7.05	2739.7	103.9	0.1	29.6
09-Nov	1407	13.13	7.02	2739.7	107.7	0.1	29.5
09-Nov	1408	13.14	6.99	2739.7	112.0	0.1	29.4
09-Nov	1409	13.11	7.01	2739.7	104.5	0.1	29.6

Average	13.1	7.09	2739.7	98.0	0.1	32.5
Minimum	13.1	6.99	2739.7	84.6	0.0	29.4
Maximum	13.1	7.16	2739.7	112.0	0.2	34.4

Mass Concentration (mg/m3 dry) n/a n/a 3192.2 77.7 0.3 62.2
 mg/m3 dry @ 8% O2 5280.2 128.5 0.5 102.9

Range 25.0 20.00 2500.0 100.0 200.0 300.0

Calibration Summary

Gas (Cert. Value)	O2	CO2	CO	THC	SOx	NOx
Analyzer Initial Span	11.00	10.04	248.0	43.2	10.0	45.2
Analyzer Initial Zero	0.00	0.03	2.7	0.72	-0.3	0.6
Initial Gas Response	11.11	9.87	243.1	42.1	6.1	41.6
Final Gas Response	11.13	9.96	248.3	42.6	6.1	42.4
Initial Zero Response	0.24	0.09	2.9	-0.1	-3.3	0.5
Final Zero Response	0.28	0.15	10.1	1.0	-3.2	1.0

Error Summary


Analyzer Cal. Error	(+/- 2% or 5% THC)	0.2%	0.3%	0.0%	-2.0%	0.0%	-0.2%
Initial Span System Bias	(+/- 5%)	0.4%	-0.9%	-0.2%	-1.1%	-1.9%	-1.2%
Final Span System Bias	(+/- 5%)	0.5%	-0.4%	0.0%	-0.6%	-1.9%	-0.9%
Initial Zero System Bias	(+/- 5%)	1.0%	0.3%	0.0%	-0.8%	-1.5%	0.0%
Final Zero System Bias	(+/- 5%)	1.1%	0.6%	0.3%	0.3%	-1.5%	0.1%
Test Span Drift	(+/- 3%)	0.1%	0.5%	0.2%	0.5%	0.0%	0.3%
Test Zero Drift	(+/- 3%)	0.2%	0.3%	0.3%	1.0%	0.0%	0.2%

Activation Stack - Run 1 (November 9, 2016)

CanTimber

METLab CEM Results


Note: Minutely data for CO is not shown, because CO concentrations were above the max scale of analyzer



Activation Stack - Run 2 (November 9, 2016) Cantimber

METLab CEM Results


Note: Minutely data for CO is not shown, because CO concentrations were above the max scale of analyzer



Activation Stack - Run 3 (Nov 9, 2016) Cantimber

METLab CEM Results

Note: Minutely data for CO is not shown, because CO concentrations were above the max scale of analyzer



APPENDIX 2
ANALYTICAL DATA




Report Transmission Cover Page

Bill To: A. Lanfranco & Associates	Project:	Lot ID: 1171690
Report To: A. Lanfranco & Associates	ID: Cantimber	Control Number: C0074715
#101, 9488 - 189 Street	Name: Activation/Carbonization	Date Received: Nov 10, 2016
Surrey, BC, Canada	Location: Pt. Alberni	Date Reported: Nov 14, 2016
V4N 4W7	LSD:	Report Number: 2147720
Attn: Mark Lanfranco	P.O.: Credit card on file	
Sampled By:	Acct code:	
Company:		

Contact & Affiliation	Address	Delivery Commitments
Mark Lanfranco	#101, 9488 - 189 Street	On [Lot Verification] send
A. Lanfranco & Associates Inc.	Surrey, British Columbia V4N 4W7	(COA) by Email - Multiple Reports By Agreement
	Phone: (604) 881-2582	On [Report Approval] send
	Fax: (604) 881-2581	(COC, Test Report) by Email - Merge Reports
	Email: mark.lanfranco@alanfranco.com	On [Lot Creation] send
		(COR) by Email - Single Report

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.



Analytical Report

Bill To: A. Lanfranco & Associates
 Report To: A. Lanfranco & Associates
 #101, 9488 - 189 Street
 Surrey, BC, Canada
 V4N 4W7
 Attn: Mark Lanfranco
 Sampled By:
 Company:

Project:
 ID: Cantimber
 Name: Activation/Carbonization
 Location: Pt.Alberni
 LSD:
 P.O.: Credit card on file
 Acct code:

Lot ID: **1171690**
 Control Number: C0074715
 Date Received: Nov 10, 2016
 Date Reported: Nov 14, 2016
 Report Number: 2147720

	Reference Number	1171690-1	1171690-2	1171690-3	
	Sample Date	Nov 08, 2016	Nov 08, 2016	Nov 08, 2016	
	Sample Time	NA	NA	NA	
	Sample Location				
	Sample Description	Blank / 20°C	Carbonization Stack Run-1 / 20°C	Carbonization Stack Run-2 / 20°C	
	Matrix	Water	Water	Water	
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Aggregate Organic Constituents					
Oil and Grease	Total	mg/sample	1	2	1
Volume	Sample volume	mL	485	465	485
pH adjustment	required prior to O&G extraction		Yes	Yes	Yes



Analytical Report

Bill To: A. Lanfranco & Associates
 Report To: A. Lanfranco & Associates
 #101, 9488 - 189 Street
 Surrey, BC, Canada
 V4N 4W7
 Attn: Mark Lanfranco
 Sampled By:
 Company:

Project:
 ID: Cantimber
 Name: Activation/Carbonization
 Location: Pt.Alberni
 LSD:
 P.O.: Credit card on file
 Acct code:

Lot ID: **1171690**
 Control Number: C0074715
 Date Received: Nov 10, 2016
 Date Reported: Nov 14, 2016
 Report Number: 2147720

	Reference Number	1171690-4	1171690-5	1171690-6	
	Sample Date	Nov 08, 2016	Nov 09, 2016	Nov 09, 2016	
	Sample Time	NA	NA	NA	
	Sample Location				
	Sample Description	Carbonization Stack Run-3 / 20°C	Activation Stack Run-1 / 20°C	Activation Stack Run-2 / 20°C	
	Matrix	Water	Water	Water	
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Aggregate Organic Constituents					
Oil and Grease	Total	mg/sample	2	1	1
Volume	Sample volume	mL	460	465	455
pH adjustment	required prior to O&G extraction		Yes	Yes	Yes



Analytical Report

Bill To: A. Lanfranco & Associates
 Report To: A. Lanfranco & Associates
 #101, 9488 - 189 Street
 Surrey, BC, Canada
 V4N 4W7
 Attn: Mark Lanfranco
 Sampled By:
 Company:


Project:
 ID: Cantimber
 Name: Activation/Carbonization
 Location: Pt.Alberni
 LSD:
 P.O.: Credit card on file
 Acct code:

Lot ID: **1171690**
 Control Number: C0074715
 Date Received: Nov 10, 2016
 Date Reported: Nov 14, 2016
 Report Number: 2147720

Reference Number 1171690-7
 Sample Date Nov 09, 2016
 Sample Time NA
 Sample Location
 Sample Description Activation Stack
 Run-3 / 20°C
 Matrix Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Aggregate Organic Constituents					
Oil and Grease	Total	mg/sample	<1		1
Volume	Sample volume	mL	460		
pH adjustment	required prior to O&G extraction		Yes		

Approved by: 
 Mathieu Simoneau
 Operations Manager



Methodology and Notes

Bill To: A. Lanfranco & Associates	Project:	Lot ID: 1171690
Report To: A. Lanfranco & Associates	ID: Cantimber	Control Number: C0074715
#101, 9488 - 189 Street	Name: Activation/Carbonization	Date Received: Nov 10, 2016
Surrey, BC, Canada	Location: Pt. Alberni	Date Reported: Nov 14, 2016
V4N 4W7	LSD:	Report Number: 2147720
Attn: Mark Lanfranco	P.O.: Credit card on file	
Sampled By:	Acct code:	
Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Oil and Grease in water (Surrey)	BCELM	* Oil & Grease in Water - Direct Hexane Extraction, Oil & Grease <i>* Reference Method Modified</i>	10-Nov-16	Exova Surrey

References

BCELM B.C. Environmental Laboratory Manual

Comments:

Please direct any inquiries regarding this report to our Client Services group.
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.



www.exova.com ED 120-02

Project Information
 Project ID: Cartimber
 Project Name: Activation/Carbonization
 Project Location: Pt. Alberni
 Legal Location:
 PO/A/E#:
 Proj. Acct. Code:
 Quote #

Invoice to:
 Company: A. Lanfranco + Associates
 Address:
 Attention: Mark Lanfranco
 Phone: 604-881-2582
 Cell:
 Fax:
 E-mail: Mark.lanfranco@lanfranco.com
 Agreement ID:
 Copy of report:

Report To:
 Company:
 Address:
 Attention:
 Phone:
 Cell:
 Fax:
 E-mail 1:
 E-mail 2:
 Copy of invoice:

RUSH Priority
 When "ASAP" is requested, turn around will default to a 100% RUSH priority, with pricing and turn around time to match. Please contact the lab prior to submitting RUSH samples. If not, all samples require RUSH, please indicate in the special instructions.

Report Results
 E-Mail: HCDWQG
 Mail: Ab Tier 1
 Online: SPIGEC
 Fax: BCCSR
 PDF: Other (list below)
 Excel:
 O/A/QC:
 Sample Custody (please print):
 Sampled by:

Date Required: Signature:
 Special Instructions/Comments (please include contact information including ph. # if different from above):
Please report mg/ per Sample oil + grease By hexane extraction

Site I.D.	Sample Description	Depth start in cm	end in cm	Date/Time Sampled	Matrix	Sampling Method
1	<u>BLANK</u>			<u>Nov. 8 + 9 / 16</u>		
2						
3	<u>Carbonization Stack Run-1</u>			<u>Nov. 8 / 16</u>		
4	<u>Carbonization Stack Run-2</u>			<u>"</u>		
5	<u>Carbonization Stack Run-3</u>			<u>"</u>		
6						
7	<u>Activation Stack Run-1</u>			<u>Nov. 9 / 16</u>		
8	<u>Activation Stack Run-2</u>			<u>"</u>		
9	<u>Activation Stack Run-3</u>			<u>"</u>		
10						
11						
12						
13						
14						
15						

Enter tests above relevant samples below) 0:1 + Grease

Indicate in the space allotted any deficiencies by the corresponding number.


1. Indicate any samples that were not packaged well
2. Indicate any samples not received in Exova supplies
3. Indicate any samples that were not clearly labeled
4. Indicate any samples not received within the required hold time or temp.
5. Indicate any missing or extra samples
6. Indicate any samples that were received broken
7. Indicate any samples where sufficient volume was not received
8. Indicate any samples received in an inappropriate container

Submission of this form acknowledges acceptance of Exova's Standard Terms and Conditions (<http://www.exova.com/about/terms-and-conditions/>)
 Please indicate any potentially hazardous samples

Lot: **1171690** COC

Shipping: COD Y/ N
 # and size of coolers
 Temp. received:
 Waybill:
 Received by:

Regulatory Requirement
 HCDWQG
 Ab Tier 1
 SPIGEC
 BCCSR
 Other (list below)





2655 Park Center Dr., Suite A
Simi Valley, CA 93065
T: +1 805 526 7161
F: +1 805 526 7270
www.alsglobal.com

LABORATORY REPORT

November 29, 2016

Mark Lanfranco
A. Lanfranco and Associates Inc.
Unit 101 - 9488 189 St.
Surrey, BC V4N 4W7

RE: Cantimber

Dear Mark:

Enclosed are the results of the samples submitted to our laboratory on November 11, 2016. For your reference, these analyses have been assigned our service request number P1605283.

All analyses were performed according to our laboratory's NELAP and DoD-ELAP-approved quality assurance program. The test results meet requirements of the current NELAP and DoD-ELAP standards, where applicable, and except as noted in the laboratory case narrative provided. For a specific list of NELAP and DoD-ELAP-accredited analytes, refer to the certifications section at www.alsglobal.com. Results are intended to be considered in their entirety and apply only to the samples analyzed and reported herein.

If you have any questions, please call me at (805) 526-7161.

Respectfully submitted,

ALS | Environmental

By Kelly Horiuchi at 3:21 pm, Nov 29, 2016

Kelly Horiuchi
Laboratory Director



2655 Park Center Dr., Suite A
Simi Valley, CA 93065
T: +1 805 526 7161
F: +1 805 526 7270
www.alsglobal.com

Client: A. Lanfranco and Associates Inc.
Project: Cantimber

Service Request No: P1605283

CASE NARRATIVE

The samples were received intact under chain of custody on November 11, 2016 and were stored in accordance with the analytical method requirements. Please refer to the sample acceptance check form for additional information. The results reported herein are applicable only to the condition of the samples at the time of sample receipt.

Fixed Gases Analysis

Three of the samples were analyzed for fixed gases (hydrogen, oxygen, nitrogen, carbon monoxide, methane and carbon dioxide) according to modified EPA Method 3C (single injection) using a gas chromatograph equipped with a thermal conductivity detector (TCD). This procedure is described in laboratory SOP VOA-EPA3C. This method is included on the laboratory's DoD-ELAP scope of accreditation, however it is not part of the NELAP accreditation.

Volatile Organic Compound Analysis

All of the samples were analyzed for volatile organic compounds in accordance with EPA Method TO-15 from the Compendium of Methods for the Determination of Toxic Organic Compounds in Ambient Air, Second Edition (EPA/625/R-96/010b), January, 1999. This procedure is described in laboratory SOP VOA-TO15. The analytical system was comprised of a gas chromatograph / mass spectrometer (GC/MS) interfaced to a whole-air preconcentrator. The method was modified for three of the samples to include the use of helium as a diluent gas in place of zero-grade air for container pressurization. When necessary, analytical sample volumes were adjusted by a correction factor for containers pressurized with helium. A summary sheet has been included listing the affected samples. This method is included on the laboratory's NELAP and DoD-ELAP scope of accreditation. Any analytes flagged with an X are not included on the NELAP or DoD-ELAP accreditation.

The spike recovery of carbon disulfide in the Laboratory Control Sample (LCS) was outside the laboratory generated control criteria. The recovery error equates to a potential high bias. However, the recovery in question was within the method criteria, therefore the data quality has not been significantly affected. No corrective action was taken.

The containers were cleaned, prior to sampling, down to the method reporting limit (MRL) reported for this project. Please note, projects which require reporting below the MRL could have results between the MRL and method detection limit (MDL) that are biased high.

The results of analyses are given in the attached laboratory report. All results are intended to be considered in their entirety, and ALS Environmental (ALS) is not responsible for utilization of less than the complete report.

Use of ALS Environmental (ALS)'s Name. Client shall not use ALS's name or trademark in any marketing or reporting materials, press releases or in any other manner ("Materials") whatsoever and shall not attribute to ALS any test result, tolerance or specification derived from ALS's data ("Attribution") without ALS's prior written consent, which may be withheld by ALS for any reason in its sole discretion. To request ALS's consent, Client shall provide copies of the proposed Materials or Attribution and describe in writing Client's proposed use of such Materials or Attribution. If ALS has not provided written approval of the Materials or Attribution within ten (10) days of receipt from Client, Client's request to use ALS's name or trademark in any Materials or Attribution shall be deemed denied. ALS may, in its discretion, reasonably charge Client for its time in reviewing Materials or Attribution requests. Client acknowledges and agrees that the unauthorized use of ALS's name or trademark may cause ALS to incur irreparable harm for which the recovery of money damages will be inadequate. Accordingly, Client acknowledges and agrees that a violation shall justify preliminary injunctive relief. For questions contact the laboratory.



2655 Park Center Dr., Suite A
 Simi Valley, CA 93065
 T: +1 805 526 7161
 F: +1 805 526 7270
www.alsglobal.com

ALS Environmental – Simi Valley

CERTIFICATIONS, ACCREDITATIONS, AND REGISTRATIONS

Agency	Web Site	Number
Arizona DHS	http://www.azdhs.gov/lab/license/env.htm	AZ0694
PJLA (DoD ELAP)	http://www.pjlabs.com/search-accredited-labs	65818 (Testing)
Florida DOH (NELAP)	http://www.doh.state.fl.us/lab/EnvLabCert/WaterCert.htm	E871020
Maine DHHS	http://www.maine.gov/dhhs/mecdc/environmental-health/water/dwp-services/labcert/labcert.htm	2016036
Minnesota DOH (NELAP)	http://www.health.state.mn.us/accreditation	977273
New Jersey DEP (NELAP)	http://www.nj.gov/dep/oqa/	CA009
New York DOH (NELAP)	http://www.wadsworth.org/labcert/elap/elap.html	11221
Oregon PHD (NELAP)	http://public.health.oregon.gov/LaboratoryServices/EnvironmentalLaboratoryAccreditation/Pages/index.aspx	4068-003
Pennsylvania DEP	http://www.depweb.state.pa.us/labs	68-03307 (Registration)
Texas CEQ (NELAP)	http://www.tceq.texas.gov/field/qa/env_lab_accreditation.html	T104704413- 16-7
Utah DOH (NELAP)	http://www.health.utah.gov/lab/labimp/certification/index.html	CA01627201 6-6
Washington DOE	http://www.ecy.wa.gov/programs/eap/labs/lab-accreditation.html	C946

Analyses were performed according to our laboratory's NELAP and DoD-ELAP approved quality assurance program. A complete listing of specific NELAP and DoD-ELAP certified analytes can be found in the certifications section at www.alsglobal.com, or at the accreditation body's website.

Each of the certifications listed above have an explicit Scope of Accreditation that applies to specific matrices/methods/analytes; therefore, please contact the laboratory for information corresponding to a particular certification.

ALS ENVIRONMENTAL

DETAIL SUMMARY REPORT

Client: A. Lanfranco and Associates Inc.
 Project ID: Cantimber

Service Request: P1605283

Date Received: 11/11/2016
 Time Received: 09:55

Client Sample ID	Lab Code	Matrix	Date Collected	Time Collected	Container ID	Pi1 (psig)	Pf1 (psig)	TO-15 - VOC Cans	3C Modified - Fxd Gases Can
Carbonization Stack Run-1	P1605283-001	Air	11/8/2016	12:56	SC01769	-1.80	3.54	X	
Carbonization Stack Run-2	P1605283-002	Air	11/8/2016	14:00	SC00282	-1.85	3.55	X	
Carbonization Stack Run-3	P1605283-003	Air	11/8/2016	15:07	SC00929	-2.44	3.53	X	
Activation Stack Run-1	P1605283-004	Air	11/9/2016	11:28	SC00403	-1.30	3.64	X	X
Activation Stack Run-2	P1605283-005	Air	11/9/2016	12:46	SC02019	-1.78	3.88	X	X
Activation Stack Run-3	P1605283-006	Air	11/9/2016	14:12	SC01693	-1.70	3.62	X	X



ALS ENVIRONMENTAL
Sample Volume Correction for Helium Pressurization
for SCAN Analysis

<u>Sample ID</u>	<u>Pi</u>	<u>Pf</u>	<u>Sample Volume (L)</u>	<u>Adjusted Volume (L)</u>
P1605283-004	-1.30	3.64	0.240	0.266
P1605283-005	-1.78	3.88	0.550	0.615
P1605283-006	-1.70	3.62	1.000	1.11

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-1
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-004

Test Code: EPA Method 3C Modified
 Instrument ID: HP5890 II/GC1/TCD
 Analyst: Adam McAfee
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC00403

Date Collected: 11/9/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.10 ml(s)

Initial Pressure (psig): -1.30 Final Pressure (psig): 3.64

Canister Dilution Factor: 1.37

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
1333-74-0	Hydrogen	0.743	0.14	
7782-44-7	Oxygen*	14.4	0.14	
7727-37-9	Nitrogen	77.3	0.14	
630-08-0	Carbon Monoxide	0.586	0.14	
74-82-8	Methane	ND	0.14	
124-38-9	Carbon Dioxide	7.00	0.14	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-2
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-005

Test Code: EPA Method 3C Modified
 Instrument ID: HP5890 II/GC1/TCD
 Analyst: Adam McAfee
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC02019

Date Collected: 11/9/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.10 ml(s)

Initial Pressure (psig): -1.78 Final Pressure (psig): 3.88

Canister Dilution Factor: 1.44

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
1333-74-0	Hydrogen	1.14	0.14	
7782-44-7	Oxygen*	14.1	0.14	
7727-37-9	Nitrogen	76.7	0.14	
630-08-0	Carbon Monoxide	0.854	0.14	
74-82-8	Methane	ND	0.14	
124-38-9	Carbon Dioxide	7.17	0.14	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-3
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-006

Test Code: EPA Method 3C Modified
 Instrument ID: HP5890 II/GC1/TCD
 Analyst: Adam McAfee
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC01693

Date Collected: 11/9/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.10 ml(s)

Initial Pressure (psig): -1.70 Final Pressure (psig): 3.62

Canister Dilution Factor: 1.41

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
1333-74-0	Hydrogen	1.75	0.14	
7782-44-7	Oxygen*	14.2	0.14	
7727-37-9	Nitrogen	75.9	0.14	
630-08-0	Carbon Monoxide	1.19	0.14	
74-82-8	Methane	ND	0.14	
124-38-9	Carbon Dioxide	6.99	0.14	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Method Blank
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P161115-MB

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Adam McAfee
Sample Type: 6.0 L Summa Canister
Test Notes:

Date Collected: NA
Date Received: NA
Date Analyzed: 11/15/16
Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
1333-74-0	Hydrogen	ND	0.10	
7782-44-7	Oxygen*	ND	0.10	
7727-37-9	Nitrogen	ND	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
74-82-8	Methane	ND	0.10	
124-38-9	Carbon Dioxide	ND	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

ALS ENVIRONMENTAL

LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Lab Control Sample
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P161115-LCS

Test Code: EPA Method 3C Modified
 Instrument ID: HP5890 II/GC1/TCD
 Analyst: Adam McAfee
 Sample Type: 6.0 L Summa Canister
 Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: NA ml(s)

CAS #	Compound	Spike Amount ppmV	Result ppmV	% Recovery	ALS	Data Qualifier
					Acceptance Limits	
1333-74-0	Hydrogen	50,000	50,400	101	94-105	
7782-44-7	Oxygen*	50,000	52,600	105	97-108	
7727-37-9	Nitrogen	50,000	52,800	106	89-113	
630-08-0	Carbon Monoxide	50,000	52,000	104	98-108	
74-82-8	Methane	50,000	50,200	100	94-111	
124-38-9	Carbon Dioxide	50,000	49,900	100	94-104	

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Carbonization Stack Run-1
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-001

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC01769

Date Collected: 11/8/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.10 Liter(s)

Initial Pressure (psig): -1.80 Final Pressure (psig): 3.54

Canister Dilution Factor: 1.41

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
115-07-1	Propene	64	7.1	37	4.1	
75-71-8	Dichlorodifluoromethane (CFC 12)	ND	7.1	ND	1.4	
74-87-3	Chloromethane	44	7.1	21	3.4	
76-14-2	1,2-Dichloro-1,1,2,2-tetrafluoroethane (CFC 114)	ND	7.1	ND	1.0	
75-01-4	Vinyl Chloride	ND	7.1	ND	2.8	
106-99-0	1,3-Butadiene	ND	7.1	ND	3.2	
74-83-9	Bromomethane	ND	7.1	ND	1.8	
75-00-3	Chloroethane	ND	7.1	ND	2.7	
64-17-5	Ethanol	ND	71	ND	37	
75-05-8	Acetonitrile	75	7.1	45	4.2	
107-02-8	Acrolein	170	28	74	12	
67-64-1	Acetone	1,200	71	530	30	
75-69-4	Trichlorofluoromethane	ND	7.1	ND	1.3	
67-63-0	2-Propanol (Isopropyl Alcohol)	ND	71	ND	29	
107-13-1	Acrylonitrile	12	7.1	5.7	3.2	
75-35-4	1,1-Dichloroethene	ND	7.1	ND	1.8	
75-09-2	Methylene Chloride	ND	7.1	ND	2.0	
107-05-1	3-Chloro-1-propene (Allyl Chloride)	ND	7.1	ND	2.3	
76-13-1	Trichlorotrifluoroethane	ND	7.1	ND	0.92	
75-15-0	Carbon Disulfide	ND	71	ND	23	
156-60-5	trans-1,2-Dichloroethene	ND	7.1	ND	1.8	
75-34-3	1,1-Dichloroethane	ND	7.1	ND	1.7	
1634-04-4	Methyl tert-Butyl Ether	ND	7.1	ND	2.0	
108-05-4	Vinyl Acetate	410	71	120	20	
78-93-3	2-Butanone (MEK)	240	71	81	24	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 2 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Carbonization Stack Run-1
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-001

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC01769

Date Collected: 11/8/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.10 Liter(s)

Initial Pressure (psig): -1.80 Final Pressure (psig): 3.54

Canister Dilution Factor: 1.41

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
156-59-2	cis-1,2-Dichloroethene	ND	7.1	ND	1.8	
141-78-6	Ethyl Acetate	ND	14	ND	3.9	
110-54-3	n-Hexane	7.1	7.1	2.0	2.0	
67-66-3	Chloroform	ND	7.1	ND	1.4	
109-99-9	Tetrahydrofuran (THF)	51	7.1	17	2.4	
107-06-2	1,2-Dichloroethane	ND	7.1	ND	1.7	
71-55-6	1,1,1-Trichloroethane	ND	7.1	ND	1.3	
71-43-2	Benzene	860	7.1	270	2.2	
56-23-5	Carbon Tetrachloride	ND	7.1	ND	1.1	
110-82-7	Cyclohexane	ND	14	ND	4.1	
78-87-5	1,2-Dichloropropane	ND	7.1	ND	1.5	
75-27-4	Bromodichloromethane	ND	7.1	ND	1.1	
79-01-6	Trichloroethene	ND	7.1	ND	1.3	
123-91-1	1,4-Dioxane	ND	7.1	ND	2.0	
80-62-6	Methyl Methacrylate	ND	14	ND	3.4	
142-82-5	n-Heptane	ND	7.1	ND	1.7	
10061-01-5	cis-1,3-Dichloropropene	ND	7.1	ND	1.6	
108-10-1	4-Methyl-2-pentanone	ND	7.1	ND	1.7	
10061-02-6	trans-1,3-Dichloropropene	ND	7.1	ND	1.6	
79-00-5	1,1,2-Trichloroethane	ND	7.1	ND	1.3	
108-88-3	Toluene	50	7.1	13	1.9	
591-78-6	2-Hexanone	ND	7.1	ND	1.7	
124-48-1	Dibromochloromethane	ND	7.1	ND	0.83	
106-93-4	1,2-Dibromoethane	ND	7.1	ND	0.92	
123-86-4	n-Butyl Acetate	ND	7.1	ND	1.5	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 3 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Carbonization Stack Run-1
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-001

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC01769

Date Collected: 11/8/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.10 Liter(s)

Initial Pressure (psig): -1.80 Final Pressure (psig): 3.54

Canister Dilution Factor: 1.41

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
111-65-9	n-Octane	ND	7.1	ND	1.5	
127-18-4	Tetrachloroethene	ND	7.1	ND	1.0	
108-90-7	Chlorobenzene	29	7.1	6.2	1.5	
100-41-4	Ethylbenzene	ND	7.1	ND	1.6	
179601-23-1	m,p-Xylenes	ND	14	ND	3.2	
75-25-2	Bromoform	ND	7.1	ND	0.68	
100-42-5	Styrene	7.1	7.1	1.7	1.7	
95-47-6	o-Xylene	ND	7.1	ND	1.6	
111-84-2	n-Nonane	ND	7.1	ND	1.3	
79-34-5	1,1,2,2-Tetrachloroethane	ND	7.1	ND	1.0	
98-82-8	Cumene	ND	7.1	ND	1.4	
80-56-8	alpha-Pinene	ND	7.1	ND	1.3	
103-65-1	n-Propylbenzene	ND	7.1	ND	1.4	
622-96-8	4-Ethyltoluene	ND	7.1	ND	1.4	
108-67-8	1,3,5-Trimethylbenzene	ND	7.1	ND	1.4	
95-63-6	1,2,4-Trimethylbenzene	ND	7.1	ND	1.4	
100-44-7	Benzyl Chloride	ND	7.1	ND	1.4	
541-73-1	1,3-Dichlorobenzene	ND	7.1	ND	1.2	
106-46-7	1,4-Dichlorobenzene	ND	7.1	ND	1.2	
95-50-1	1,2-Dichlorobenzene	ND	7.1	ND	1.2	
5989-27-5	d-Limonene	ND	7.1	ND	1.3	
96-12-8	1,2-Dibromo-3-chloropropane	ND	7.1	ND	0.73	
120-82-1	1,2,4-Trichlorobenzene	ND	7.1	ND	0.95	
91-20-3	Naphthalene	370	7.1	70	1.3	
87-68-3	Hexachlorobutadiene	ND	7.1	ND	0.66	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 3

Client: A. Lanfranco and Associates Inc.

Client Sample ID: Carbonization Stack Run-2

Client Project ID: Cantimber

ALS Project ID: P1605283

ALS Sample ID: P1605283-002

Test Code: EPA TO-15

Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9

Analyst: Simon Cao

Sample Type: 6.0 L Summa Canister

Test Notes:

Container ID: SC00282

Date Collected: 11/8/16

Date Received: 11/11/16

Date Analyzed: 11/15/16

Volume(s) Analyzed: 0.40 Liter(s)

Initial Pressure (psig): -1.85 Final Pressure (psig): 3.55

Canister Dilution Factor: 1.42

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
115-07-1	Propene	97	1.8	56	1.0	
75-71-8	Dichlorodifluoromethane (CFC 12)	ND	1.8	ND	0.36	
74-87-3	Chloromethane	37	1.8	18	0.86	
76-14-2	1,2-Dichloro-1,1,2,2-tetrafluoroethane (CFC 114)	ND	1.8	ND	0.25	
75-01-4	Vinyl Chloride	ND	1.8	ND	0.69	
106-99-0	1,3-Butadiene	ND	1.8	ND	0.80	
74-83-9	Bromomethane	3.1	1.8	0.79	0.46	
75-00-3	Chloroethane	ND	1.8	ND	0.67	
64-17-5	Ethanol	23	18	12	9.4	
75-05-8	Acetonitrile	60	1.8	36	1.1	
107-02-8	Acrolein	94	7.1	41	3.1	
67-64-1	Acetone	960	18	410	7.5	
75-69-4	Trichlorofluoromethane	ND	1.8	ND	0.32	
67-63-0	2-Propanol (Isopropyl Alcohol)	ND	18	ND	7.2	
107-13-1	Acrylonitrile	6.9	1.8	3.2	0.82	
75-35-4	1,1-Dichloroethene	ND	1.8	ND	0.45	
75-09-2	Methylene Chloride	ND	1.8	ND	0.51	
107-05-1	3-Chloro-1-propene (Allyl Chloride)	ND	1.8	ND	0.57	
76-13-1	Trichlorotrifluoroethane	ND	1.8	ND	0.23	
75-15-0	Carbon Disulfide	ND	18	ND	5.7	
156-60-5	trans-1,2-Dichloroethene	ND	1.8	ND	0.45	
75-34-3	1,1-Dichloroethane	ND	1.8	ND	0.44	
1634-04-4	Methyl tert-Butyl Ether	ND	1.8	ND	0.49	
108-05-4	Vinyl Acetate	450	18	130	5.0	
78-93-3	2-Butanone (MEK)	230	18	79	6.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 2 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Carbonization Stack Run-2
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-002

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC00282

Date Collected: 11/8/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.40 Liter(s)

Initial Pressure (psig): -1.85 Final Pressure (psig): 3.55

Canister Dilution Factor: 1.42

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
156-59-2	cis-1,2-Dichloroethene	ND	1.8	ND	0.45	
141-78-6	Ethyl Acetate	7.5	3.6	2.1	0.99	
110-54-3	n-Hexane	8.0	1.8	2.3	0.50	
67-66-3	Chloroform	2.0	1.8	0.42	0.36	
109-99-9	Tetrahydrofuran (THF)	43	1.8	15	0.60	
107-06-2	1,2-Dichloroethane	ND	1.8	ND	0.44	
71-55-6	1,1,1-Trichloroethane	ND	1.8	ND	0.33	
71-43-2	Benzene	300	1.8	95	0.56	
56-23-5	Carbon Tetrachloride	ND	1.8	ND	0.28	
110-82-7	Cyclohexane	ND	3.6	ND	1.0	
78-87-5	1,2-Dichloropropane	ND	1.8	ND	0.38	
75-27-4	Bromodichloromethane	ND	1.8	ND	0.27	
79-01-6	Trichloroethene	ND	1.8	ND	0.33	
123-91-1	1,4-Dioxane	ND	1.8	ND	0.49	
80-62-6	Methyl Methacrylate	ND	3.6	ND	0.87	
142-82-5	n-Heptane	2.0	1.8	0.49	0.43	
10061-01-5	cis-1,3-Dichloropropene	ND	1.8	ND	0.39	
108-10-1	4-Methyl-2-pentanone	2.9	1.8	0.70	0.43	
10061-02-6	trans-1,3-Dichloropropene	ND	1.8	ND	0.39	
79-00-5	1,1,2-Trichloroethane	ND	1.8	ND	0.33	
108-88-3	Toluene	57	1.8	15	0.47	
591-78-6	2-Hexanone	5.3	1.8	1.3	0.43	
124-48-1	Dibromochloromethane	ND	1.8	ND	0.21	
106-93-4	1,2-Dibromoethane	ND	1.8	ND	0.23	
123-86-4	n-Butyl Acetate	ND	1.8	ND	0.37	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 3 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Carbonization Stack Run-2
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-002

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC00282

Date Collected: 11/8/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.40 Liter(s)

Initial Pressure (psig): -1.85 Final Pressure (psig): 3.55

Canister Dilution Factor: 1.42

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
111-65-9	n-Octane	2.1	1.8	0.45	0.38	
127-18-4	Tetrachloroethene	ND	1.8	ND	0.26	
108-90-7	Chlorobenzene	30	1.8	6.6	0.39	
100-41-4	Ethylbenzene	9.2	1.8	2.1	0.41	
179601-23-1	m,p-Xylenes	20	3.6	4.6	0.82	
75-25-2	Bromoform	ND	1.8	ND	0.17	
100-42-5	Styrene	ND	1.8	ND	0.42	
95-47-6	o-Xylene	5.7	1.8	1.3	0.41	
111-84-2	n-Nonane	ND	1.8	ND	0.34	
79-34-5	1,1,2,2-Tetrachloroethane	ND	1.8	ND	0.26	
98-82-8	Cumene	ND	1.8	ND	0.36	
80-56-8	alpha-Pinene	ND	1.8	ND	0.32	
103-65-1	n-Propylbenzene	ND	1.8	ND	0.36	
622-96-8	4-Ethyltoluene	3.8	1.8	0.78	0.36	
108-67-8	1,3,5-Trimethylbenzene	2.6	1.8	0.53	0.36	
95-63-6	1,2,4-Trimethylbenzene	4.0	1.8	0.82	0.36	
100-44-7	Benzyl Chloride	ND	1.8	ND	0.34	
541-73-1	1,3-Dichlorobenzene	4.8	1.8	0.79	0.30	
106-46-7	1,4-Dichlorobenzene	2.1	1.8	0.35	0.30	
95-50-1	1,2-Dichlorobenzene	8.4	1.8	1.4	0.30	
5989-27-5	d-Limonene	ND	1.8	ND	0.32	
96-12-8	1,2-Dibromo-3-chloropropane	ND	1.8	ND	0.18	
120-82-1	1,2,4-Trichlorobenzene	2.7	1.8	0.36	0.24	
91-20-3	Naphthalene	130	1.8	26	0.34	
87-68-3	Hexachlorobutadiene	ND	1.8	ND	0.17	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Carbonization Stack Run-3
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-003

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC00929

Date Collected: 11/8/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.070 Liter(s)

Initial Pressure (psig): -2.44 Final Pressure (psig): 3.53

Canister Dilution Factor: 1.49

CAS #	Compound	Result	MRL	Result	MRL	Data Qualifier
		µg/m ³	µg/m ³	ppbV	ppbV	
115-07-1	Propene	56	11	32	6.2	
75-71-8	Dichlorodifluoromethane (CFC 12)	ND	11	ND	2.2	
74-87-3	Chloromethane	42	11	20	5.2	
76-14-2	1,2-Dichloro-1,1,2,2-tetrafluoroethane (CFC 114)	ND	11	ND	1.5	
75-01-4	Vinyl Chloride	ND	11	ND	4.2	
106-99-0	1,3-Butadiene	ND	11	ND	4.8	
74-83-9	Bromomethane	ND	11	ND	2.7	
75-00-3	Chloroethane	ND	11	ND	4.0	
64-17-5	Ethanol	ND	110	ND	57	
75-05-8	Acetonitrile	56	11	33	6.3	
107-02-8	Acrolein	94	43	41	19	
67-64-1	Acetone	1,000	110	420	45	
75-69-4	Trichlorofluoromethane	ND	11	ND	1.9	
67-63-0	2-Propanol (Isopropyl Alcohol)	ND	110	ND	43	
107-13-1	Acrylonitrile	ND	11	ND	4.9	
75-35-4	1,1-Dichloroethene	ND	11	ND	2.7	
75-09-2	Methylene Chloride	ND	11	ND	3.1	
107-05-1	3-Chloro-1-propene (Allyl Chloride)	ND	11	ND	3.4	
76-13-1	Trichlorotrifluoroethane	ND	11	ND	1.4	
75-15-0	Carbon Disulfide	ND	110	ND	34	
156-60-5	trans-1,2-Dichloroethene	ND	11	ND	2.7	
75-34-3	1,1-Dichloroethane	ND	11	ND	2.6	
1634-04-4	Methyl tert-Butyl Ether	ND	11	ND	3.0	
108-05-4	Vinyl Acetate	550	110	160	30	
78-93-3	2-Butanone (MEK)	200	110	69	36	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 2 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Carbonization Stack Run-3
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-003

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC00929

Date Collected: 11/8/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.070 Liter(s)

Initial Pressure (psig): -2.44 Final Pressure (psig): 3.53

Canister Dilution Factor: 1.49

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
156-59-2	cis-1,2-Dichloroethene	ND	11	ND	2.7	
141-78-6	Ethyl Acetate	ND	21	ND	5.9	
110-54-3	n-Hexane	ND	11	ND	3.0	
67-66-3	Chloroform	ND	11	ND	2.2	
109-99-9	Tetrahydrofuran (THF)	37	11	12	3.6	
107-06-2	1,2-Dichloroethane	ND	11	ND	2.6	
71-55-6	1,1,1-Trichloroethane	ND	11	ND	2.0	
71-43-2	Benzene	160	11	51	3.3	
56-23-5	Carbon Tetrachloride	ND	11	ND	1.7	
110-82-7	Cyclohexane	ND	21	ND	6.2	
78-87-5	1,2-Dichloropropane	ND	11	ND	2.3	
75-27-4	Bromodichloromethane	ND	11	ND	1.6	
79-01-6	Trichloroethene	ND	11	ND	2.0	
123-91-1	1,4-Dioxane	ND	11	ND	3.0	
80-62-6	Methyl Methacrylate	ND	21	ND	5.2	
142-82-5	n-Heptane	ND	11	ND	2.6	
10061-01-5	cis-1,3-Dichloropropene	ND	11	ND	2.3	
108-10-1	4-Methyl-2-pentanone	ND	11	ND	2.6	
10061-02-6	trans-1,3-Dichloropropene	ND	11	ND	2.3	
79-00-5	1,1,2-Trichloroethane	ND	11	ND	2.0	
108-88-3	Toluene	21	11	5.7	2.8	
591-78-6	2-Hexanone	ND	11	ND	2.6	
124-48-1	Dibromochloromethane	ND	11	ND	1.2	
106-93-4	1,2-Dibromoethane	ND	11	ND	1.4	
123-86-4	n-Butyl Acetate	ND	11	ND	2.2	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 3 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Carbonization Stack Run-3
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-003

Test Code: EPA TO-15
Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
Analyst: Simon Cao
Sample Type: 6.0 L Summa Canister
Test Notes:
Container ID: SC00929

Date Collected: 11/8/16
Date Received: 11/11/16
Date Analyzed: 11/15/16
Volume(s) Analyzed: 0.070 Liter(s)

Initial Pressure (psig): -2.44 Final Pressure (psig): 3.53

Canister Dilution Factor: 1.49

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
111-65-9	n-Octane	ND	11	ND	2.3	
127-18-4	Tetrachloroethene	ND	11	ND	1.6	
108-90-7	Chlorobenzene	23	11	4.9	2.3	
100-41-4	Ethylbenzene	ND	11	ND	2.5	
179601-23-1	m,p-Xylenes	ND	21	ND	4.9	
75-25-2	Bromoform	ND	11	ND	1.0	
100-42-5	Styrene	ND	11	ND	2.5	
95-47-6	o-Xylene	ND	11	ND	2.5	
111-84-2	n-Nonane	ND	11	ND	2.0	
79-34-5	1,1,2,2-Tetrachloroethane	ND	11	ND	1.6	
98-82-8	Cumene	ND	11	ND	2.2	
80-56-8	alpha-Pinene	ND	11	ND	1.9	
103-65-1	n-Propylbenzene	ND	11	ND	2.2	
622-96-8	4-Ethyltoluene	ND	11	ND	2.2	
108-67-8	1,3,5-Trimethylbenzene	ND	11	ND	2.2	
95-63-6	1,2,4-Trimethylbenzene	ND	11	ND	2.2	
100-44-7	Benzyl Chloride	ND	11	ND	2.1	
541-73-1	1,3-Dichlorobenzene	ND	11	ND	1.8	
106-46-7	1,4-Dichlorobenzene	ND	11	ND	1.8	
95-50-1	1,2-Dichlorobenzene	ND	11	ND	1.8	
5989-27-5	d-Limonene	ND	11	ND	1.9	
96-12-8	1,2-Dibromo-3-chloropropane	ND	11	ND	1.1	
120-82-1	1,2,4-Trichlorobenzene	ND	11	ND	1.4	
91-20-3	Naphthalene	95	11	18	2.0	
87-68-3	Hexachlorobutadiene	ND	11	ND	1.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-1
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-004

Test Code: EPA TO-15 Modified
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC00403

Date Collected: 11/9/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.266 Liter(s)

Initial Pressure (psig): -1.30 Final Pressure (psig): 3.64

Canister Dilution Factor: 1.37

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
115-07-1	Propene	ND	2.6	ND	1.5	
75-71-8	Dichlorodifluoromethane (CFC 12)	ND	2.6	ND	0.52	
74-87-3	Chloromethane	ND	2.6	ND	1.2	
76-14-2	1,2-Dichloro-1,1,2,2-tetrafluoroethane (CFC 114)	ND	2.6	ND	0.37	
75-01-4	Vinyl Chloride	ND	2.6	ND	1.0	
106-99-0	1,3-Butadiene	ND	2.6	ND	1.2	
74-83-9	Bromomethane	ND	2.6	ND	0.66	
75-00-3	Chloroethane	ND	2.6	ND	0.98	
64-17-5	Ethanol	ND	26	ND	14	
75-05-8	Acetonitrile	15	2.6	8.9	1.5	
107-02-8	Acrolein	12	10	5.4	4.5	
67-64-1	Acetone	250	26	110	11	
75-69-4	Trichlorofluoromethane	ND	2.6	ND	0.46	
67-63-0	2-Propanol (Isopropyl Alcohol)	ND	26	ND	10	
107-13-1	Acrylonitrile	ND	2.6	ND	1.2	
75-35-4	1,1-Dichloroethene	ND	2.6	ND	0.65	
75-09-2	Methylene Chloride	ND	2.6	ND	0.74	
107-05-1	3-Chloro-1-propene (Allyl Chloride)	ND	2.6	ND	0.82	
76-13-1	Trichlorotrifluoroethane	ND	2.6	ND	0.34	
75-15-0	Carbon Disulfide	ND	26	ND	8.3	
156-60-5	trans-1,2-Dichloroethene	ND	2.6	ND	0.65	
75-34-3	1,1-Dichloroethane	ND	2.6	ND	0.64	
1634-04-4	Methyl tert-Butyl Ether	ND	2.6	ND	0.71	
108-05-4	Vinyl Acetate	110	26	32	7.3	
78-93-3	2-Butanone (MEK)	37	26	12	8.7	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 2 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-1
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-004

Test Code: EPA TO-15 Modified
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC00403

Date Collected: 11/9/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.266 Liter(s)

Initial Pressure (psig): -1.30 Final Pressure (psig): 3.64

Canister Dilution Factor: 1.37

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
156-59-2	cis-1,2-Dichloroethene	ND	2.6	ND	0.65	
141-78-6	Ethyl Acetate	ND	5.2	ND	1.4	
110-54-3	n-Hexane	8.8	2.6	2.5	0.73	
67-66-3	Chloroform	ND	2.6	ND	0.53	
109-99-9	Tetrahydrofuran (THF)	5.1	2.6	1.7	0.87	
107-06-2	1,2-Dichloroethane	ND	2.6	ND	0.64	
71-55-6	1,1,1-Trichloroethane	ND	2.6	ND	0.47	
71-43-2	Benzene	100	2.6	32	0.81	
56-23-5	Carbon Tetrachloride	ND	2.6	ND	0.41	
110-82-7	Cyclohexane	ND	5.2	ND	1.5	
78-87-5	1,2-Dichloropropane	ND	2.6	ND	0.56	
75-27-4	Bromodichloromethane	ND	2.6	ND	0.38	
79-01-6	Trichloroethene	3.8	2.6	0.72	0.48	
123-91-1	1,4-Dioxane	ND	2.6	ND	0.71	
80-62-6	Methyl Methacrylate	ND	5.2	ND	1.3	
142-82-5	n-Heptane	ND	2.6	ND	0.63	
10061-01-5	cis-1,3-Dichloropropene	ND	2.6	ND	0.57	
108-10-1	4-Methyl-2-pentanone	ND	2.6	ND	0.63	
10061-02-6	trans-1,3-Dichloropropene	ND	2.6	ND	0.57	
79-00-5	1,1,2-Trichloroethane	ND	2.6	ND	0.47	
108-88-3	Toluene	41	2.6	11	0.68	
591-78-6	2-Hexanone	ND	2.6	ND	0.63	
124-48-1	Dibromochloromethane	ND	2.6	ND	0.30	
106-93-4	1,2-Dibromoethane	ND	2.6	ND	0.34	
123-86-4	n-Butyl Acetate	ND	2.6	ND	0.54	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 3 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-1
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-004

Test Code: EPA TO-15 Modified
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC00403

Date Collected: 11/9/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.266 Liter(s)

Initial Pressure (psig): -1.30 Final Pressure (psig): 3.64

Canister Dilution Factor: 1.37

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
111-65-9	n-Octane	ND	2.6	ND	0.55	
127-18-4	Tetrachloroethene	ND	2.6	ND	0.38	
108-90-7	Chlorobenzene	ND	2.6	ND	0.56	
100-41-4	Ethylbenzene	ND	2.6	ND	0.59	
179601-23-1	m,p-Xylenes	ND	5.2	ND	1.2	
75-25-2	Bromoform	ND	2.6	ND	0.25	
100-42-5	Styrene	ND	2.6	ND	0.61	
95-47-6	o-Xylene	ND	2.6	ND	0.59	
111-84-2	n-Nonane	ND	2.6	ND	0.49	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.6	ND	0.38	
98-82-8	Cumene	ND	2.6	ND	0.52	
80-56-8	alpha-Pinene	ND	2.6	ND	0.46	
103-65-1	n-Propylbenzene	ND	2.6	ND	0.52	
622-96-8	4-Ethyltoluene	ND	2.6	ND	0.52	
108-67-8	1,3,5-Trimethylbenzene	ND	2.6	ND	0.52	
95-63-6	1,2,4-Trimethylbenzene	ND	2.6	ND	0.52	
100-44-7	Benzyl Chloride	ND	2.6	ND	0.50	
541-73-1	1,3-Dichlorobenzene	ND	2.6	ND	0.43	
106-46-7	1,4-Dichlorobenzene	ND	2.6	ND	0.43	
95-50-1	1,2-Dichlorobenzene	ND	2.6	ND	0.43	
5989-27-5	d-Limonene	ND	2.6	ND	0.46	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.6	ND	0.27	
120-82-1	1,2,4-Trichlorobenzene	ND	2.6	ND	0.35	
91-20-3	Naphthalene	9.6	2.6	1.8	0.49	
87-68-3	Hexachlorobutadiene	ND	2.6	ND	0.24	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-2
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-005

Test Code: EPA TO-15 Modified
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC02019

Date Collected: 11/9/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.615 Liter(s)

Initial Pressure (psig): -1.78 Final Pressure (psig): 3.88

Canister Dilution Factor: 1.44

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
115-07-1	Propene	ND	1.2	ND	0.68	
75-71-8	Dichlorodifluoromethane (CFC 12)	1.4	1.2	0.29	0.24	
74-87-3	Chloromethane	ND	1.2	ND	0.57	
76-14-2	1,2-Dichloro-1,1,2,2-tetrafluoroethane (CFC 114)	ND	1.2	ND	0.17	
75-01-4	Vinyl Chloride	ND	1.2	ND	0.46	
106-99-0	1,3-Butadiene	ND	1.2	ND	0.53	
74-83-9	Bromomethane	ND	1.2	ND	0.30	
75-00-3	Chloroethane	ND	1.2	ND	0.44	
64-17-5	Ethanol	ND	12	ND	6.2	
75-05-8	Acetonitrile	12	1.2	6.9	0.70	
107-02-8	Acrolein	ND	4.7	ND	2.0	
67-64-1	Acetone	120	12	52	4.9	
75-69-4	Trichlorofluoromethane	ND	1.2	ND	0.21	
67-63-0	2-Propanol (Isopropyl Alcohol)	ND	12	ND	4.8	
107-13-1	Acrylonitrile	ND	1.2	ND	0.54	
75-35-4	1,1-Dichloroethene	ND	1.2	ND	0.30	
75-09-2	Methylene Chloride	ND	1.2	ND	0.34	
107-05-1	3-Chloro-1-propene (Allyl Chloride)	ND	1.2	ND	0.37	
76-13-1	Trichlorotrifluoroethane	ND	1.2	ND	0.15	
75-15-0	Carbon Disulfide	ND	12	ND	3.8	
156-60-5	trans-1,2-Dichloroethene	ND	1.2	ND	0.30	
75-34-3	1,1-Dichloroethane	ND	1.2	ND	0.29	
1634-04-4	Methyl tert-Butyl Ether	ND	1.2	ND	0.32	
108-05-4	Vinyl Acetate	97	12	28	3.3	
78-93-3	2-Butanone (MEK)	22	12	7.4	4.0	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 2 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-2
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-005

Test Code: EPA TO-15 Modified
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC02019

Date Collected: 11/9/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.615 Liter(s)

Initial Pressure (psig): -1.78 Final Pressure (psig): 3.88

Canister Dilution Factor: 1.44

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
156-59-2	cis-1,2-Dichloroethene	ND	1.2	ND	0.30	
141-78-6	Ethyl Acetate	ND	2.3	ND	0.65	
110-54-3	n-Hexane	8.2	1.2	2.3	0.33	
67-66-3	Chloroform	ND	1.2	ND	0.24	
109-99-9	Tetrahydrofuran (THF)	2.6	1.2	0.87	0.40	
107-06-2	1,2-Dichloroethane	ND	1.2	ND	0.29	
71-55-6	1,1,1-Trichloroethane	ND	1.2	ND	0.21	
71-43-2	Benzene	73	1.2	23	0.37	
56-23-5	Carbon Tetrachloride	ND	1.2	ND	0.19	
110-82-7	Cyclohexane	ND	2.3	ND	0.68	
78-87-5	1,2-Dichloropropane	ND	1.2	ND	0.25	
75-27-4	Bromodichloromethane	ND	1.2	ND	0.17	
79-01-6	Trichloroethene	ND	1.2	ND	0.22	
123-91-1	1,4-Dioxane	ND	1.2	ND	0.33	
80-62-6	Methyl Methacrylate	ND	2.3	ND	0.57	
142-82-5	n-Heptane	ND	1.2	ND	0.29	
10061-01-5	cis-1,3-Dichloropropene	ND	1.2	ND	0.26	
108-10-1	4-Methyl-2-pentanone	ND	1.2	ND	0.29	
10061-02-6	trans-1,3-Dichloropropene	ND	1.2	ND	0.26	
79-00-5	1,1,2-Trichloroethane	ND	1.2	ND	0.21	
108-88-3	Toluene	15	1.2	4.1	0.31	
591-78-6	2-Hexanone	ND	1.2	ND	0.29	
124-48-1	Dibromochloromethane	ND	1.2	ND	0.14	
106-93-4	1,2-Dibromoethane	ND	1.2	ND	0.15	
123-86-4	n-Butyl Acetate	ND	1.2	ND	0.25	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 3 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-2
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-005

Test Code: EPA TO-15 Modified
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC02019

Date Collected: 11/9/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.615 Liter(s)

Initial Pressure (psig): -1.78 Final Pressure (psig): 3.88

Canister Dilution Factor: 1.44

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
111-65-9	n-Octane	ND	1.2	ND	0.25	
127-18-4	Tetrachloroethene	ND	1.2	ND	0.17	
108-90-7	Chlorobenzene	ND	1.2	ND	0.25	
100-41-4	Ethylbenzene	ND	1.2	ND	0.27	
179601-23-1	m,p-Xylenes	ND	2.3	ND	0.54	
75-25-2	Bromoform	ND	1.2	ND	0.11	
100-42-5	Styrene	ND	1.2	ND	0.28	
95-47-6	o-Xylene	ND	1.2	ND	0.27	
111-84-2	n-Nonane	ND	1.2	ND	0.22	
79-34-5	1,1,2,2-Tetrachloroethane	ND	1.2	ND	0.17	
98-82-8	Cumene	ND	1.2	ND	0.24	
80-56-8	alpha-Pinene	ND	1.2	ND	0.21	
103-65-1	n-Propylbenzene	ND	1.2	ND	0.24	
622-96-8	4-Ethyltoluene	ND	1.2	ND	0.24	
108-67-8	1,3,5-Trimethylbenzene	ND	1.2	ND	0.24	
95-63-6	1,2,4-Trimethylbenzene	ND	1.2	ND	0.24	
100-44-7	Benzyl Chloride	ND	1.2	ND	0.23	
541-73-1	1,3-Dichlorobenzene	ND	1.2	ND	0.19	
106-46-7	1,4-Dichlorobenzene	ND	1.2	ND	0.19	
95-50-1	1,2-Dichlorobenzene	ND	1.2	ND	0.19	
5989-27-5	d-Limonene	ND	1.2	ND	0.21	
96-12-8	1,2-Dibromo-3-chloropropane	ND	1.2	ND	0.12	
120-82-1	1,2,4-Trichlorobenzene	ND	1.2	ND	0.16	
91-20-3	Naphthalene	8.8	1.2	1.7	0.22	
87-68-3	Hexachlorobutadiene	ND	1.2	ND	0.11	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-3
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-006

Test Code: EPA TO-15 Modified
Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
Analyst: Simon Cao
Sample Type: 6.0 L Summa Canister
Test Notes:
Container ID: SC01693

Date Collected: 11/9/16
Date Received: 11/11/16
Date Analyzed: 11/15/16
Volume(s) Analyzed: 1.11 Liter(s)

Initial Pressure (psig): -1.70 Final Pressure (psig): 3.62

Canister Dilution Factor: 1.41

CAS #	Compound	Result	MRL	Result	MRL	Data Qualifier
		µg/m ³	µg/m ³	ppbV	ppbV	
115-07-1	Propene	2.0	0.64	1.2	0.37	
75-71-8	Dichlorodifluoromethane (CFC 12)	1.4	0.64	0.29	0.13	
74-87-3	Chloromethane	ND	0.64	ND	0.31	
76-14-2	1,2-Dichloro-1,1,2,2-tetrafluoroethane (CFC 114)	ND	0.64	ND	0.091	
75-01-4	Vinyl Chloride	ND	0.64	ND	0.25	
106-99-0	1,3-Butadiene	ND	0.64	ND	0.29	
74-83-9	Bromomethane	ND	0.64	ND	0.16	
75-00-3	Chloroethane	ND	0.64	ND	0.24	
64-17-5	Ethanol	ND	6.4	ND	3.4	
75-05-8	Acetonitrile	7.8	0.64	4.7	0.38	
107-02-8	Acrolein	ND	2.5	ND	1.1	
67-64-1	Acetone	48	6.4	20	2.7	
75-69-4	Trichlorofluoromethane	0.73	0.64	0.13	0.11	
67-63-0	2-Propanol (Isopropyl Alcohol)	ND	6.4	ND	2.6	
107-13-1	Acrylonitrile	ND	0.64	ND	0.29	
75-35-4	1,1-Dichloroethene	ND	0.64	ND	0.16	
75-09-2	Methylene Chloride	ND	0.64	ND	0.18	
107-05-1	3-Chloro-1-propene (Allyl Chloride)	ND	0.64	ND	0.20	
76-13-1	Trichlorotrifluoroethane	ND	0.64	ND	0.083	
75-15-0	Carbon Disulfide	8.0	6.4	2.6	2.0	
156-60-5	trans-1,2-Dichloroethene	ND	0.64	ND	0.16	
75-34-3	1,1-Dichloroethane	ND	0.64	ND	0.16	
1634-04-4	Methyl tert-Butyl Ether	ND	0.64	ND	0.18	
108-05-4	Vinyl Acetate	55	6.4	15	1.8	
78-93-3	2-Butanone (MEK)	9.6	6.4	3.3	2.2	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 2 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-3
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-006

Test Code: EPA TO-15 Modified
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC01693

Date Collected: 11/9/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 1.11 Liter(s)

Initial Pressure (psig): -1.70 Final Pressure (psig): 3.62

Canister Dilution Factor: 1.41

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
156-59-2	cis-1,2-Dichloroethene	ND	0.64	ND	0.16	
141-78-6	Ethyl Acetate	ND	1.3	ND	0.35	
110-54-3	n-Hexane	4.5	0.64	1.3	0.18	
67-66-3	Chloroform	ND	0.64	ND	0.13	
109-99-9	Tetrahydrofuran (THF)	0.72	0.64	0.24	0.22	
107-06-2	1,2-Dichloroethane	ND	0.64	ND	0.16	
71-55-6	1,1,1-Trichloroethane	ND	0.64	ND	0.12	
71-43-2	Benzene	56	0.64	17	0.20	
56-23-5	Carbon Tetrachloride	ND	0.64	ND	0.10	
110-82-7	Cyclohexane	ND	1.3	ND	0.37	
78-87-5	1,2-Dichloropropane	ND	0.64	ND	0.14	
75-27-4	Bromodichloromethane	ND	0.64	ND	0.095	
79-01-6	Trichloroethene	ND	0.64	ND	0.12	
123-91-1	1,4-Dioxane	ND	0.64	ND	0.18	
80-62-6	Methyl Methacrylate	ND	1.3	ND	0.31	
142-82-5	n-Heptane	ND	0.64	ND	0.16	
10061-01-5	cis-1,3-Dichloropropene	ND	0.64	ND	0.14	
108-10-1	4-Methyl-2-pentanone	ND	0.64	ND	0.16	
10061-02-6	trans-1,3-Dichloropropene	ND	0.64	ND	0.14	
79-00-5	1,1,2-Trichloroethane	ND	0.64	ND	0.12	
108-88-3	Toluene	13	0.64	3.6	0.17	
591-78-6	2-Hexanone	ND	0.64	ND	0.16	
124-48-1	Dibromochloromethane	ND	0.64	ND	0.075	
106-93-4	1,2-Dibromoethane	ND	0.64	ND	0.083	
123-86-4	n-Butyl Acetate	ND	0.64	ND	0.13	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 3 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Activation Stack Run-3
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P1605283-006

Test Code: EPA TO-15 Modified
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:
 Container ID: SC01693

Date Collected: 11/9/16
 Date Received: 11/11/16
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 1.11 Liter(s)

Initial Pressure (psig): -1.70 Final Pressure (psig): 3.62

Canister Dilution Factor: 1.41

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
111-65-9	n-Octane	0.78	0.64	0.17	0.14	
127-18-4	Tetrachloroethene	ND	0.64	ND	0.094	
108-90-7	Chlorobenzene	ND	0.64	ND	0.14	
100-41-4	Ethylbenzene	ND	0.64	ND	0.15	
179601-23-1	m,p-Xylenes	1.4	1.3	0.33	0.29	
75-25-2	Bromoform	ND	0.64	ND	0.061	
100-42-5	Styrene	ND	0.64	ND	0.15	
95-47-6	o-Xylene	ND	0.64	ND	0.15	
111-84-2	n-Nonane	ND	0.64	ND	0.12	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.64	ND	0.093	
98-82-8	Cumene	ND	0.64	ND	0.13	
80-56-8	alpha-Pinene	ND	0.64	ND	0.11	
103-65-1	n-Propylbenzene	ND	0.64	ND	0.13	
622-96-8	4-Ethyltoluene	ND	0.64	ND	0.13	
108-67-8	1,3,5-Trimethylbenzene	ND	0.64	ND	0.13	
95-63-6	1,2,4-Trimethylbenzene	ND	0.64	ND	0.13	
100-44-7	Benzyl Chloride	ND	0.64	ND	0.12	
541-73-1	1,3-Dichlorobenzene	ND	0.64	ND	0.11	
106-46-7	1,4-Dichlorobenzene	ND	0.64	ND	0.11	
95-50-1	1,2-Dichlorobenzene	ND	0.64	ND	0.11	
5989-27-5	d-Limonene	ND	0.64	ND	0.11	
96-12-8	1,2-Dibromo-3-chloropropane	ND	0.64	ND	0.066	
120-82-1	1,2,4-Trichlorobenzene	ND	0.64	ND	0.086	
91-20-3	Naphthalene	6.1	0.64	1.2	0.12	
87-68-3	Hexachlorobutadiene	ND	0.64	ND	0.060	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Method Blank
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P161115-MB

Test Code: EPA TO-15
Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
Analyst: Simon Cao
Sample Type: 6.0 L Summa Canister
Test Notes:

Date Collected: NA
Date Received: NA
Date Analyzed: 11/15/16
Volume(s) Analyzed: 1.00 Liter(s)

Canister Dilution Factor: 1.00

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
115-07-1	Propene	ND	0.50	ND	0.29	
75-71-8	Dichlorodifluoromethane (CFC 12)	ND	0.50	ND	0.10	
74-87-3	Chloromethane	ND	0.50	ND	0.24	
76-14-2	1,2-Dichloro-1,1,2,2-tetrafluoroethane (CFC 114)	ND	0.50	ND	0.072	
75-01-4	Vinyl Chloride	ND	0.50	ND	0.20	
106-99-0	1,3-Butadiene	ND	0.50	ND	0.23	
74-83-9	Bromomethane	ND	0.50	ND	0.13	
75-00-3	Chloroethane	ND	0.50	ND	0.19	
64-17-5	Ethanol	ND	5.0	ND	2.7	
75-05-8	Acetonitrile	ND	0.50	ND	0.30	
107-02-8	Acrolein	ND	2.0	ND	0.87	
67-64-1	Acetone	ND	5.0	ND	2.1	
75-69-4	Trichlorofluoromethane	ND	0.50	ND	0.089	
67-63-0	2-Propanol (Isopropyl Alcohol)	ND	5.0	ND	2.0	
107-13-1	Acrylonitrile	ND	0.50	ND	0.23	
75-35-4	1,1-Dichloroethene	ND	0.50	ND	0.13	
75-09-2	Methylene Chloride	ND	0.50	ND	0.14	
107-05-1	3-Chloro-1-propene (Allyl Chloride)	ND	0.50	ND	0.16	
76-13-1	Trichlorotrifluoroethane	ND	0.50	ND	0.065	
75-15-0	Carbon Disulfide	ND	5.0	ND	1.6	
156-60-5	trans-1,2-Dichloroethene	ND	0.50	ND	0.13	
75-34-3	1,1-Dichloroethane	ND	0.50	ND	0.12	
1634-04-4	Methyl tert-Butyl Ether	ND	0.50	ND	0.14	
108-05-4	Vinyl Acetate	ND	5.0	ND	1.4	
78-93-3	2-Butanone (MEK)	ND	5.0	ND	1.7	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 2 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Method Blank
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P161115-MB

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 1.00 Liter(s)

Canister Dilution Factor: 1.00

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
156-59-2	cis-1,2-Dichloroethene	ND	0.50	ND	0.13	
141-78-6	Ethyl Acetate	ND	1.0	ND	0.28	
110-54-3	n-Hexane	ND	0.50	ND	0.14	
67-66-3	Chloroform	ND	0.50	ND	0.10	
109-99-9	Tetrahydrofuran (THF)	ND	0.50	ND	0.17	
107-06-2	1,2-Dichloroethane	ND	0.50	ND	0.12	
71-55-6	1,1,1-Trichloroethane	ND	0.50	ND	0.092	
71-43-2	Benzene	ND	0.50	ND	0.16	
56-23-5	Carbon Tetrachloride	ND	0.50	ND	0.080	
110-82-7	Cyclohexane	ND	1.0	ND	0.29	
78-87-5	1,2-Dichloropropane	ND	0.50	ND	0.11	
75-27-4	Bromodichloromethane	ND	0.50	ND	0.075	
79-01-6	Trichloroethene	ND	0.50	ND	0.093	
123-91-1	1,4-Dioxane	ND	0.50	ND	0.14	
80-62-6	Methyl Methacrylate	ND	1.0	ND	0.24	
142-82-5	n-Heptane	ND	0.50	ND	0.12	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	ND	0.11	
108-10-1	4-Methyl-2-pentanone	ND	0.50	ND	0.12	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	ND	0.11	
79-00-5	1,1,2-Trichloroethane	ND	0.50	ND	0.092	
108-88-3	Toluene	ND	0.50	ND	0.13	
591-78-6	2-Hexanone	ND	0.50	ND	0.12	
124-48-1	Dibromochloromethane	ND	0.50	ND	0.059	
106-93-4	1,2-Dibromoethane	ND	0.50	ND	0.065	
123-86-4	n-Butyl Acetate	ND	0.50	ND	0.11	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 3 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Method Blank
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P161115-MB

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 1.00 Liter(s)

Canister Dilution Factor: 1.00

CAS #	Compound	Result µg/m ³	MRL µg/m ³	Result ppbV	MRL ppbV	Data Qualifier
111-65-9	n-Octane	ND	0.50	ND	0.11	
127-18-4	Tetrachloroethene	ND	0.50	ND	0.074	
108-90-7	Chlorobenzene	ND	0.50	ND	0.11	
100-41-4	Ethylbenzene	ND	0.50	ND	0.12	
179601-23-1	m,p-Xylenes	ND	1.0	ND	0.23	
75-25-2	Bromoform	ND	0.50	ND	0.048	
100-42-5	Styrene	ND	0.50	ND	0.12	
95-47-6	o-Xylene	ND	0.50	ND	0.12	
111-84-2	n-Nonane	ND	0.50	ND	0.095	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	ND	0.073	
98-82-8	Cumene	ND	0.50	ND	0.10	
80-56-8	alpha-Pinene	ND	0.50	ND	0.090	
103-65-1	n-Propylbenzene	ND	0.50	ND	0.10	
622-96-8	4-Ethyltoluene	ND	0.50	ND	0.10	
108-67-8	1,3,5-Trimethylbenzene	ND	0.50	ND	0.10	
95-63-6	1,2,4-Trimethylbenzene	ND	0.50	ND	0.10	
100-44-7	Benzyl Chloride	ND	0.50	ND	0.097	
541-73-1	1,3-Dichlorobenzene	ND	0.50	ND	0.083	
106-46-7	1,4-Dichlorobenzene	ND	0.50	ND	0.083	
95-50-1	1,2-Dichlorobenzene	ND	0.50	ND	0.083	
5989-27-5	d-Limonene	ND	0.50	ND	0.090	
96-12-8	1,2-Dibromo-3-chloropropane	ND	0.50	ND	0.052	
120-82-1	1,2,4-Trichlorobenzene	ND	0.50	ND	0.067	
91-20-3	Naphthalene	ND	0.50	ND	0.095	
87-68-3	Hexachlorobutadiene	ND	0.50	ND	0.047	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

SURROGATE SPIKE RECOVERY RESULTS

Page 1 of 1

Client: A. Lanfranco and Associates Inc.
Client Project ID: Cantimber

ALS Project ID: P1605283

Test Code: EPA TO-15 / EPA TO-15 Modified
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister(s)
 Test Notes:

Date(s) Collected: 11/8 - 11/9/16
 Date(s) Received: 11/11/16
 Date(s) Analyzed: 11/15/16

Client Sample ID	ALS Sample ID	1,2-Dichloroethane-d4	Toluene-d8	Bromofluorobenzene	Acceptance Limits	Data Qualifier
		Percent Recovered	Percent Recovered	Percent Recovered		
Method Blank	P161115-MB	103	100	96	70-130	
Lab Control Sample	P161115-LCS	101	99	98	70-130	
Carbonization Stack Run-1	P1605283-001	102	96	98	70-130	
Carbonization Stack Run-2	P1605283-002	103	98	100	70-130	
Carbonization Stack Run-3	P1605283-003	102	97	97	70-130	
Activation Stack Run-1	P1605283-004	102	96	98	70-130	
Activation Stack Run-2	P1605283-005	105	96	98	70-130	
Activation Stack Run-3	P1605283-006	106	98	100	70-130	

Surrogate percent recovery is verified and accepted based on the on-column result.

Reported results are shown in concentration units and as a result of the calculation, may vary slightly from the on-column percent recovery.

ALS ENVIRONMENTAL

LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Lab Control Sample
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P161115-LCS

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.125 Liter(s)

CAS #	Compound	Spike Amount µg/m ³	Result µg/m ³	% Recovery	ALS	Data Qualifier
					Acceptance Limits	
115-07-1	Propene	210	205	98	52-127	
75-71-8	Dichlorodifluoromethane (CFC 12)	210	203	97	68-109	
74-87-3	Chloromethane	210	209	100	51-130	
76-14-2	1,2-Dichloro-1,1,2,2-tetrafluoroethane (CFC 114)	211	195	92	66-114	
75-01-4	Vinyl Chloride	210	194	92	61-125	
106-99-0	1,3-Butadiene	210	210	100	62-144	
74-83-9	Bromomethane	210	210	100	73-123	
75-00-3	Chloroethane	210	214	102	69-122	
64-17-5	Ethanol	1,060	1140	108	62-124	
75-05-8	Acetonitrile	213	219	103	57-114	
107-02-8	Acrolein	212	206	97	62-116	
67-64-1	Acetone	1,060	1000	94	57-117	
75-69-4	Trichlorofluoromethane	210	200	95	63-98	
67-63-0	2-Propanol (Isopropyl Alcohol)	424	444	105	66-121	
107-13-1	Acrylonitrile	213	223	105	68-123	
75-35-4	1,1-Dichloroethene	213	206	97	76-118	
75-09-2	Methylene Chloride	212	199	94	60-118	
107-05-1	3-Chloro-1-propene (Allyl Chloride)	212	220	104	65-126	
76-13-1	Trichlorotrifluoroethane	212	208	98	73-114	
75-15-0	Carbon Disulfide	213	229	108	57-102	L
156-60-5	trans-1,2-Dichloroethene	213	215	101	74-123	
75-34-3	1,1-Dichloroethane	212	206	97	69-111	
1634-04-4	Methyl tert-Butyl Ether	213	207	97	69-113	
108-05-4	Vinyl Acetate	1,060	1050	99	76-128	
78-93-3	2-Butanone (MEK)	212	216	102	63-127	

Laboratory Control Sample percent recovery is verified and accepted based on the on-column result. Reported results are shown in concentration units and as a result of the calculation, may vary slightly. L = Laboratory control sample recovery outside the specified limits, results may be biased high.

ALS ENVIRONMENTAL

LABORATORY CONTROL SAMPLE SUMMARY

Page 2 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Lab Control Sample
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P161115-LCS

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.125 Liter(s)

CAS #	Compound	Spike Amount µg/m ³	Result µg/m ³	% Recovery	ALS Acceptance Limits	Data Qualifier
156-59-2	cis-1,2-Dichloroethene	212	212	100	72-117	
141-78-6	Ethyl Acetate	426	456	107	68-127	
110-54-3	n-Hexane	213	225	106	55-116	
67-66-3	Chloroform	212	208	98	70-109	
109-99-9	Tetrahydrofuran (THF)	213	207	97	72-113	
107-06-2	1,2-Dichloroethane	212	210	99	69-113	
71-55-6	1,1,1-Trichloroethane	212	200	94	72-115	
71-43-2	Benzene	212	197	93	65-107	
56-23-5	Carbon Tetrachloride	213	201	94	71-113	
110-82-7	Cyclohexane	425	415	98	71-115	
78-87-5	1,2-Dichloropropane	212	212	100	71-115	
75-27-4	Bromodichloromethane	214	211	99	75-118	
79-01-6	Trichloroethene	212	206	97	68-114	
123-91-1	1,4-Dioxane	213	218	102	81-131	
80-62-6	Methyl Methacrylate	424	440	104	72-130	
142-82-5	n-Heptane	213	209	98	68-116	
10061-01-5	cis-1,3-Dichloropropene	210	211	100	77-126	
108-10-1	4-Methyl-2-pentanone	213	218	102	69-126	
10061-02-6	trans-1,3-Dichloropropene	213	216	101	79-125	
79-00-5	1,1,2-Trichloroethane	212	208	98	75-119	
108-88-3	Toluene	212	199	94	59-118	
591-78-6	2-Hexanone	213	222	104	69-129	
124-48-1	Dibromochloromethane	213	210	99	74-136	
106-93-4	1,2-Dibromoethane	212	212	100	73-131	
123-86-4	n-Butyl Acetate	216	227	105	69-130	

Laboratory Control Sample percent recovery is verified and accepted based on the on-column result.
 Reported results are shown in concentration units and as a result of the calculation, may vary slightly.

ALS ENVIRONMENTAL

LABORATORY CONTROL SAMPLE SUMMARY

Page 3 of 3

Client: A. Lanfranco and Associates Inc.
Client Sample ID: Lab Control Sample
Client Project ID: Cantimber

ALS Project ID: P1605283
 ALS Sample ID: P161115-LCS

Test Code: EPA TO-15
 Instrument ID: Tekmar AUTOCAN/Agilent 5973inert/6890N/MS9
 Analyst: Simon Cao
 Sample Type: 6.0 L Summa Canister
 Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 11/15/16
 Volume(s) Analyzed: 0.125 Liter(s)

CAS #	Compound	Spike Amount µg/m ³	Result µg/m ³	% Recovery	ALS Acceptance Limits	Data Qualifier
111-65-9	n-Octane	212	221	104	66-120	
127-18-4	Tetrachloroethene	213	207	97	65-130	
108-90-7	Chlorobenzene	212	204	96	68-120	
100-41-4	Ethylbenzene	212	206	97	68-122	
179601-23-1	m,p-Xylenes	424	413	97	68-123	
75-25-2	Bromoform	212	214	101	69-130	
100-42-5	Styrene	212	214	101	71-133	
95-47-6	o-Xylene	212	207	98	68-122	
111-84-2	n-Nonane	212	212	100	65-120	
79-34-5	1,1,2,2-Tetrachloroethane	212	213	100	69-130	
98-82-8	Cumene	212	205	97	70-123	
80-56-8	alpha-Pinene	213	206	97	70-128	
103-65-1	n-Propylbenzene	214	210	98	69-125	
622-96-8	4-Ethyltoluene	212	217	102	67-130	
108-67-8	1,3,5-Trimethylbenzene	212	206	97	67-124	
95-63-6	1,2,4-Trimethylbenzene	212	211	100	67-129	
100-44-7	Benzyl Chloride	212	228	108	79-138	
541-73-1	1,3-Dichlorobenzene	212	215	101	65-136	
106-46-7	1,4-Dichlorobenzene	213	219	103	66-141	
95-50-1	1,2-Dichlorobenzene	212	216	102	67-136	
5989-27-5	d-Limonene	212	201	95	71-134	
96-12-8	1,2-Dibromo-3-chloropropane	212	231	109	73-136	
120-82-1	1,2,4-Trichlorobenzene	212	238	112	64-134	
91-20-3	Naphthalene	214	249	116	62-136	
87-68-3	Hexachlorobutadiene	213	220	103	60-133	

Laboratory Control Sample percent recovery is verified and accepted based on the on-column result.
 Reported results are shown in concentration units and as a result of the calculation, may vary slightly.

3300 Breckinridge Blvd
Suite 400
Duluth, GA 30096

770.662.8509
FAX 770.662.8532
www.mvainc.com

Stack Sample Analysis

PM10 & PM2.5 Custom
Particle Sizing

Particle Shape Analysis

Particulate Matter
Identification

Back-Half Catch Residue
Identification (M202)

Filter Debris Analysis

Ambient Air Sample
Characterization

Condensable Analysis

Litigation Support

Techniques

Light Microscopy

Scanning Electron
Microscopy

Transmission Electron
Microscopy

Fourier Transform
Infrared Spectroscopy

Confocal Raman Microscopy

White Light Interference
Microscopy

Energy Dispersive X-ray
Spectrometry

Fluorescence Microscopy

Ion Milling & Ultramicrotomy

Accreditations

cGMP Compliant

ISO/IEC 17025
A2LA Certificate #2096.01

FDA Registered

Report of Results: MVA11801

Particle Size Distribution Measurement

Prepared for:

**A. Lanfranco & Associates
9488 189 St., Suite 101
Surrey, BC V4W 4W7
Canada**

Respectfully Submitted by:



**EXECUTED BY
ELECTRONIC
SIGNATURE**

**Tim B. Vander Wood, Ph.D.
Executive Director**

5 December 2016

Report of Results: MVA11801

Particle Size Distribution Measurement

Introduction

This report includes the results of the requested particle size analysis to 0.5µm minimum diameter of two of four Method 5 filter samples received on 17 November 2016. We were asked to hold the remaining two samples. Upon receipt, the analyzed samples were assigned unique MVA Scientific Consultants laboratory identification numbers as shown in Table 1. Analyses were performed at MVA Scientific Consultants during the period of 18 November through 5 December 2016.

Methods

Samples were prepared for analysis in accordance with MVA SOP 310, "Sample Preparation Methods for Total Particle Sizing Using Microscopical Techniques."

The particle size distribution was measured in accordance with MVA SOP 318, "Manual Feature Sizing in Digital Images Using ImageJ" from digital images of the particles on the filters obtained using a JEOL JSM-6500F field emission scanning electron microscope. The particle size data are presented in terms of particle number and in terms of estimated mass. The assumption has been made that the particles are all of similar density and therefore the particle volume distribution is equivalent to the particle mass distribution.

Results

The size distributions of the particles down to 0.5 micrometer are shown in Tables 1 and 2. Sample AB1829 (Cantimber Run-2 Nov 9/16 Activation Stack) was very lightly loaded with particulate.

Table 1. MVA 11801. Percentages of Particles in Various Diameter Ranges by Number of Particles

MVA#	AB1829	AB1831
Client ID	Cantimber Run-2 Nov 9/16 Activation Stack	Cantimber Run-2 Nov 8/16 Carbonization Stack
Diameter Range (µm)	Number %	Number %
0.5-≤1.0	71.6	86.7
>1.0-≤2.5	25.5	12.3
>2.5-≤5.0	2.8	0.6
>5.0-≤7.5	0.0	0.2
>7.5-≤10.0	0.0	0.1
>10.0	0.0	0.1

Table 2. MVA 11801. Percentages of Particles in Various Diameter Ranges by Mass of Particles


MVA#	AB1829	AB1831
Client ID	Cantimber Run-2 Nov 9/16 Activation Stack	Cantimber Run-2 Nov 8/16 Carbonization Stack
Diameter Range (µm)	Mass %	Mass %
0.5-≤1.0	14.0	5.6
>1.0-≤2.5	48.7	11.6
>2.5-≤5.0	37.3	8.2
>5.0-≤7.5	0.0	13.1
>7.5-≤10.0	0.0	14.6
>10.0	0.0	46.9




CHAIN OF CUSTODY

Project No. or Identification Cantimber

Client Sample ID	MVA ID*	Comments / Analytical Requests
		report to mark.lanfranco@alanfranco.com
Activation Run 2	AB1829	
*Activation Run 3	AB1830	* Only to be run if Run 2 is compromised. Backup only.
Carbonization Run 2	AB1831	
*Carbonization Run 3	AB1832	* Only to be run if Run 2 is compromised. Backup only.
		To be clear we want 2 analysis only

Relinquished by (sign): 	Relinquished by (sign):
Via:	Via:
Date: Nov. 16 Printed Name: Mark Lanfranco	Date: Printed Name:
Company: A. Lanfranco and Associates	Company:

Received by (sign): 	Received by (sign):
Date: 11/17/16 Printed Name: Tim VanderWort	Date: Printed Name:
Company: MVA Scientific Consultants	Company:

APPENDIX 3
FIELD DATA SHEETS

NOTE: 4A1 Probe has Short probe temp on umbilical not working

ML

CLIENT	CANTIMBER		PROBE TIP DIAMETER, IN.	0.40 20		IMPINGER, INITIAL	FINAL		TOTAL GAIN				
RUN No	PART 1		PROBE LENGTH, FT / Cp	0.8450 0.8450		VOLUMES	(mL)		(mL)				
SOURCE	NORTH SCRUBBER - WEST		PORT LENGTH	4A2		Imp. #1	222		122				
DATE	NOV. 9, 2016		STATIC PRESSURE, IN. H2O	+ .03		Imp. #2	100		134				
OPERATOR	JOHN BURCH / CARTER LAN		STACK DIAMETER	15"		Imp. #3	10		102				
CONTROL UNIT / Y	1.0194 / ST CAE 2		STACK HEIGHT			Imp. #4							
	ΔH@ 1.825		INITIAL LEAK TEST	.004		Imp. #5							
	BAROMETRIC PRESSURE, IN. Hg		FINAL LEAK TEST	.004		Imp. #6							
	ASSUMED MOISTURE, Bw		WB = 13.8 DB = 13.8		Upstream Diameters		2.8						
					Downstream Diameters		35 in						
Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Dry Gas Outlet	Stack	Probe	Box	Impinger Exit	Pump Vac. IN. Hg	CO ₂ Vol. %	O ₂ Vol. %	PRE HUM FLOWS
1	9:50	557.570	0.080	1.45	59	138	240	240	48	3	7.5	13.0	.08
2	2.5	559.16	0.08	1.45	59	138	240	240	48	3	7.5	13.0	.08
3	5.0	560.75	0.08	1.45	59	137	240	240	48	3	7.5	13.0	.10
4	7.5	562.34	0.08	1.45	59	137	240	240	48	3	7.5	13.0	.10
5	10.0	563.93	0.08	1.45	59	137	240	240	48	3	7.5	13.0	.10
6	12.5	565.52	0.10	1.81	59	137	240	240	48	3	7.5	13.0	.10
7	15.0	567.30	0.10	1.81	59	137	240	240	48	3	7.5	13.0	.10
8	17.5	569.08	0.10	1.81	60	138	240	240	48	3	7.5	13.0	.10
9	20.0	570.86	0.10	1.81	60	138	240	240	48	3	7.5	13.0	.10
10	22.5	572.64	0.10	1.81	61	138	240	240	48	3	7.5	13.0	.10
11	25.0	574.43	0.10	1.81	61	138	240	240	48	3	7.5	13.0	.10
12	27.5	576.22	0.10	1.81	62	138	240	240	48	3	7.5	13.0	.10
13	30.0	578.01	0.10	1.81	62	138	240	240	48	3	7.5	13.0	.10
1	2.5	579.61	0.08	1.46	63	139	240	240	48	3	7.5	13.0	.10
2	5.0	581.21	0.08	1.46	63	139	240	240	48	3	7.5	13.0	.10
3	7.5	582.81	0.08	1.46	63	139	240	240	48	3	7.5	13.0	.10
4	10.0	584.42	0.08	1.46	64	138	240	241	48	3	7.5	13.0	.10
5	12.5	586.03	0.08	1.46	64	138	240	241	48	3	7.5	13.0	.10
6	15.0	587.64	0.08	1.46	65	139	240	240	48	3	7.5	13.0	.10
7	17.5	589.25	0.08	1.46	66	139	240	240	48	3	7.5	13.0	.10
8	20.0	591.05	0.10	1.83	66	139	240	240	48	3	7.5	13.0	.10
9	22.5	592.85	0.10	1.83	66	139	240	240	48	3	7.5	13.0	.10
10	25.0	594.65	0.10	1.83	67	139	238	240	48	3	7.5	13.0	.10
11	27.5	596.26	0.08	1.47	68	139	238	240	48	3	7.5	13.0	.10
12	30.0	597.886	0.08	1.47	69	139	240	240	48	3	7.5	13.0	.10
	10:51	END OF TEST											

same
p45
0.5
0.4
0.4
0.4

10.217 11:05

WET BULB = 124
Dry Bulb = 124

ML

CLIENT	CAUTIMBER	
RUN No	PART 1	
SOURCE	SOUTH SCURBER (INSIDE)	
DATE	NOV. 8, 2016	
OPERATOR	JOHN BURCH / CARTER LAN.	
CONTROL UNIT / Y	1.0194	
	ΔH@ 1.825	
BAROMETRIC PRESSURE, IN. Hg	29.92	
ASSUMED MOISTURE, Bw	13% - 16% - 19%	
PROBE TIP DIAMETER, IN.	0.3720	
PROBE LENGTH, FT / Cp	4.2 0.8450	
PORT LENGTH	5"	
STATIC PRESSURE, IN. H2O	.05	
STACK DIAMETER	15"	
STACK HEIGHT		
INITIAL LEAK TEST	.004	
FINAL LEAK TEST	.004	

5.1%
PTS

Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP IN. H ₂ O	Orifice ΔH IN. H ₂ O	Dry Gas Outlet	Stack	Temperature °F	Impinger Exit	Pump Vac. IN. Hg	Fyrites		TOTAL GAIN (mL)
										CO ₂ Vol. %	O ₂ Vol. %	
1	11:50	438.568	0.10	1.53	68	121	240	48	3	10.0	11.0	0
2	2.5	440.23	0.10	1.52	68	123	240	48	3			0
3	5.0	441.90	0.10	1.46	68	127	240	48	3			0
4	7.5	443.50	0.10	1.44	68	130	240	48	3			0
5	10.0	445.09	0.10	1.42	68	132	240	48	3			0
6	12.5	446.68	0.10	1.42	68	134	240	48	3			0
7	15.0	448.27	0.10	1.41	68	136	240	48	3			0
8	17.5	449.86	0.10	1.41	68	138	240	48	3			0
9	20.0	451.44	0.10	1.41	68	138	240	48	3	9.0	12.0	0
10	22.5	453.03	0.10	1.41	69	139	240	48	3			0
11	25.0	454.62	0.10	1.41	70	139	241	48	3			0
12	27.5	456.21	0.10	1.41	70	140	241	48	3			0
13	30.0	457.79	0.10	1.41	71	140	240	48	3			0
14	2.5	459.46	0.11	1.55	71	140	240	48	3	9.0	12.0	0
15	5.0	461.13	0.11	1.55	71	140	240	48	3			0
16	7.5	462.76	0.11	1.49	71	140	241	48	3			0
17	10.0	464.39	0.11	1.49	71	140	241	48	3			0
18	12.5	466.02	0.12	1.62	72	141	240	48	3			0
19	15.0	467.65	0.12	1.62	73	142	240	48	3			0
20	17.5	469.28	0.12	1.62	74	142	240	48	3			0
21	20.0	471.03	0.12	1.63	74	142	240	48	3			0
22	22.5	473.02	0.13	1.76	74	142	240	48	3			0
23	25.0	474.81	0.13	1.76	75	142	240	48	3			0
24	27.5	476.60	0.13	1.76	75	142	240	48	3			0
25	30.0	478.38	0.12	1.63	75	142	240	48	3			0
	12:58	END OF TEST										

0.31
1.0
1.8
2.6
3.7
5.3
9.7
11.2
12.3
13.2
14.0
14.7

D.S. ①

CEM FIELD DATA SHEET

Client
Source
Date

*Cantimber - Pt. Alberni
Tussock Swallow Stk (South)
Nov. 8, 2016
(CARBONIZATION STK)*

Technician
Ambient Temp (°C)
Barometric Pressure (in. Hg)

*D.S.
10°C
29.94*

	N ₂	H ₂	1 Gas	2 Gas	3 Gas	4 Gas	5 Gas	O ₂ / CO ₂	Comb Air	Low Meth	Mid Meth	High Meth
Cylinder #			838	023	963	500						1700
Pressure (psi)			550	1500	300	1500		1500				
O ₂ (%)								10.95				
CO ₂ (%)								9.98				
CO (ppm)			463	248								
SO ₂ (ppm)				173		10.04						
NOx (ppm)				242	45.7							
THC (ppm)					502							2502

Analyzer Range	O ₂	CO ₂	CO	SO ₂	NOx	THC

CEM READINGS

Time	Source	O ₂	CO ₂	CO	SO ₂	NOx	THC	Response Time (sec)
MANIFOLD 1110	Ambient	20.96						O ₂ Up
	N ₂	.03	.02	1.56	-.40	0.20		O ₂ Dn
	1 Gas			469.8				CO ₂ Up
	2 Gas			252.17	172.62	242.08		CO ₂ Dn
	3 Gas					44.90		CO Up
	4 Gas				9.52			CO Dn
	O ₂ / CO ₂	11.03	9.98					SO ₂ Up
								SO ₂ Dn
STACK:	N ₂	0.13	0.05	1.47	.13	1.21	1.68	NOx Up
	1 Gas			462.8	162.98			NOx Dn
	2 Gas			246.38	159.05	239.46		THC Up
	3 Gas					45.3	510.43	THC Dn
	4 Gas				9.76			
	High Meth						2509	
	(3 Gas) Mid Meth						510.43	
	O ₂ / CO ₂	10.87	9.90					
Run #1: 12:15 - 13:15								
N ₂	.04	.06	2.41	-.42	0.40	2.78		
2 Gas			242.05	159.05	232.49			
3 Gas					43.49	489.22		
4 Gas				9.62				
O ₂ / CO ₂	11.08	9.58						

CEM FIELD DATA SHEET

DS ✓ (1)

Client
Source
Date

CANTIMBER - Pt. ALBERNI
NORTH SCRAPER
11/19/06
(Activation Stack)

Technician
Ambient Temp (°C)
Barometric Pressure (in. Hg)

DS
10°C
30.11

	N ₂	H ₂	1 Gas	2 Gas	3 Gas	4 Gas	5 Gas	O ₂	Comb Air	Low Meth	Mid Meth	High Meth
Cylinder #					963							
Pressure (psi)					200							
O ₂ (%)								10.95				
CO ₂ (%)								9.98				
CO (ppm)			463	248								
SO ₂ (ppm)				173	10.09	10.04						
NOx (ppm)				242	45.7	45.7						
THC (ppm)											44.1	91.4

Analyzer Range	O ₂	CO ₂	CO	SO ₂	NOx	THC
	0-25	0-20	0-500	0-200	0-300	0-100

CEM READINGS

Time	Source	O ₂	CO ₂	CO	SO ₂	NOx	THC	Response Time (sec)
	Ambient	20.90						O ₂ Up
MANIFOLD: 845	N ₂	0.0	0.03	2.72	-2.7	.61		O ₂ Dn
	1 Gas			467.64				CO ₂ Up
	2 Gas			242.95	172.62	242.49		CO ₂ Dn
	3 Gas					45.21		CO Up
	4 Gas				9.96			CO Dn
	O ₂ /CO ₂	11.0	10.04					SO ₂ Up
								SO ₂ Dn
	STACK: 905	N ₂	0.11	0.07	1.35	.13	0.71	.72
1 Gas				462.48				NOx Dn
2 Gas				244.63	168.24	241.98		THC Up
3 Gas						44.90		THC Dn
4 Gas					10.16			
High Meth							91.42	
Mid Meth							43.20	
O ₂ /CO ₂		10.99	9.92					
Run #1: 10:15 - 11:15								
	N ₂	0.18	0.11	4.52	-2.96	.61	.14	
	2 Gas			243.56	165.24	237.80		
	3 Gas					42.98		
	4 Gas				6.92			
	Mid Meth						44.05	
	O ₂ /CO ₂	11.08	9.93					

DS ✓ (2)

CEM FIELD DATA SHEET

Client CANTIMAR - Pt. ALBERTI
 Source NORTH SCRUBBER CONT...
 Date NOV. 9, 2016
(Activation Stack)

Technician _____
 Ambient Temp (°C) _____
 Barometric Pressure (in. Hg) _____

DS
10°C
30.11

	N ₂	H ₂	1 Gas	2 Gas	3 Gas	4 Gas	5 Gas	O ₂	Comb Air	Low Meth	Mid Meth	High Meth
Cylinder #												
Pressure (psi)												
O ₂ (%)												
CO ₂ (%)												
CO (ppm)												
SO ₂ (ppm)												
NOx (ppm)												
THC (ppm)												

Analyzer Range	O ₂	CO ₂	CO	SO ₂	NOx	THC

CEM READINGS

Time	Source	O ₂	CO ₂	CO	SO ₂	NOx	THC	Response Time (sec)
	Run #2: 11:35 - 12:35							O ₂ Up
	N ₂	-24	0.09	2.94	-330	0.50	-07	O ₂ Dn
	2 Gas			243.08	156.42	238.70		CO ₂ Up
	3 Gas					41.62		CO ₂ Dn
	4 Gas				6.13			CO Up
	O ₂ / CO ₂	11.11	9.87					CO Dn
	MTO METL						42.07	SO ₂ Up
								SO ₂ Dn
	Run #3: 13:10 - 14:10							NOx Up
	N ₂	.78	.15	12.08	-3.23	1.01	-97	NOx Dn
	2 Gas			248.34	155.42	239.82		THC Up
	3 Gas					42.44		THC Dn
	4 Gas				6.10			
	O ₂ / CO ₂	11.13	9.96					
	MTO METL						42.59	

A. Lanfranco and Associates Inc.

Carbonization Stack

Client Cartimber Y Wizit 4620 1.0180
 Source South Scrubber Cp
 Parameter Hot-Phenol-methanol Pbar 29.92 Static
 Date Nov. 8/16 Operator Carter Lanfranco

Leak Check	Run 1	Run 2	Run 3
Initial @ 15'	0.0001	0.0001	0.0001
Final @ 15'	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m ³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	11:50	1.9116	62					
			65					
			68					
2	12:50	1.9508	70					
			72					
			74					
3	12:55	1.9515	68					
			70					
			70					
3	13:55	1.9830	72					
			71					
3	14:00	1.9832	68					
			69					
			70					
3	15:00	2.0055	68					
			69					
			66					

DS ✓

Activation Stack

Client Cartimber Y Wizit 4620 1.0180
 Source North Scrubber Cp
 Parameter Hot-Phenol-methanol Pbar 29.90 Static
 Date Nov. 9/16 Operator Carter Lanfranco

Leak Check	Run 1	Run 2	Run 3
Initial @ 15'	0.0001	0.0001	0.0001
Final @ 15'	0.0001	0.0001	0.0001

Test No.	Time (hhmm)	DGM Volume (cu ft) / (m ³)	Temperature (°F)		Imp. Vol. (mL)	ΔP IN. H ₂ O		
			DGM Outlet	Stack		R1	R2	R3
1	10:15	2.0059	58					
			60					
			60					
2	11:15	2.0424	62					
			64					
2	11:35	2.0428	60					
			59					
			60					
2	12:35	2.0780	60					
			62					
3	13:12	2.0785	66					
			65					
			66					
3	14:12	2.1152	66					
			64					
			67					

Canister sampling sheet

Plant Can timber Test Date Nov. 8/16
 File No. South Scrubber Recovery Date _____
Carbonization stacks

Source: Run-1

Pbar in hg	<u>29.92</u>					
Canister number	<u>500769</u>					
Controller number	<u>0A01093</u>					
Initial: Start time	<u>11:56</u>					
Flask Vac. (in Hg)	<u>-30</u>					
Final: Finish time	<u>12:56</u>					
Flask Vac. (in Hg)	<u>-5</u>					

Source: Run-2

Pbar in hg	<u>29.92</u>					
Canister number	<u>500282</u>					
Controller number	<u>0A0164</u>					
Initial: Start time	<u>13:00</u>					
Flask Vac. (in Hg)	<u>-27</u>					
Final: End time	<u>14:00</u>					
Flask Vac. (in Hg)	<u>-3</u>					

Source: Run-3

Pbar in hg	<u>29.92</u>					
Canister number	<u>500829</u>					
Controller number	<u>0A00572</u>					
Initial: Start time	<u>14:07</u>					
Flask Vac. (in Hg)	<u>-29</u>					
Final: End time	<u>15:07</u>					
Flask Vac. (in Hg)	<u>-5</u>					

Source:

Pbar in hg						
Canister number						
Controller number						
Initial: Start time						
Flask Vac. (in Hg)						
Final: End time						
Flask Vac. (in Hg)						

134025can/mv/in

Canister sampling sheet

Plant Cantimber Test Date Nov. 9/16
File No. North Scriber Recovery Date _____
Activation Stack

Source: Run-1

Pbar in hg	29.90					
Canister number	5000403					
Controller number	0A01516					
Initial: Start time	10:28					
Flask Vac. (in Hg)	-3					
Final: Finish time	11:28					
Flask Vac. (in Hg)	-5					

Source: Run-2

Pbar in hg	29.90					
Canister number	5002019					
Controller number	0A01828 *					
Initial: Start time	11:46					
Flask Vac. (in Hg)	-29					
Final: End time	12:46					
Flask Vac. (in Hg)	-5					

Source: Run-3

Pbar in hg	29.90					
Canister number	5001693					
Controller number	0A01141					
Initial: Start time	13:12					
Flask Vac. (in Hg)	-29					
Final: End time	14:12					
Flask Vac. (in Hg)	-4					

Source:

Pbar in hg						
Canister number						
Controller number						
Initial: Start time						
Flask Vac. (in Hg)						
Final: End time						
Flask Vac. (in Hg)						

APPENDIX 4

**CALIBRATION DATA
and PROCESS DATA**

Pitot Tube Calibration

Date: 04-Jul-16
Pbar (in.Hg): 29.88

Temp (R): 530
Dn (in.): 0.25

Pitot ID: **Napp 4A**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.120	0.160	22.9	0.8574	0.0040
0.210	0.280	30.4	0.8574	0.0040
0.360	0.490	39.7	0.8486	0.0048
0.510	0.690	47.3	0.8511	0.0023
0.660	0.890	53.8	0.8525	0.0009
Average :			0.8534	0.0032

Pitot ID: **HT-4A**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.130	0.180	23.9	0.8413	0.0039
0.285	0.390	35.4	0.8463	0.0011
0.470	0.650	45.4	0.8418	0.0034
0.670	0.920	54.2	0.8448	0.0004
0.770	1.040	58.1	0.8519	0.0066
Average :			0.8452	0.0031

Pitot ID: **AL 4A-1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.135	0.190	24.3	0.8345	0.0024
0.280	0.390	35.1	0.8388	0.0019
0.390	0.550	41.4	0.8337	0.0033
0.540	0.760	48.7	0.8345	0.0024
0.660	0.910	53.8	0.8431	0.0062
Average :			0.8369	0.0032

Pitot ID: **HT-4B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.140	0.190	24.8	0.8498	0.0046
0.210	0.285	30.4	0.8498	0.0046
0.300	0.405	36.3	0.8521	0.0068
0.440	0.600	43.9	0.8478	0.0026
0.710	0.955	55.8	0.8536	0.0084
Average :			0.8506	0.0054

Pitot ID: **AL 4A-2**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.125	0.170	23.4	0.8489	0.0039
0.280	0.390	35.1	0.8388	0.0061
0.370	0.510	40.3	0.8432	0.0017
0.500	0.690	46.8	0.8427	0.0022
0.680	0.920	54.6	0.8511	0.0062
Average :			0.8450	0.0040

Pitot ID: **HT-4C**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.140	0.190	24.8	0.8498	0.0046
0.210	0.285	30.4	0.8498	0.0046
0.305	0.410	36.6	0.8539	0.0086
0.510	0.690	47.3	0.8511	0.0059
0.680	0.910	54.6	0.8558	0.0106
Average :			0.8521	0.0068

Pitot ID: **4B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.050	0.070	14.8	0.8367	0.0064
0.200	0.280	29.6	0.8367	0.0064
0.275	0.380	34.7	0.8422	0.0010
0.490	0.660	46.4	0.8530	0.0099
0.820	1.120	60.0	0.8471	0.0040
Average :			0.8431	0.0055

Pitot ID: **HT-4D**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.180	0.240	28.1	0.8574	0.0121
0.230	0.310	31.8	0.8527	0.0075
0.355	0.480	39.5	0.8514	0.0062
0.510	0.690	47.3	0.8511	0.0059
0.680	0.920	54.6	0.8511	0.0059
Average :			0.8528	0.0075

* Average absolute deviation must not exceed 0.01.



Calibrated by A. Lanfranco and Associates Inc.

A. Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: Wizit
Serial #: 4620

Date: 04-May-16
Barometric Pressure: 29.95 (in. Hg)
Theoretical Critical Vacuum: 14.13 (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)³*(min))
!!!!!!!

----- DRY GAS METER READINGS -----

dH (in H2O)	Time (min)	Volume		Volume Total (cu ft)	Initial Temps.		Final Temps.	
		Initial (m ³)	Final (m ³)		Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)
0.00	6.00	1.425	1.478	1.861	75.0	75.0	75.0	75.0
0.00	22.00	1.478	1.671	6.823	75.0	75.0	77.0	77.0
0.00	15.00	1.671	1.803	4.672	77.0	77.0	78.0	78.0

-CRITICAL ORIFICE READINGS-

Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --	
			Initial (deg F)	Final (deg F)
40	0.2408	14.0	75.0	75.0
40	0.2408	14.0	75.0	77.0
40	0.2408	14.0	77.0	76.0

***** RESULTS *****

--- DRY GAS METER ---

VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vc(std) (cu ft)	VOLUME CORRECTED Vcr (liters)	VOLUME NOMINAL Vcr (cu ft)	CALIBRATION FACTOR Y	
				Value (number)	Variation (number)
1.838	1.871	53.0	1.894	1.018	0.000
6.725	6.853	194.1	6.953	1.019	0.001
4.592	4.670	132.3	4.743	1.017	-0.001

-- DRY GAS METER --

CALIBRATION FACTOR Y	Value (in H2O)	Variation (in H2O)	CALIBRATION FACTOR dH@	
			Value (mm H2O)	Variation (in H2O)
0.000	0.000	0.000	0.00	0.000
0.000	0.000	0.000	0.00	0.000
0.000	0.000	0.000	0.00	0.000

Average Y-----> 1.0180 Average dH@-----> 0.0001 Average dH@-----> 0.00

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

SIGNED: 

Date: May 4, 2016

A. Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K Factor

Model #: ST CAE2
Serial #: 0028-072911-1

Date: 05-Jul-16
Barometric Pressure: 29.98 (in. Hg)
Theoretical Critical Vacuum: 14.14 (in. Hg)

IMPORTANT: For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT: The Critical Orifice Coefficient, K', must be entered in English units, (ft³·s²·(deg R)^{0.5}·(in·Hg)⁻¹·(min)).

--- DRY GAS METER READINGS ---										--- CRITICAL ORIFICE READINGS ---					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Inlet (deg F)	Outlet (deg F)	Inlet Temps (deg F)	Outlet (deg F)	Final Temps (deg F)	Orifice Serial# (number)	K' Coefficient (see above)	Actual Vacuum (in Hg)	Initial (deg F)	Final (deg F)	Average (deg F)
0.33	15.00	322.000	326.596	4.596	77.0	75.0	78.0	75.0	75.0	40	0.2408	24.3	81.0	82.0	81.5
0.68	15.00	315.200	321.947	6.747	76.0	74.0	78.0	75.0	75.0	46	0.3560	22.5	76.0	75.0	75.5
1.15	15.00	305.700	315.171	9.471	73.0	73.0	77.0	74.0	74.0	55	0.4606	20.5	75.0	78.0	76.5
1.95	15.00	294.200	305.660	11.460	73.0	71.0	74.0	72.0	72.0	63	0.5956	19.0	73.0	78.0	75.5
3.70	15.00	278.400	294.200	15.800	70.0	70.0	75.0	71.0	71.0	73	0.8185	16.0	70.0	74.0	72.0

***** RESULTS *****																			
--- DRY GAS METER ---					--- ORIFICE ---														
VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vc(std) (cu ft)	VOLUME NOMINAL Vn (cu ft)	Vr (cu ft)	Vr/Vn	Value (number)	Variation (in H2O)	dh@ (mm H2O)	Value (in H2O)	Ko (value)										
4.534	128.4	4.765	131.8	1.026	1.026	0.007	47.66	1.877	0.698										
6.671	188.9	6.918	195.9	1.037	1.037	0.018	45.21	1.780	0.709										
9.402	266.3	9.548	270.4	1.016	1.016	-0.004	46.76	1.801	0.719										
11.436	323.9	11.574	327.8	1.012	1.012	-0.007	46.58	1.834	0.714										
15.864	449.3	15.958	451.9	1.006	1.006	-0.013	46.58	1.834	0.717										
Average Y →					Average dh@ →					Average Ko →									
					1.0194					1.825					46.4				

TEMPERATURE CALIBRATION			
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Variation (deg F)	Percent of Absolute
32	32	0	0.00%
100	100	0	0.00%
300	300	0	0.00%
500	500	0	0.00%
1000	1000	0	0.00%

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor K', the orifice differential pressure in inches of H2O that equals to 0.15 cm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Device, the reading must be within 1.3% of certified calibration standard (absolute temperature) to be acceptable.

SIGNED 


Date: July 5, 2016

A. LANFRANCO and ASSOCIATES INC.

ENVIRONMENTAL CONSULTANTS

NOZZLE DIAMETER CALIBRATION FORM

Technician: S. Ferguson
Date: July 4, 2016

Signature: 


Nozzle I.D.	d1 (inch)	d2 (inch)	d3 (inch)	difference (inch)	average dia. (inch)	average area (ft ²)
ST01	0.1270	0.1240	0.1245	0.0030	0.1252	0.0000854
ST05	0.1695	0.1720	0.1710	0.0025	0.1708	0.0001592
SS-7	0.1715	0.1715	0.1740	0.0025	0.1723	0.0001620
SS-1	0.1775	0.1785	0.1790	0.0015	0.1783	0.0001735
SS-8	0.2010	0.1995	0.2020	0.0025	0.2008	0.0002200
ST11	0.2130	0.2135	0.2125	0.0010	0.2130	0.0002474
ST10	0.2345	0.2360	0.2355	0.0015	0.2353	0.0003021
SS-18	0.2415	0.2410	0.2400	0.0015	0.2408	0.0003163
ST15	0.2425	0.2430	0.2400	0.0030	0.2418	0.0003190
SS-2	0.2425	0.2430	0.2400	0.0030	0.2418	0.0003190
SS-24	0.2410	0.2440	0.2430	0.0030	0.2427	0.0003212
SS-3	0.2425	0.2450	0.2435	0.0025	0.2437	0.0003238
B	0.2450	0.2440	0.2465	0.0025	0.2452	0.0003278
ST30	0.2500	0.2470	0.2480	0.0030	0.2483	0.0003364
ST20	0.2475	0.2500	0.2485	0.0025	0.2487	0.0003373
SS-14	0.2505	0.2490	0.2485	0.0020	0.2493	0.0003391
A	0.2505	0.2505	0.2510	0.0005	0.2507	0.0003427
SS-9	0.2755	0.2770	0.2765	0.0015	0.2763	0.0004165
ST40	0.2850	0.2830	0.2855	0.0025	0.2845	0.0004415
SS-13	0.2970	0.2985	0.3000	0.0030	0.2985	0.0004860
ST50	0.3020	0.3015	0.3025	0.0010	0.3020	0.0004974
SS-30	0.3020	0.3025	0.3015	0.0010	0.3020	0.0004974
SS-4	0.3030	0.3010	0.3040	0.0030	0.3027	0.0004996
ST60	0.3035	0.3040	0.3050	0.0015	0.3042	0.0005046
SS-10	0.3175	0.3195	0.3200	0.0025	0.3190	0.0005550
ST65	0.3305	0.3305	0.3290	0.0015	0.3300	0.0005940
ST66	0.3395	0.3375	0.3385	0.0020	0.3385	0.0006249
ST80	0.3615	0.3615	0.3610	0.0005	0.3613	0.0007121
SS-5	0.3710	0.3730	0.3720	0.0020	0.3720	0.0007548
ST75	0.3730	0.3735	0.3705	0.0030	0.3723	0.0007561
SS-16	0.3730	0.3740	0.3750	0.0020	0.3740	0.0007629
ST76	0.3740	0.3745	0.3750	0.0010	0.3745	0.0007649
ST85	0.4030	0.4000	0.4030	0.0030	0.4020	0.0008814
SS-15	0.4050	0.4060	0.4065	0.0015	0.4058	0.0008983
DD	0.4070	0.4050	0.4065	0.0020	0.4062	0.0008998
SS-11	0.4205	0.4190	0.4185	0.0020	0.4193	0.0009591
ST70	0.4250	0.4260	0.4240	0.0020	0.4250	0.0009852
ST86	0.4545	0.4510	0.4550	0.0040	0.4535	0.0011217
SS-49	0.4955	0.4965	0.4975	0.0020	0.4965	0.0013445
C	0.4960	0.4980	0.4970	0.0020	0.4970	0.0013472
SS-6	0.4980	0.4970	0.4975	0.0010	0.4975	0.0013499
ST90	0.4960	0.4980	0.5000	0.0040	0.4980	0.0013527
ST92	0.5060	0.5040	0.5045	0.0020	0.5048	0.0013900
ST96	0.5560	0.5540	0.5550	0.0020	0.5550	0.0016800
SS-12	0.7515	0.7505	0.7485	0.0030	0.7502	0.0030693

Where:

- (a) D1, D2, D3 = three different nozzle diameters; each diameter must be measured to within (0.025mm) 0.001 in.
- (b) Difference = maximum difference between any two diameters; must be less than or equal to (0.1mm) 0.004 in.
- (c) Average = average of D1, D2 and D3

BAROMETER CALIBRATION FORM

Device	Cal Date	Pbar Env Canada		Device (inches of Hg)		Difference (Env Can - Elv Corr)
		(kPa)	(inches of Hg)	Reading	Elevation Corrected	
LA	July 4, 2016	102.1	30.16	30.02	30.09	0.06
DS	July 4, 2016	102.1	30.16	30.02	30.09	0.06
CL	July 4, 2016	102.1	30.16	30.02	30.09	0.06
ML	July 4, 2016	102.1	30.16	30.02	30.09	0.06
MH	July 4, 2016	102.1	30.16	30.02	30.09	0.06
SH	July 4, 2016	102.1	30.16	30.02	30.09	0.06
JZ	July 4, 2016	102.1	30.16	30.02	30.09	0.06
JB	July 4, 2016	102.1	30.16	30.02	30.09	0.06
SF	July 4, 2016	102.1	30.16	30.02	30.09	0.06
AN	July 4, 2016	102.1	30.16	30.02	30.09	0.06

SIGNED:  Date: July 4, 2016


Performance Specification is
Device Corrected for Elevation must be +/- 0.1 " Hg of ENV CANADA SEA-LEVEL Pbar
 Enter Environment Canada Pressure from their website for Vancouver (link below)
 and the reading from your barometer on the ground floor of the office.

http://www.weatheroffice.gc.ca/city/pages/bc-74_metric_e.html

A. LANFRANCO and ASSOCIATES INC.
 ENVIRONMENTAL CONSULTANTS

TEMPERATURE CALIBRATION FORM

Technician: S. Ferguson
 Date: 04-Jul-16

Signature: 

TEMPERATURE DEVICE CALIBRATIONS

Reference Device Model CL23A Calibrator	Temperature Settings (degrees F)													
	32		100		200		300		500		800		1700	
	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation	Reading	Variation
Omega HH11A	32	0.00%	99	-0.18%	201	0.15%	301	0.13%	498	-0.21%	797	-0.24%	1700	0.00%
Omega HH11A	32	-6.51%	99	-17.87%	201	-30.32%	301	-39.49%	498	-52.10%	797	-63.51%	1700	-78.72%
Omega HH11A - ST	32	0.00%	99	-0.18%	200	0.00%	300	0.00%	497	-0.31%	797	-0.24%	1696	-0.19%
Omega HH11A	32	0.00%	99	-0.18%	200	0.00%	300	0.00%	497	-0.31%	796	-0.32%	1695	-0.23%
Omega HH11A	33	0.20%	100	0.00%	201	0.15%	302	0.25%	499	-0.10%	798	0.15%	1697	0.14%
TPI 341K 2 - 4	29	-0.61%	97	-0.54%	195	-0.61%	296	-0.53%	496	-0.42%	795	-0.40%	1692	-0.37%
TPI 341K 2 - 8	29	-0.61%	98	-0.36%	197	-0.45%	297	-0.39%	497	-0.31%	796	-0.32%	1692	-0.37%
Cont Cmpny	10	-6.51%	98	-17.87%	199	-30.32%	299	-39.49%	499	-52.10%	799	-63.51%	1703	-78.72%
Cont Cmpny 2	30	-0.41%	98	-0.35%	199	-0.15%	300	0.00%	502	0.21%	803	0.24%	1713	0.50%
HH501A/JK ST-3	33	-6.51%	100	-17.87%	201	-30.32%	302	-39.49%	499	-52.10%	799	-63.51%	1699	-78.72%
HH501A/JK ST-4	33	-6.51%	100	-17.87%	201	-30.32%	302	-39.49%	499	-52.10%	799	-63.51%	1699	-78.72%
Omega HH11	33	0.20%	100	0.00%	201	0.15%	302	0.25%	499	-0.10%	799	-0.08%	1699	-0.05%
TPI 2	30	-6.51%	98	-17.87%	198	-30.32%	299	-39.49%	499	-52.10%	799	-63.51%	1703	-78.72%
TPI 341K	30	-0.41%	98	-0.36%	198	-0.30%	299	-0.13%	499	-0.10%	800	0.00%	1703	0.14%
TPI 341K	29	-0.61%	97	-0.54%	197	-0.45%	297	-0.39%	496	-0.42%	796	-0.32%	1695	-0.23%
TPI 341K	30	-0.41%	99	-0.18%	198	-0.30%	298	-0.26%	498	-0.21%	797	-0.24%	1694	-0.28%
TPI 341K	28	-0.61%	97	-0.54%	197	-0.45%	297	-0.39%	496	-0.42%	796	-0.32%	1694	-0.28%
TPI 341K	29	-0.61%	98	-0.36%	197	-0.45%	297	-0.39%	496	-0.42%	796	-0.32%	1694	-0.28%
TPI 341K 2 - 3	32	0.00%	99	-0.18%	200	0.00%	299	-0.13%	499	-0.10%	800	0.00%	1701	0.05%

Reference device is a NIST certified digital thermocouple calibrator
 Variation expressed as a percentage of the absolute temperature must be within 1.5 %

A. LANFRANCO and ASSOCIATES INC.
ENVIRONMENTAL CONSULTANTS

TEMPERATURE CALIBRATION FORM

Technician: C. Lanfranco

Date: Jan. 4, 2016

Signature:



K-TYPE THERMOCOUPLE CALIBRATIONS

Probe/TC ID	Hg Thermometer Temp (F)	CL23A Readout (F)	Probe/TC ID	Hg Thermometer Temp (F)	CL23A Readout (F)
3B	212	211	TC 3-3	212	211
3C	212	211	TC 4-3	210	211
4A	212	212	TC 4-4	212	212
4B	212	212	TC 5-4	210	212
5A	211	211	TC 5-5	n/a	n/a
5B	212	211	TC 5-6	212	211
5C	211	211	TC 6-4	211	211
5D	211	211	TC 10-3	211	211
6A	212	212	TC 10-4	n/a	n/a
6B	211	211	5' Fording	211	211
6C	212	211	TC Marshal	212	211
7C	210	210			
8A	211	212			
8B	210	210			
10A	210	211			
10B	212	212			
11A	210	211			
12A	213	212.0			
12B	209	209			

* n/a denotes not in service



DocNumber: 000054306

Praxair
5700 South Alameda Street
Los Angeles, CA 90058
Tel:(323)585-2154 Fax:(714)542-6689
PGVP ID: F22013

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

A LANFRANCO & ASSOC INC
101 9488 189TH ST
SURREY BC V4N 4W7

Praxair Order Number: 18220389
Customer PO Number: MARK LANFRANCC
Customer Reference Number:

Fill Date: 5/14/2013
Part Number: NI CO450NS1E-AS
Lot Number: 109313409
Cylinder Style and Outlet: AS CGA 660
Cylinder Pressure and Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Table with 4 columns: Expiration Date, Cylinder Number, Component Name, and Analytical Uncertainty. Components include CARBON MONOXIDE, NITRIC OXIDE, SULFUR DIOXIDE, and NITROGEN.

NOx ppm = 464 PPM

NOX for Reference Only

Certification Information: Certification Date: 5/29/2013 Term: 96 Months Expiration Date: 05/29/2021

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1. The certification expiration date was assigned using the May 2012 revision of the EPA Traceability Protocol document. Do Not Use this Standard if Pressure is less than 150 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component:

CARBON MONOXIDE

Requested Concentration: 450 ppm
Certified Concentration: 463 ppm
Instrument Used: HORIBA, VIA-510 576 876 015
Analytical Method: NDIR
Last Multipoint Calibration: 05/27/2013

Table with 4 columns: Z, R, C, Conc. for First Analysis Data. Mean Test Assay: 463 ppm.

Reference Standard Type: GMIS
Ref. Std. Cylinder #: SA16869
Ref. Std. Conc.: 494 ppm
Ref. Std. traceable to SRM #: vs. 1680b
SRM Sample #: 2-J-15
SRM Cylinder #: CAL018072

Table with 4 columns: Z, R, C, Conc. for Second Analysis Data. Mean Test Assay: 0 ppm.

2. Component:

NITRIC OXIDE

Requested Concentration: 450 ppm
Certified Concentration: 464 ppm
Instrument Used: Thermo Electron 42i S/N 072602432C
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 05/27/2013

Table with 4 columns: Z, R, C, Conc. for First Analysis Data. Mean Test Assay: 464 ppm.

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC207299
Ref. Std. Conc.: 498 ppm
Ref. Std. traceable to SRM #: 1687b
SRM Sample #: 41-K-34
SRM Cylinder #: FF31364

Table with 4 columns: Z, R, C, Conc. for Second Analysis Data. Mean Test Assay: 463 ppm.

3. Component:

SULFUR DIOXIDE

Requested Concentration: 275 ppm
Certified Concentration: 286 ppm
Instrument Used: HORIBA, VIA-510, 56946604
Analytical Method: NDIR11
Last Multipoint Calibration: 05/27/2013

Table with 4 columns: Z, R, C, Conc. for First Analysis Data. Mean Test Assay: 285 ppm.

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC117224
Ref. Std. Conc.: 495 ppm
Ref. Std. traceable to SRM #: vs. 1661a
SRM Sample #: 94-H-05
SRM Cylinder #: FF28146

Table with 4 columns: Z, R, C, Conc. for Second Analysis Data. Mean Test Assay: 286 ppm.

Analyzed by:

Nelson Ma

Certified by:

Diego Mestanza

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specified analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose.



Praxair
 5700 South Alameda Street
 Los Angeles, CA 90058
 Tel: (323) 585-2154 Fax: (714) 542-6689
 PGVPID: F22016

DocNumber: 000097877

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

A LANFRANCO & ASSOC INC
 101 9488 189TH ST
 SURREY BC V4N 4

Praxair Order Number: 27077023
 Customer P. O. Number:
 Customer Reference Number:

Fill Date: 8/17/2016
 Part Number: NI CO240NS3E-AS
 Lot Number: 109623008
 Cylinder Style & Outlet: AS CGA 660
 Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	8/29/2024	NIST Traceable
Cylinder Number:	DT0014773	Analytical Uncertainty:
248 ppm	CARBON MONOXIDE	± 0.6 %
242 ppm	NITRIC OXIDE	± 0.6 %
173 ppm	SULFUR DIOXIDE	± 0.5 %
Balance	NITROGEN	

NOx = 242 ppm

NOx for Reference Only

Certification Information: Certification Date: 8/29/2016 Term: 96 Months Expiration Date: 8/29/2024
 This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE

Requested Concentration: 240 ppm
 Certified Concentration: 248 ppm
 Instrument Used: HORIBA, VIA-510 576 876 015
 Analytical Method: NDIR
 Last Multipoint Calibration: 8/26/2016

First Analysis Data:		Date: 8/22/2016	
Z: 0	R: 251.6	C: 247.4	Conc: 247.4
R: 251.3	Z: 0	C: 247.7	Conc: 247.7
Z: 0	C: 247.5	R: 251.9	Conc: 247.5
UOM: ppm	Mean Test Assay:		247.53 ppm

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: SA10433
 Ref. Std. Conc: 251.6 ppm
 Ref. Std. Traceable to SRM #: 2636a
 SRM Sample #: 57-E-28
 SRM Cylinder #: FF23380

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: ppm	Mean Test Assay:		0 ppm

2. Component: NITRIC OXIDE

Requested Concentration: 235 ppm
 Certified Concentration: 242 ppm
 Instrument Used: Thermo Electron 42i S/N 072602432C
 Analytical Method: Chemiluminescence
 Last Multipoint Calibration: 8/10/2016

First Analysis Data:		Date: 8/22/2016	
Z: 0	R: 248	C: 242	Conc: 242.33
R: 247	Z: 0	C: 241	Conc: 241.32
Z: 0	C: 242	R: 248	Conc: 242.33
UOM: ppm	Mean Test Assay:		241.99 ppm

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: CC3151
 Ref. Std. Conc: 248.0 ppm
 Ref. Std. Traceable to SRM #: 1685b
 SRM Sample #: 43-L-11
 SRM Cylinder #: CAL017304

Second Analysis Data:		Date: 8/29/2016	
Z: 0	R: 248	C: 242	Conc: 242
R: 248	Z: 0	C: 242	Conc: 242
Z: 0	C: 242	R: 248	Conc: 242
UOM: ppm	Mean Test Assay:		242 ppm


3. Component: SULFUR DIOXIDE


Requested Concentration: 165 ppm
 Certified Concentration: 173 ppm
 Instrument Used: HORIBA, VIA-510, 5203551011
 Analytical Method: NDIR
 Last Multipoint Calibration: 8/15/2016

First Analysis Data:		Date: 8/22/2016	
Z: 0	R: 507.9	C: 172.7	Conc: 172.41
R: 509.1	Z: 0	C: 172.9	Conc: 172.61
Z: 0	C: 173	R: 509.3	Conc: 172.71
UOM: ppm	Mean Test Assay:		172.57 ppm

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: CC30796
 Ref. Std. Conc: 507.9 ppm
 Ref. Std. Traceable to SRM #: 1661a
 SRM Sample #: 94-I-18
 SRM Cylinder #: FF22304

Second Analysis Data:		Date: 8/29/2016	
Z: 0	R: 507.9	C: 172.4	Conc: 172.4
R: 507.9	Z: 0	C: 172.9	Conc: 172.9
Z: 0	C: 172.8	R: 507.9	Conc: 172.8
UOM: ppm	Mean Test Assay:		172.7 ppm

Analyzed by:  Jose Vasquez

Certified by:  Jack E. ...

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.



Praxair
 5700 South Alameda Street
 Los Angeles, CA 90058
 Tel: (323) 585-2154 Fax: (714) 542-6689
 PGVPID: F22013

DocNumber: 000056184

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

A LANFRANCO & ASSOC INC
 101 9488 189TH ST
 SURREY BC V4N 4

Praxair Order Number: 18656476
 Customer P. O. Number: MARK
 Customer Reference Number:

Fill Date: 7/13/2013
 Part Number: NI ME490N1E-AS
 Lot Number: 109319402
 Cylinder Style & Outlet: AS CGA 660
 Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	7/25/2017	NIST Traceable
Cylinder Number:	CC423963	Analytical Uncertainty:
45.7 ppm	NITRIC OXIDE	± 0.7 %
502 ppm	METHANE	± 1 %
Balance	NITROGEN	

NOx = 45.9 ppm

NOx for Reference Only

Certification Information: Certification Date: 7/25/2013 Term: 48 Months Expiration Date: 7/25/2017

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: NITRIC OXIDE

Requested Concentration: 45 ppm
 Certified Concentration: 45.7 ppm
 Instrument Used: Thermo Electron 42C S/N 518112467
 Analytical Method: Chemiluminescence
 Last Multipoint Calibration: 7/24/2013

First Analysis Data:		Date: 7/17/2013	
Z: 0	R: 50	C: 45.6	Conc: 45.6
R: 50	Z: 0	C: 45.6	Conc: 45.6
Z: 0	C: 45.6	R: 50	Conc: 45.6
UOM: ppm	Mean Test Assay:		45.6 ppm

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: CC362455
 Ref. Std. Conc: 50.0 ppm
 Ref. Std. Traceable to SRM #: 1683b
 SRM Sample #: 45-U-37
 SRM Cylinder #: CAL015617

Second Analysis Data:		Date: 7/25/2013	
Z: 0	R: 50	C: 45.5	Conc: 45.5
R: 50	Z: 0	C: 45.7	Conc: 45.7
Z: 0	C: 46	R: 50	Conc: 46
UOM: ppm	Mean Test Assay:		45.733 ppm

2. Component: METHANE

Requested Concentration: 490 ppm
 Certified Concentration: 502 ppm
 Instrument Used: HORIBA, FIA-510, 851135122
 Analytical Method: Flame Ionization Detector
 Last Multipoint Calibration: 7/24/2013

First Analysis Data:		Date: 7/17/2013	
Z: 0	R: 430.2	C: 432.6	Conc: 502.21
R: 431.3	Z: 0	C: 432.1	Conc: 501.63
Z: 0	C: 431.7	R: 430.6	Conc: 501.16
UOM: ppmC	Mean Test Assay:		501.66 ppm

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: H93454
 Ref. Std. Conc: 500 ppm
 Ref. Std. Traceable to SRM #: vs. 2751
 SRM Sample #: 212-09-AL
 SRM Cylinder #: SX-20000

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: ppmC	Mean Test Assay:		0 ppm

Analyzed by:

R. Kaywood
 Rolonda Kaywood

Certified by:

Jack Fyfe



Praxair
 5700 South Alameda Street
 Los Angeles, CA 90058
 Tel: (323) 585-2154 Fax: (714) 542-6689
 PGVPID: F22013

DocNumber: 000050754

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

A LANFRANCO & ASSOC INC
 101 9488 189TH ST
 SURREY BC V4N 4

Praxair Order Number: 17623309
 Customer P. O. Number: MARK LANFRAN
 Customer Reference Number:

Fill Date: 3/5/2013
 Part Number: NI SD10ME-AS
 Lot Number: 109306407
 Cylinder Style & Outlet: AS CGA 660
 Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	3/15/2017	NIST Traceable
Cylinder Number:	CC424105	Analytical Uncertainty:
10.04 ppm	SULFUR DIOXIDE	± 2 %
Balance	NITROGEN	

Certification Information: Certification Date: 3/15/2013 Term: 48 Months Expiration Date: 3/15/2017

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1. The certification expiration date was assigned using the May 2012 revision of the EPA Traceability Protocol document. Do Not Use this Standard if Pressure is less than 150 PSIG.

Analytical Data: (R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: SULFUR DIOXIDE

Requested Concentration: 10 ppm
 Certified Concentration: 10.04 ppm
 Instrument Used: Ametek 921CE S/N AW-921-S321
 Analytical Method: Ultraviolet Absorption
 Last Multipoint Calibration: 3/11/2013

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: SA18706
 Ref. Std. Conc: 10.04 ppm
 Ref. Std. Traceable to SRM #: vs. 1693a
 SRM Sample #: 96-K-040
 SRM Cylinder #: CAL015390

First Analysis Data:		Date: 3/8/2013
Z: 0	R: 100.5	C: 99.6
R: 100.9	Z: 0	C: 100.2
Z: 0	C: 100.9	R: 100.6
UOM: mV		Mean Test Assay: 10 ppm

Second Analysis Data:		Date: 3/15/2013
Z: 0	R: 99.2	C: 99.8
R: 100.5	Z: 0	C: 100.6
Z: 0	C: 100.7	R: 100.1
UOM: mV		Mean Test Assay: 10.08 ppm

Analyzed by:



Jack Fu

Certified by:



Diego Vestanza



Praxair
 5700 South Alameda Street
 Los Angeles, CA 90058
 Tel: (323) 585-2154 Fax: (714) 542-6689
 PGVPID: F22016

DocNumber: 000097295

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

A LANFRANCO & ASSOC INC
 101 9488 189TH ST
 SURREY BC V4N 4

Praxair Order Number: 26862209
 Customer P. O. Number:
 Customer Reference Number:

Fill Date: 7/25/2016
 Part Number: NI CD10028E-AS
 Lot Number: 109620707
 Cylinder Style & Outlet: AS CGA 590
 Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	8/4/2024	NIST Traceable
Cylinder Number:	CC308772	Analytical Uncertainty:
9.98 %	CARBON DIOXIDE	± 0.4 %
10.95 %	OXYGEN	± 0.3 %
Balance	NITROGEN	

Certification Information: Certification Date: 8/4/2016 Term: 96 Months Expiration Date: 8/4/2024

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

O2 responses have been corrected for CO2 interference.

Analytical Data: (R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON DIOXIDE

Requested Concentration: 10 %
 Certified Concentration: 9.98 %
 Instrument Used: Horiba VIA-510 S/N 20C194WK
 Analytical Method: NDIR
 Last Multipoint Calibration: 7/18/2016

First Analysis Data:		Date: 8/4/2016	
Z: 0	R: 9.95	C: 9.98	Conc: 9.973
R: 9.96	Z: 0	C: 9.98	Conc: 9.973
Z: 0	C: 9.99	R: 9.96	Conc: 9.983
UOM: %	Mean Test Assay:		9.977 %

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: SA15063
 Ref. Std. Conc: 9.95%
 Ref. Std. Traceable to SRM #: 1674b
 SRM Sample #: 7-H-07
 SRM Cylinder #: FF10631

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %	Mean Test Assay:		0 %

2. Component: OXYGEN


Requested Concentration: 11 %
 Certified Concentration: 10.95 %
 Instrument Used: OXYMAT 5E
 Analytical Method: PARAMAGNETIC
 Last Multipoint Calibration: 7/29/2016

First Analysis Data:		Date: 8/4/2016	
Z: 0	R: 10	C: 10.96	Conc: 10.96
R: 10	Z: 0	C: 10.94	Conc: 10.94
Z: 0	C: 10.96	R: 10	Conc: 10.96
UOM: %	Mean Test Assay:		10.953 %


Reference Standard Type: GMIS
 Ref. Std. Cylinder #: CC187493
 Ref. Std. Conc: 10.00%
 Ref. Std. Traceable to SRM #: 2658a
 SRM Sample #: 72-D-28
 SRM Cylinder #: CAL016862

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %	Mean Test Assay:		0 %

Analyzed by:


 Ying Yu

Certified by:


 Maria Soberanis

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

As a global, employee-owned organisation with over 50 years of experience, Golder Associates is driven by our purpose to engineer earth's development while preserving earth's integrity. We deliver solutions that help our clients achieve their sustainable development goals by providing a wide range of independent consulting, design and construction services in our specialist areas of earth, environment and energy.

For more information, visit golder.com

Africa	+ 27 11 254 4800
Asia	+ 86 21 6258 5522
Australasia	+ 61 3 8862 3500
Europe	+ 44 1628 851851
North America	+ 1 800 275 3281
South America	+ 56 2 2616 2000

solutions@golder.com
www.golder.com

Golder Associates Ltd.
Suite 200 - 2920 Virtual Way
Vancouver, BC, V5M 0C4
Canada
T: +1 (604) 296 4200

